

76

HOSTS

55

ONLINE

21

OFFLINE

18

SNMP OK

103

ALERTAS

COBERTURA SNMP

24%

18 de 76

34%

26 de 76

SNMP Activo

Configurado

PROTOCOLO

snmpV2c26

ICMP49

ModbusTCP1

VENDORS

UNKNOWN39

SAMLEX19

ELTEK12

MEI5

VICTRON1



SNMP Hosts Activos

18 midiendo

SITIO	IP	VENDOR	BAT	CFE	SOC	CARGA	HEALTH
PDA_PLANTA-ELTEK	172.30.111.246	ELTEK	54.32V	239V	-	16.7A	95
ANTIGUA-ESTANZUELA_PLAN..	172.30.246.250	ELTEK	53.54V	247V	-	0.6A	100
MITRAS_PLANTA-ELTEK	172.30.90.98	ELTEK	53.55V	220V	50%	10.4A	98
MITRAS_INVERSOR-SAMLEX	172.30.90.102	SAMLEX	53V	-	-	422.9A	100
SENDERO_PLANTA-ELTEK	172.30.109.194	ELTEK	53.52V	242V	100%	17A	98
SAL_MECASA-RAMOS_PLANTA..	172.18.13.190	ELTEK	54.56V	215V	100%	8.2A	100
QUERÉTARO_JURIQUILLA_IN..	172.25.138.250	SAMLEX	26.8V	125.5V	-	-	93
QUERÉTARO_BANDERA_INVER..	172.25.131.162	SAMLEX	26.9V	113.6V	-	-	94
QUERÉTARO_TEC100_INVERS..	172.25.132.246	SAMLEX	26.9V	128V	-	-	94
MONTEMORELOS_INVERSOR-S..	172.30.13.226	SAMLEX	27.1V	123V	-	-	95
DENIS_INVERSOR-SAMLEX	172.30.176.238	SAMLEX	26.9V	112.7V	-	-	97
NORTE_INVERSOR-SAMLEX	172.30.91.254	SAMLEX	53.4V	-	-	295.8A	97
PURISIMA_INVERSOR-SAMLEX	172.30.99.166	SAMLEX	26.9V	111.5V	-	-	98
PDA_INVERSOR-SAMLEX	172.30.111.54	SAMLEX	56.9V	-	-	492.2A	97
QUERÉTARO_COLORADO_PLAN..	172.25.134.246	ELTEK	53.52V	223V	50%	8.3A	93
INDEPENDENCIA_PLANTA-EL..	172.26.18.20	ELTEK	53.53V	245V	100%	0.7A	98
INDEPENDENCIA_INVERSOR...	172.26.18.21	SAMLEX	53.2V	125.5V	-	-	99
HUINALA_INVERSOR-SAMLEX	172.30.119.238	SAMLEX	53.2V	121.2V	-	-	96

OFFLINE (8)

CHIHUAHUA_PANAMERICANA_INVER..	10.33.8.250
MIRASUR_INVERSOR-SAMLEX	172.30.162.38
SANTA-ROSA_INVERSOR-SAMLEX	172.30.220.70
SAN-LUIS-POTOSÍ_EDIFICIO-EME..	10.40.1.238
LOMA_INVERSOR-SAMLEX	172.30.56.66
MÉXICO_TEPETLIXPA_INVERSOR-S..	10.60.105.250
REYNOSA_MEYBI_INVERSOR-SAMLEX	172.20.47.242
QUERÉTARO_CARRTERA-57_INVERS..	10.40.11.242

Laboratorio de Independencia

● PLANTA ELTEK

ONLINE

IP: 172.26.18.20

Proto: snmpV2c

Vendor: eltek

Bat Voltage **53.45V**

CFE **247V**

SOC **100%**

Rectif. **3**

Carga **2.1A**

Rect.Curr **2A**

● INVERSOR SAMLEX

ONLINE

IP: 172.26.18.21

Proto: snmpV2c

Vendor: samlex

Bat Voltage **53.3V**

CFE **125V**

AC Output **121.1V**

Freq **59.9Hz**

CFE Ok **Si**

● VICTRON

OFFLINE

IP: 172.26.18.106

Proto: modbusTCP

Vendor: victron

SIN DATOS

● SITE MONITOR ALG

OFFLINE

IP: 172.30.20.22

Proto: icmp

Vendor: algcom

SIN DATOS

UMBRALES DE ALARMA

Bat. Voltaje

WARNING

< **51V**

CRITICAL

< **46V**

Bat. SOC

WARNING

< **40%**

CRITICAL

< **20%**

Latencia

WARNING

> **50ms**

CRITICAL

> **200ms**

Packet Loss

WARNING

> **5%**

CRITICAL

> **20%**

CFE Outage

WARNING

3 lecturas

CRITICAL

Corte confirm.

Roadmap

SNMP Coverage

