SECTION 12 30 00

STEEL COUNTERTOPS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Countertops for architectural cabinet work.

1.02 RELATED REQUIREMENTS

A. Section 224000 - Plumbing Fixtures: Sinks.

1.03 REFERENCE STANDARDS

A. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless-Steel Sheet, Strip, Plate, and Flat Bar 2015.

1.04 SUBMITTALS

- A. See Section 013000 Administrative Requirements for submittal procedures.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Specimen warranty.
- C. Shop Drawings: Complete details of materials and installation; combine with shop drawings of cabinets and casework specified in other sections.
- D. Selection Samples: For each finish product specified, color chips representing manufacturer's full range of available colors and patterns.
- E. Verification Samples: For each finish product specified, minimum size 6 inches (150 mm) square, representing actual product, color, and patterns.
- F. Installer's qualification statement.
- G. Installation Instructions: Manufacturer's installation instructions and recommendations.

1.05 QUALITY ASSURANCE

A. Installer Qualifications: Company specializing in performing work of the type specified in this section, with not less than three years of documented experience.

1.06 FIELD CONDITIONS

A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

PART 2 PRODUCTS

2.01 COUNTERTOPS

- A. Stainless Steel Countertops: , Type 304, stainless steel sheet; 16 gauge, 0.0625 inch (1.59 mm) nominal sheet thickness.
 - 1. Finish: 4B satin brushed finish.
 - 2. Exposed Edge Shape: Bullnose with return; 5/8 inch (16 mm) radius, return to face of case; reinforced with hardwood or steel.
 - 3. Back and End Splashes: Same material; welded 1/4 inch (6 mm) radius coved joint to countertop; square top edge with 1 inch (25 mm) wide top surface and minimum 1/2 inch (12 mm) turndown.
 - 4. Splash Dimensions: 4 inch (100 mm) high by 1 inch (25 mm) thick, unless otherwise indicated.
 - 5. Associated Window Sills: Same material, same thickness.

2.02 FABRICATION

- A. Fabricate tops and splashes in the largest sections practicable, with top surface of joints flush.
 - 6. Join lengths of tops using best method recommended by manufacturer.
 - 7. Fabricate to overhang fronts and ends of cabinets 1 inch (25 mm) except where top butts against cabinet or wall.
 - 8. Prepare all cutouts accurately to size; replace tops having improperly dimensioned or unnecessary cutouts or fixture holes.
- B. Provide back/end splash wherever counter edge abuts vertical surface unless otherwise indicated.
 - Secure to countertop with concealed fasteners and with contact surfaces set in waterproof glue.
 - 10. Height: 4 inches (102 mm), unless otherwise indicated.
- C. Stainless Steel: Fabricate tops up to 144 inches (3,657 mm) long in one piece including nosings and back and end splashes; accurately fitted mechanical field joints in lengths over that dimension are permitted.
 - 11. Weld joints; grind smooth and polish to match.
 - 12. Provide stainless steel hat channel stiffeners, welded or soldered to underside, where indicated on drawings.
 - 13. Provide wall clips for support of back/end splash turndowns.
 - 14. Sound Deadening: Apply water resistant, fire resistant sound deadening mastic to entire bottom surface.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.
- C. Verify that wall surfaces have been finished and mechanical and electrical services and outlets are installed in proper locations.

3.02 PREPARATION

A. Clean surfaces thoroughly prior to installation.

FRANKLIN CO. ANIMAL CONTROL FACILITY

B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.03 INSTALLATION

- A. Securely attach countertops to cabinets using concealed fasteners. Make flat surfaces level; shim where required.
- B. Attach stainless steel countertops using stainless steel fasteners and clips.
- C. Seal joint between back/end splashes and vertical surfaces.

3.04 TOLERANCES

- A. Variation From Horizontal: 1/8 inch in 10 feet (3 mm in 3 m), maximum.
- B. Offset From Wall, Countertops: 1/8 inch (3 mm) maximum; 1/16 inch (1.5 mm) minimum.
- C. Field Joints: 1/8 inch (3 mm) wide, maximum.

3.05 CLEANING

A. Clean countertops surfaces thoroughly.

3.06 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Date of Substantial Completion.

END OF SECTION