



Pixie-Net

User Manual

Release 2.30

August 18, 2023

Hardware Versions:

A	0xA990
B (12bit)	0xA991
B (14bit)	0xA9A1

Software Release: 2.30

Firmware Versions and Variants:

Standard	0xHWHW_0230
PSA	0xHWHW_1228
PTP	0xHWHW_2230

XIA LLC
2744 East 11th St
Oakland, CA 94601 USA
Email: support@xia.com
<http://www.xia.com/>

Information furnished by XIA LLC is believed to be accurate and reliable. However, no responsibility is assumed by XIA for its use, or for any infringements of patents or other rights of third parties which may result from its use. No license is granted by implication or otherwise under any patent or patent rights of XIA. XIA reserves the right to change hardware or software specifications at any time without notice.

Contents

Safety	6
Specific Precautions	6
Power Source	6
User Adjustments/Disassembly	6
Detector and Preamplifier Damage.....	6
Voltage Ratings.....	6
Servicing and Cleaning	6
Linux Passwords	6
Linux Backup.....	6
Warranty Statement	7
Contact Information:.....	7
Manual Conventions	8
1 Introduction.....	9
1.1 Pixie Net Features	9
1.2 Specifications (4 channel 12/250 and 14/250).....	10
1.3 System Requirements.....	11
1.3.1 Drivers and Software	12
1.3.2 Detector Signals	12
1.3.3 Power Requirements	12
1.3.4 Connectors and Cabling.....	12
1.4 Software and Firmware Overview	12
1.5 Support.....	13
2 Setup	14
2.1 Power	14
2.2 Serial Port (USB-UART).....	14
2.3 SSH login.....	15
2.4 Web Interface.....	15
2.5 SMB (Samba).....	15
2.6 Required Initial Linux Commands.....	16
2.7 Useful Linux Commands	16
2.8 Direct Network Connection between Pixie-Net and a Windows PC	17
3 Pixie-Net Operation	19
3.1 Adjust Settings.....	19
3.2 Basic Data Acquisition.....	20
3.3 User Interface Options	21
3.3.1 Terminal	21
3.3.2 Terminal and Webpages.....	21
3.3.3 Terminal, SMB and Windows programs	22
3.3.4 Graphical User Interface on Host PC	22
3.3.5 Webpage-Only Operation	23
3.3.6 Web API.....	24
3.3.7 On-board ROOT Graphical User Interface	26
3.4 Optimizing Parameters.....	26
3.4.1 Energy Filter Parameters.....	26
3.4.2 Threshold and Trigger Filter Parameters	26

3.4.3	Decay Time	27
3.4.4	Baselines and ADC calibration	27
4	API functions	28
4.1	progfippi.....	28
4.2	gettraces, cgitraces	28
4.3	findsettings	29
4.4	runstats, cgistats	29
4.5	startdaq.....	30
4.6	acquire.....	31
4.7	coinedaq	32
4.8	clockprog.....	33
4.9	polCSR.....	33
4.10	avgadc, cgiavgtraces	33
4.11	cgireadsettings.....	34
4.12	cgiwritesettings	35
5	Web Pages.....	36
5.1	index.html	36
5.2	adcpage.html, cgitraces.cgi	38
5.3	mcapage.html	39
5.4	rspage.html, cgistats.cgi	39
5.5	psahistpage.html.....	40
5.6	psahistprojpage.html	41
5.7	psasurfacepage.html.....	42
5.8	lmtablepage.html.....	43
5.9	cgiwaveforms.cgi	44
5.10	avgadcpage.html, cgiavgtraces.cgi.....	45
5.11	Web Operations (webops/webopsindex.html)	46
5.12	ADC Setup (webops/adcsetuppage.html)	47
5.13	DAQ Control (webops/ daqpage.html)	48
5.14	All Settings (webops/allsettingspage.html).....	49
6	Parameters in the Settings Files	50
6.1	System Parameters	50
6.2	Module Parameters	51
6.3	Channel Parameters	53
7	Data Formats.....	57
7.1	List Mode Data Files.....	57
7.1.1	List mode files with waveforms (Run Type 0x500)	57
7.1.2	List mode files without waveforms (Run Type 0x501)	58
7.1.3	List mode files with PSA (Run Type 0x502).....	59
7.1.4	Coincidence list mode files without waveforms (Run Type 0x503).....	59
7.1.5	Binary list mode files with waveforms (Run Type 0x400).....	59
7.1.6	Binary coincidence list mode files with waveforms (Run Type 0x402).....	60
7.2	Run Statistics Files.....	61
7.3	MCA Files.....	62
7.4	PSA Files	62

8	Module Registers Visible to Linux	63
8.1	Input Registers	63
8.2	Event Registers	64
8.3	Run Statistics Registers.....	65
9	Channel Registers Visible to Linux	66
9.1	Input Registers	66
9.2	Event Registers	67
9.3	Run Statistics Registers.....	68
10	Linux Configuration	70
10.1	Licensing Information.....	70
10.2	Software Information.....	70
10.2.1	Ubuntu 15.....	71
10.2.2	Ubuntu 18.....	71
10.2.3	Systemd startup routine to configure parameters.....	73
10.2.4	Other configurations	73
10.3	Other Settings.....	73
10.3.1	Static IP address	73
11	Theory of Operation.....	75
11.1	Digital Filters for γ -ray Detectors	75
11.2	Trapezoidal Filtering in a Pixie Module	77
11.3	Baselines and Preamplifier Decay Times	78
11.4	Thresholds and Pile-up Inspection.....	79
11.5	Filter Range.....	81
11.6	Data Capture Process	81
11.7	Dead Time and Run Statistics.....	82
11.7.1	Definitions.....	82
11.7.2	Count time and dead time counters.....	85
11.7.3	Count Rates	86
11.7.4	Dead time correction in the Pixie-Net.....	87
11.8	Other Functions.....	88
11.8.1	Capturing triggered, averaged ADC waveforms.....	88
12	Hardware and Firmware Variants	89
12.1	Pulse Shape Analysis and Constant Fraction Timing	89
12.1.1	Overview	89
12.1.2	PSA Input Parameters	91
12.1.3	PSA Return Values	91
12.1.4	Reduced General Purpose Functionality	92
12.2	IEEE 1588 Precision Timing Protocol.....	93
12.2.1	Overview	93
12.2.2	PTP Stack Software: LinuxPTP	94
12.2.3	PTP PHY Control Software: ptp-mii-tool.....	94
12.2.4	PTP Clock PLL Control Software: clockprog	95
12.2.5	PTP parameter settings.....	95
12.2.6	Linux Shell Scripts for PTP operation	96
12.2.7	List Mode Data Analysis.....	97
12.2.8	Reduced General Purpose Functionality	98
12.3	ADC Variant with 14 Bit Precision	99

13	Hardware Information.....	100
13.1	Jumpers	100
13.1.1	Revision A Modules.....	100
13.1.2	Revision B Modules.....	100
13.2	HDMI GPIO Connector Pinout.....	100
13.3	PMOD Connector	102
14	Igor Pro GUI.....	103
14.1	Introduction and Setup.....	103
14.2	Operation via web API (Recommended).....	104
14.3	Operation via Serial Port.....	106
14.4	Results.....	107
14.4.1	Oscilloscope.....	107
14.4.2	MCA Spectrum.....	107
14.4.3	Run Statistics Table	108
14.4.4	List Mode Traces	109
14.5	Web API coding example	109

Safety

Please take a moment to review these safety precautions. They are provided both for your protection and to prevent damage to the Pixie module and connected equipment. This safety information applies to all operators and service personnel.

Specific Precautions

Power Source

The Pixie-Net module is powered through an AC/DC wall adapter. The default adapter has a variety of AC plug attachments for different localities. Please remember to shut down the Linux OS before removing the power plug from the Pixie-Net.

User Adjustments/Disassembly

To avoid personal injury, and/or damage, always disconnect power before accessing the Pixie module's interior. There are a few jumpers related to clocking inside the box and there are debug push buttons and headers experienced users may want to use.

Detector and Preamplifier Damage

The Pixie module can provide +5V power and a 0..5V control voltage, intended for active PMT bases. The +5V power comes up immediately when the Pixie is connected to power, the control voltage is undefined until the Linux system is booted and basic configuration has been applied.

Please review all instructions and safety precautions provided with these components before powering a connected system.

Voltage Ratings

Signals on the analog inputs (gold SMA connectors) must not exceed $\pm 3.5V$. Exceptions apply for certain attenuation and termination settings, see Appendix.

Signals on the digital inputs (gold MMCX connector and HDMI GPIO connector) must not exceed 3.3V. Please review the pinout in the appendix before making any connections.

Servicing and Cleaning

To avoid personal injury, and/or damage to the Pixie module or connected equipment, do not attempt to repair or clean the inside of these units.

Linux Passwords

The Pixie-Net Linux OS comes with default user IDs and passwords for 1) SSH login, 2) SMB file sharing, and 3) Web Operations as described below. Users should immediately change these passwords, especially when the Pixie-Net is connected to external networks. Don't let hackers take over your Pixie-Net!

Linux Backup

The Pixie-Net Linux OS is stored on a removable SD card. SD cards' file systems can become corrupted, which would crash the Linux system and make the Pixie-Net unable to operate. Therefore periodic backup of the SD card is recommended, for example using Win32DiskImager. (Byte for byte copy is required).

Note that all Linux passwords are stored on the SD card.

Warranty Statement

XIA LLC warrants that this product will be free from defects in materials and workmanship for a period of one (1) year from the date of shipment. If any such product proves defective during this warranty period, XIA LLC, at its option, will either repair the defective products without charge for parts and labor, or will provide a replacement in exchange for the defective product.

In order to obtain service under this warranty, Customer must notify XIA LLC of the defect before the expiration of the warranty period and make suitable arrangements for the performance of the service.

This warranty shall not apply to any defect, failure or damage caused by improper uses or inadequate care. XIA LLC shall not be obligated to furnish service under this warranty a) to repair damage resulting from attempts by personnel other than XIA LLC representatives to repair or service the product; or b) to repair damage resulting from improper use or connection to incompatible equipment.

THIS WARRANTY IS GIVEN BY XIA LLC WITH RESPECT TO THIS PRODUCT IN LIEU OF ANY OTHER WARRANTIES, EXPRESSED OR IMPLIED. XIA LLC AND ITS VENDORS DISCLAIM ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. XIA'S RESPONSIBILITY TO REPAIR OR REPLACE DEFECTIVE PRODUCTS IS THE SOLE AND EXCLUSIVE REMEDY PROVIDED TO THE CUSTOMER FOR BREACH OF THIS WARRANTY. XIA LLC AND ITS VENDORS WILL NOT BE LIABLE FOR ANY INDIRECT, SPECIAL, INCIDENTAL, OR CONSEQUENTIAL DAMAGES IRRESPECTIVE OF WHETHER XIA LLC OR THE VENDOR HAS ADVANCE NOTICE OF THE POSSIBILITY OF SUCH DAMAGES.

Contact Information:

XIA LLC
31057 Genstar Rd.
Hayward, CA 94544 USA

Telephone: (510) 401-5760
Downloads: <http://support.xia.com>
Hardware Support: support@xia.com
Software Support: support@xia.com

Manual Conventions

The following conventions are used throughout this manual

Convention	Description	Example
»	The » symbol leads you through nested menu items and dialog box options.	The sequence File»Page Setup»Options directs you to pull down the File menu, select the Page Setup item, and choose Options from the sub menu.
Bold	Bold text denotes items that you must select or click on in the software, such as menu items, and dialog box options.	...click on the MCA tab.
[Bold]	Bold text within [] denotes a command button.	[Start Run] indicates the command button labeled Start Run.
Monospace	Items in this font denote text or characters that you enter from the keyboard, sections of code, file contents, and syntax examples.	Setup.exe refers to a file called “setup.exe” on the host computer.
“window”	Text in quotation refers to window titles, and quotations from other sources	“Options” indicates the window accessed via Tools»Options .
<i>Italics</i>	Italic text denotes a new term being introduced , or simply emphasis	<i>peaking time</i> refers to the length of the slow filter. ...it is important first to set the energy filter Gap so that SLOWGAP to <i>at least one unit greater than</i> the preamplifier risetime...
<Key> <Shift-Alt-Delete> or <Ctrl+D>	Angle brackets denote a key on the keyboard (not case sensitive). A hyphen or plus between two or more key names denotes that the keys should be pressed simultaneously (not case sensitive).	<W> indicates the W key <Ctrl+W> represents holding the control key while pressing the W key on the keyboard
<i>Bold italic</i>	Warnings and cautionary text.	<i>CAUTION: Improper connections or settings can result in damage to system components.</i>
CAPITALS	CAPITALS denote DSP parameter names	SLOWLEN is the length of the slow energy filter
SMALL CAPS	SMALL CAPS are used for panels/windows/graphs in the GUI.	...go to the MCADISPLAY panel and you see...

1 Introduction

The Pixie-Net is a Zynq System on Module (SoM) combined with an ADC input board. The Zynq is a combination of an FPGA (Programmable Logic, PL) with an ARM processor (Processing System, PS). The PL captures the ADC data and applies digital pulse processing. The PS runs a basic Linux OS with gcc, webserver, etc; it has USB and Ethernet peripherals and 1GB of memory.

1.1 Pixie Net Features

The Pixie-Net is designed to capture pulses from a radiation detector and compute pulse heights, tag the time of arrival, build MCA pulse height spectra and optionally perform pulse shape analysis.

- Designed for
 - high precision γ -ray spectroscopy with HPGe detectors,
 - timing with fast scintillators (NaI, LaBr₃, etc),
 - pulse shape analysis to extract time, position, and/or particle type in segmented or strip detectors, phoswich detectors, or neutron detectors
 - coincidence acquisition
- 12-14 bit, 250 MSPS ADC, 4 channels
- Programmable gain and input offset.
- Programmable pulse height and pileup inspection parameters include trigger filter length, energy filter length, decay time, threshold, and rejection criteria.
- Triggered synchronous waveform acquisition across channels and modules.
- Simultaneous amplitude measurement, waveform capture, and pulse shape analysis.
- On-board MCA memory
- Configurable digital inputs and outputs
- Oscilloscope mode for triggered ADC data with programmable sampling intervals.
- Embedded Linux environment, acting as a standalone PC with built-in SD card drive, USB host, 10/100/1000 Ethernet, webserver, GPIO
- Open source DAQ software

1.2 Specifications (4 channel 12/250 and 14/250)

Front Panel I/O	
Signal Input (4x)	4 analog SMA inputs. Programmable input impedance: 50Ω and $5k\Omega$. Input range: After termination and attenuation, up to $\pm 1.25V$ DC can be added to compensate signal DC offsets. After DC offset compensation, signals in the range from 0V to ($2V/\text{analog gain}$) are accepted by the ADC. (See below for analog gain values)
Pulser Output	1 MMCX coaxial connector “PULSE” Periodic, exponentially decaying reference pulser. Programmable on/off
Control Voltage Output	1 MMCX coaxial connector “CTRL” 0..5V programmable via DAC
Rear Panel I/O	
Logic Input/Output	General Purpose I/O connected to programmable logic: 1 MMCX coaxial connector “VETO” input only default use: Veto signal to suppress event triggering 2.5V logic, 5V compatible 1 micro HDMI connector with 13 GPIO signals (<u>not video</u>) single ended or differential can be used as clock input factory set to 5V (default) or 2.5V logic. PTP variant: PTP and syncE compatible Ethernet (with adapter)
Power	12V DC in. AC adapter requirements: 12V, 18W, Barrel Plug 2.1mm I.D. x 5.5mm O.D., center positive 5V DC out MMCX coaxial connector “5V” Usage: typical ~10W, peak ~14W
PMOD	12-pin 0.1” connector for 8 I/O signals, 3.3V power, GND Compatible with PMOD I/O modules (I2C, GPIO, serial, wifi, GPS, ...)
Clocks	1 MMCX coaxial connector “CLK”, programmable PTP clock out (PTP variant only, 3.3V) or external clock in (any variant, internal jumpers, 2.5V) 1 MMCX coaxial connector “PPS” programmable PTP trigger (PTP variant only), 3.3V, output only

Processor	1 USB 2.0 1 USB-UART 1 RJ45 Ethernet 1 SD card slot 3 LEDs
Embedded Processing	
Processor	Xilinx Zynq
Data Interfaces	10/100/1000 Ethernet USB 2.0 (host) USB-UART
Memory	1 GB of DDR3 SDRAM 128 Mb of QSPI Flash 16 GB micro SD card (removable)
Operating System	Linux (Xillinux – based on Ubuntu LTS 12.04, 15, or 18.04 LTS) Operates from Linux partition on SD card
Digital Controls	
Gain	Coarse analog gain: 250 MSPS variant: 2 gain settings: 2 and 5 Other variants: please contact XIA Digital gain: Arbitrary gain factor for channel matching
Offset	DC offset adjustment from -1.25V to $+1.25\text{V}$, in 65535 steps.
Shaping	Trapezoidal filter with peaking times 0.048 to $63.4\ \mu\text{s}$ Adjustable flat top to eliminate ballistic deficit effects
Trigger	Digital trapezoidal trigger filter with adjustable threshold. Rise time and flat top set independently.
Coincidence	Programmable coincidence window: 40 to 1016 ns Reject unwanted hit patterns of the 4 channels
Data collection	MCA number of bins 1Ki to 32Ki Waveform lengths and pre-trigger delay List mode data format (text, binary, content)
Data Outputs	
Spectrum	1024-32768 bins per channel, 32 bit deep (4.2 billion counts/bin). Additional memory for sum spectrum for clover detectors.
Statistics	Real time, counting time, filter dead time, input and throughput counts.
List mode event data	Pulse height (energy), time stamps, pulse shape analysis results, waveform data (up to 4Ki samples) and ancillary data like hit patterns.

Table 1-1. Specifications for the Pixie-Net

1.3 System Requirements

The digital spectroscopy system considered here consists of a Pixie-Net and a gamma ray detector with appropriate power supplies. A PC, smartphone or tablet is required to communicate with the Pixie-Net, but data acquisition is fully contained in the Pixie-Net itself.

1.3.1 Drivers and Software

The Pixie-Net operates with an embedded Linux system that includes all software and drivers to communicate with external devices via Ethernet or USB. It can

- Make DAQ results available via webserver
- Read and write USB drives for data exchanges
- Share files over a Windows network

For higher convenience of communication and data analysis, we provide the Pixie Viewer, based on Wavemetrics' Igor Pro. (Igor version 8 or higher is required). Alternative interfaces are under development (LabView, ROOT (under Linux), MATLAB, etc).

1.3.2 Detector Signals

The Pixie-Net is designed for fast rising, exponentially decaying signals. Step pulses and short non-exponential pulses can be accommodated with specific parameter settings. Staircase type signals from reset preamplifiers generally need to be AC coupled.

Detector signals must not exceed $\pm 3.5V$.

1.3.3 Power Requirements

The Pixie-Net consumes roughly 10-14 W, requiring the following currents from the AC adapter:

12V up to 1.5 A

1.3.4 Connectors and Cabling

The Pixie-Net uses SMA connectors for the analog inputs from the detectors. SMA to BNC adapter cables are provided with the module.

MMCX connectors are used for power, analog outputs, and digital input/outputs. MMCX to BNC adapter cables are provided with the module.

A micro HDMI connector is used for 13 additional digital inputs and outputs, but not video. HDMI cables are widely available and not provided with the module. For the PTP variant, the micro HDMI connector carries the Ethernet connection, which requires cabling adapters.

1.4 Software and Firmware Overview

The DAQ software of the Pixie-Net consists of a small set of C programs (API functions) applying settings to the PL, reading data from the PL, and storing it on the SD card (or network drives). The API functions are called from the Linux command line or as CGI scripts from a web page. DAQ results can be viewed or downloaded via the web page, or copied over the network. Acquisition parameters are stored in an .ini file that can be edited by the user to adjust parameter settings.

Firmware code for the PL on-board pulse processing functions is loaded to the PL as part of the powerup boot sequence.

Users may modify the API functions (source code and gcc compiler is included in the Linux environment on the SD card). Applications can be executed from the SD card or a mounted USB drive.

More sophisticated graphical user interfaces can be developed, providing control buttons and data analysis functions. One such interface is based on Igor Pro; please contact XIA for details and demo code for other implementations.

1.5 Support

A unique benefit of dealing with a small company like XIA is that the technical support for our sophisticated instruments is often provided by the same people who designed them. Our customers are thus able to get in-depth technical advice on how to fully utilize our products within the context of their particular applications.

Please read through the following sections before contacting us. Contact information is listed in the first few pages of this manual.

2 Setup

When powered up, the Pixie-Net automatically boots the FPGA configuration and starts the Linux OS. There are several ways for a user to connect to the Pixie-Net Linux OS:

1. Serial port via USB-UART
2. Network SSH terminal
3. Web server
4. SMB (Samba) file sharing

The typical procedure for setup would be to first power up the Pixie-Net (2.1), then install and configure drivers for the serial port on a USB master PC (2.2). Log on via serial port terminal, find the Pixie-Net's IP address, and execute a few setup programs (2.5). After that, the Pixie-Net can be operated through terminal, web interface and/or SMB.

2.1 Power

To power up the Pixie-Net, simply connect the 12V DC power plug from the AC adapter. The center pin must be positive and the adapter must be rated for 18W or more. *Several outputs and internal settings are undefined after powerup, so it is recommended to log in quickly via serial port or SSH and apply the settings.*

To power down the Pixie-Net, first shut down the Linux OS (type `halt`), then remove the 12V DC power plug (and UART cable).

2.2 Serial Port (USB-UART)

The serial port connection requires a PC driver to map the UART to a serial port and a terminal running on the USB master PC. Windows installation consists of the following steps:

5. Download and extract/install the Silicon Labs CP210x USB-to-UART driver from www.silabs.com/products/development-tools/software/usb-to-uart-bridge-vcp-drivers. For more information, see microzed.org/sites/default/files/documentation/CP210x_Setup_Guide_1_2.pdf
6. Download and install Tera Term (or other suitable terminal program). See <http://ttssh2.osdn.jp/>
7. Connect USB cable between Pixie-Net and PC and power up the Pixie-Net (see 2.1) (PC: any USB port, Pixie-Net: port labeled UART)
8. From the Silicon Labs installation, run CP210xVCPInstaller_x64.exe to create a COM port
 - Find the new COM port's number in the Windows device manager
 - The COM port assignment is device specific, so this has to be repeated every time switching to a different Pixie-Net unit. For the same Pixie-Net, this is a one-time operation.
9. Open Tera Term.
 - Connect via the serial port showing the COM number above
 - Select Setup > Serial port. Defaults are ok, except baud rate must be 115200
 - Adjust the font and size if desired

- Login credentials are required for Linux login via serial port on Ubuntu 18, but not on Ubuntu 12 and 15. Default ID/PW is **root/xia17pxn** (*please change*).

On a Linux system, it is possible to use the Minicom utility as for serial port I/O. Usually no installation or drivers are required. It can be configured via

```
sudo minicom -s
```

and by specifying *ttyUSB0* as the port, with *no* HW flow control. See also <https://help.ubuntu.com/community/Minicom>.

2.3 SSH login

Tera Term or another suitable program can be used to log in via the network once the Pixie-Net is powered, connected to a network, and its IP address is known. The IP address can be found by

- connecting via serial port terminal as described above, and typing `ifconfig`
- log on to router, see list of connected devices
- just try the one it had before, IP addresses seem fairly persistent through power cycles

To connect, open a terminal and make connection to the Pixie-Net's IP address. Default ID/PW is **root/xia17pxn** (*please change*).

Two possible free SSH terminal program for Android are "SSH Client" and "JuiceSSH", allowing login from a tablet or smartphone.

2.4 Web Interface

Any web browser can be used to log in via the network once the Pixie-Net is powered, connected to a network, and its IP address is known. The IP address can be found by

- connecting via serial port terminal as described above, and typing `ifconfig`
- log on to router, see list of connected devices
- just try the one it had before, they seem fairly persistent through power cycles

To connect, enter Pixie-Net's IP address as the web address in your browser. Any browser should work; XIA uses Firefox and does not test for compatibility with other browsers. No password is required for the Pixie-Net home page, however, login is required for web operations duplicating terminal access. The default ID/PW is **webops/xia17pxn** (*please change*).

For proper operation of most links in the home page, prior execution of a function in the Linux terminal is required. See below for details.

2.5 SMB (Samba)

The Pixie-Net Linux OS is running Samba, a "Windows interoperability suite of programs for Linux and Unix". It allows the files in the Linux partition of the Pixie-Net SD card to

be shared with Windows networking. By default, only one folder is shared (/var/www) which is the location of the API functions.

To connect, type \\192.168.1.xxx\PNvarwww in the Windows Explorer location bar, where 192.168.1.xxx is the IP Address of the Pixie-Net found as above and PNvarwww is the name given to /var/www for file sharing purposes in Samba. Windows will prompt for login; the default ID/PW is **root/xia17pxn** (*please change*).

The settings file `settings.ini`, output data files, and all (source and executable) files of the API functions can now easily be copied or edited with Windows tools and programs. However, to *execute* the API functions, serial port or SSH login is required (or in some cases, API functions can be executed from the web interface)

2.6 Required Initial Linux Commands

Once logged on via the Linux terminal or the web operations page, the following steps **must** be performed:

1. Change directory: `cd /var/www`
This is the directory visible via the web server. Data created by execution of XIA API functions can be read via the web browser from this directory. For convenience, it contains a “release” of all XIA SW functions and is used as the default working directory. (Not required for web operations page)
2. Adjust permissions: `chmod 777 /dev/uio0`
This allows cgi functions called via the web interface to access the FPGA register space. Only required in OS version older than release 1.2
3. Apply settings to FPGA: `./progfippi`
4. Automatically set a few basic parameters (and resolve random channel swapping):
`./findsettings`
This should be performed with the detector connected, with the correct polarity and termination setting.

2.7 Useful Linux Commands

The following commands may be helpful

1. Type `ifconfig` to find the IP address
The network does not come up by itself occasionally. This appears to coincide with the webpage being open in a browser during (re)boot. For a change of restart, type `sudo /etc/init.d/networking restart` else power cycle
2. Type `more /sys/devices/amba.0/f8007100.ps7-xadc/temp` to get the temperature of the Zynq chip. In SW 1.2 and higher using Ubuntu 15, the temperature is reported only as a raw number in `/sys/devices/soc0/amba/f8007100.adc/iio:device0/in_temp0_raw`; the actual temperature can be computed by subtracting 2219 and multiplying with 0.12304. ADC and Zynq temperatures are also reported in the run statistics and by `./progfippi`
3. To change a parameter value in the settings file without opening/editing/closing the file, a sed command as follows can be used:


```
sed -i '/RUN_TYPE/c RUN_TYPE      1281' settings.ini
This replaces (-i = in the file) the line containing the string "RUN_TYPE" with the
text "RUN_TYPE 1281".
```

4. To mount a USB drive (e.g. to copy data or SW updates), type
`mount /dev/sda1 /mnt/usb`
 /var is not a suitable directory to mount the USB stick, as it confuses the web server
5. Type `date` to verify Linux time automatically updated to UTC
6. Use the `mount` command to mount external network drives. For example, to mount NASdrive/data from a PC with IP address 192.168.1.123, type
`mount //192.168.1.123/data /mnt/data -o
"username=[user],password=[passwd]"`
 with the appropriate values filled in for [user] and [passwd]
7. To mount the SD card boot partition to a folder /mnt/sd, execute
`mount /dev/mmcblk0p1 /mnt/sd`
 this is useful to update the boot files without removing the SD card. The Pixie-Net has to be rebooted before the new boot files become effective.
8. To clear the command line history, type
`history -c`
`history -w`

2.8 Direct Network Connection between Pixie-Net and a Windows PC

The above description of setup and operation of the Pixie-Net assumes both Pixie-Net and the user device (PC, tablet, smartphone) are connected to a local network with DHCP server and gateway. Instead, it is possible to directly connect the Pixie-Net to a laptop or desktop with a standard Ethernet cable (no crossover cable required). However, a number of configurations have to be set manually:

1. On the Pixie-Net terminal, type `ifconfig eth1 up 192.168.1.86` to bring up the Ethernet connection and assign the IP number. In some cases, eth0 or eth2 has to be used instead of eth1.
2. On the Windows PC (here Windows 7), go to Start > Control Panel > Network and Sharing Center > Change Adapter Settings > Local Area Connection



In the Local Area Connection “Properties” dialog, select “Internet Protocol Version 4 (TCP/IPv4)” and click “Properties”.

In the properties dialog, set IP address, subnet mask, and gateway as shown above.
(The gateway is equal to Pixie-Net’s IP address.)

Note: The network will not be able to connect to the internet. The date/time of the Pixie-Net will likely be initialized to 1970.

3 Pixie-Net Operation

Basic operation of the Pixie-Net uses a combination of terminal commands and web interface. The former controls all data taking and requires login to the system. The latter displays data and is accessible to anyone. This provides a measure of security in instrument control while making it convenient to view data.

3.1 Adjust Settings

The pulse processing parameters must be adjusted (once) to match the detector characteristics. This includes analog settings such as gain and offset, and pulse processing parameters such as decay time and trigger threshold.

All settings are stored in an .ini file. The default settings file is configured for the Pixie-Net internal pulser. This file, *defaults.ini*, contains all the parameter settings as described in section 6. Settings are grouped into system (e.g. requested run time), module (e.g. coincidence patterns), and channel (e.g. offset). A condensed settings file, *settings.ini*, contains the most important parameters and **will override the defaults**. The default method to change settings is to edit *settings.ini* and then execute `./progfippi` to apply them to the FPGA. If necessary, lines with additional parameters can be copied from *defaults.ini* into *settings.ini*; also lines can be deleted from *settings.ini* if there is no need to vary specific parameters. The file *defaults.ini* should be considered a read-only file. Editing can be accomplished with a built-in Linux editor through the terminal (for example VI) or by opening the file in a Windows editor through the SMB file sharing.

The most important parameters for initial setup are

REQ_RUNTIME	Requested runtime of the data acquisition
MCSRTERM01_01	If 1, channel 0 and 1 inputs are terminated with 50 Ohm, else high-Z
MCSRTERM23_02	If 1, channel 2 and 3 inputs are terminated with 50 Ohm, else high-Z
RUN_TYPE	0x301 for MCA only, 0x400-0x503 for various list mode runs
CCSRA_INVERT_05	If 1, invert incoming signal
ANALOG_GAIN	Currently limited to 2 or 5
DIG_GAIN	Arbitrary gain factor for energies in MCA spectra and list mode events
VOFFSET	DC offset
TAU	Exponential decay time of the input signal

(See also section 3.4 for optimizing trigger and energy filter settings)

When set up correctly, the signal baseline should be at approximately 400 ADC steps. The polarity and gain should be set such that pulses start with a fast rise and decay back down to baseline, and do not go out of the ADC range (max 4096 steps for a 12 bit ADC). The decay time must be measured and specified as the parameter TAU. This is best verified by opening/refreshing the Pixie-Net ADC page in the web browser, or executing `./gettraces` and viewing the resulting ADC.csv file. You can also open/refresh the Run Statistics page in the web browser or execute `./runstats` and read the output parameters in the resulting RS.csv file. The current input count rate, out of range fraction, temperatures, and FPGA system time will update even when no run is in progress. The function `./findsettings` can assist in finding parameters such as DC offset. It also resolves random channel swapping between channels 0/1 and 2/3.

The typical startup sequence (see also section 2.6) is to run `./progfippi` pretty much as soon as the modules is powered up to initialize all parameters in the pulse processing logic. Then, with detectors connected, run `./findsettings` to resolve a possible random channel swap and to find the offsets. If you prefer to keep the original offsets from `settings.ini`, run `./progfippi` again to overwrite the changes that `./findsettings` made to the offsets, else update `settings.ini` with the offsets found by `./findsettings` to keep applying the new offsets in all future executions of `./progfippi`.

Every time there is a change in `settings.ini`, run `./progfippi` to apply the changes to the pulse processing logic. After every power up, `./findsettings` must be run once to resolve the possible random channel swap. Changes in analog gain and input termination likely affect the offsets, so `./findsettings` should be executed again after such changes.

3.2 Basic Data Acquisition

1. In the terminal, type `./startdaq` or `./acquire` to start run with current settings.
The screen will be updated with print statements of the runtime
2. In the browser, navigate to the MCA page (“view spectra”) or the Run Statistics page (“view run statistics”) under DAQ Monitoring.
Refresh these pages with browser button to see updates during DAQ
3. < wait > *Currently the only way to stop is ctrl-c*
4. When the DAQ finishes in the terminal, the final MCA, the run statistics, and the list mode data files have been created. *The filenames are fixed to MCA.csv, RS.csv and LMdata.dat/.txt for ./startdaq while ./acquire allows arbitrary list mode file names.*
5. In the browser, the data files can be viewed or downloaded (under “DAQ Results”)
6. In the terminal, the data files can be copied to local USB drive or network drive
7. In a Windows Explorer window pointing to <\\<Pixel Net IP>\PNvarwww>, the data files can be copied or opened by Windows tools and programs.

3.3 User Interface Options

There are a variety of interface options to operate the Pixie-Net. They range from basic terminal and file I/O to plug-ins for data acquisition or data analysis software. Fundamentally, the Pixie-Net communicates through generic interfaces such as serial port and Ethernet, so that any program emulating a serial port and reading files from a network drive can be used to operate the system. A few examples are listed in the following sections


3.3.1 Terminal

```
10.168.1.60 - net@localhost: /var/www VT
File Edit Setup Control Windows Help
PixieNetCommon.o backup d3.v3.min.js  progs/progs.html.backup
PixieNetCommon.h backup d3.v3.min.js  progs/progs.html.backup
PixieNetCommon.o d3graph-combined.js  progs/progs.html.backup
PixieNetCommon.o findsettings.o  epage.html
PixieNetCommon.o findsettings.o  runstate.o
PixieNetConfig.h gettraces.o  runstate.o
PixieNetConfig.o gettraces.o  runstate.o
PixieNetConfig.o gettraces.cgi  settings.ini.backup
PixieNetConfig.h backup gettraces.cgi  settings.ini.backup
PixieNet_Manual.doc gettraces.o  shared.o
PixieNet_Manual.pdf index.html  startdaq.o
pixie.net.manual.pdf index.html  startdaq.o
pixie.net.manual.jpg index.html  startdaq.o
pixie.net.manual.xls index.html  startdaq.o
pixie.net.manual.htm index.html  startdaq.o
pixie.net.manual.htm  startdaq.o
pixie.net.manual.htm  startdaq.o
root@localhost:/var/www# ./progfippi
TRACE LENGTH[1] will be rounded off to + 1.280000 us, 320 samples
TRACE LENGTH[1] will be rounded off to + 0.256000 us, 64 samples
TRACE LENGTH[2] will be rounded off to + 1.280000 us, 320 samples
TRACE LENGTH[2] will be rounded off to + 0.256000 us, 64 samples
TRACE LENGTH[3] will be rounded off to + 1.280000 us, 320 samples
ADC board temperature: 57 C
Sync temperature: 68 C
Revision A990, Serial Number 12
root@localhost:/var/www#
```

At the most basic level, users can log in to the Pixie-Net with a terminal program and execute the C programs to set up and perform data acquisition (e.g. `./progfippi` and `./startdaq`). Settings are modified by editing the settings file `settings.ini` with a basic text editor like VI. Results are files on the Pixie-Net's SD card, which can be viewed with a text editor or copied to mounted network drives.

This environment may appeal most to users familiar with Linux, and also allows modification and recompilation of the C programs with the built-in gcc compiler.


3.3.2 Terminal and Webpages



For direct graphical feedback, users can log in via terminal as in the preceding section, but view results as a webpage. The Pixie-Net is running a web server, and the output files are plotted on webpages with a variety of java scripts.

While still requiring familiarity with Linux, the graphical feedback makes for an easier setup and a better presentation of the results.


3.3.3 Terminal, SMB and Windows programs



With SMB file sharing, Windows programs can be used to directly view, edit, and analyze settings and results. For example, the workflow could be

- 1) Using WordPad, open, modify, and save settings.ini
- 2) Execute `./progfippi` and `./startdaq` in the terminal
- 3) Open MCA.csv in Excel or other program to view, analyze, and plot results


3.3.4 Graphical User Interface on Host PC



Many data acquisition and analysis program can communicate with serial ports, external files and web servers. Examples include Igor Pro, MATLAB, LabVIEW, and so on. It is

therefore possible to develop graphical user interfaces with buttons and plots in such a program. As described in section 14, Igor Pro’s “very dumb terminal” function is used to send the commands normally typed into the terminal with the click of a button. After sending the command, Igor reads the Pixie-Net webpage and extracts and displays the data. For example, a “refresh” button in the Igor Pro “oscilloscope” display issues the command `./gettraces` and reads/displays ADC.csv. A “start run” button issues `./startdaq`, and so on. The data can then be further processed with user specific functions, for example the offline pulse shape analysis 2D histogram visible in the upper right of the plot. Igor Pro version 8 and higher also can use the function URLrequest to communicate via the web API functions.

A demo MATLAB implementation is shown in the screenshot below. It uses serial port communication similar to the Igor Pro example described above, then reads and displays the data from files. (While in principle the Pixie-Net’s Zynq firmware can be developed with MATLAB tools as well, this is currently not supported by XIA.)



Our current policy is to provide demo code for free, but to charge for software and support for more sophisticated user interfaces, in particular if customized for specific applications. Please contact XIA for more information.

3.3.5 Webpage-Only Operation

As an alternative to the terminal entry and execution of the C programs to set up and perform data acquisition (e.g. `./progfippi` and `./startdaq`), there is a [moderately] secure web page that allows execution of the C programs as a cgi script through a browser. The Web Operation starting page can be reached via a link in the sidebar of the default Pixie-Net pages. It essentially lists the C functions that would normally be called by typing in the terminal; clicking on the function name executes the function. Data is created in a separate subdirectory with Linux permissions for data write access for the webserver (`/var/www/webops`). The Web Operation page shows the equivalent links from the Pixie-Net page to download and display the data.

As this webpage allows generation and execution of files from any remote user, the webserver has been set up to require authentication to access this webpage. Details of the setup are described in section 10. The default user ID/password is `webops/xia17pxn`, currently specified as plain text in the file `/var/www/webopspasswords`. Obviously, this is

only moderately secure and should be a) changed by the user as soon as possible and b) upgraded to encrypted password storage for sensitive environments.

Pixie-Net Web Operations

XIA
Instruments That Advance The Art

- [Home](#)
- [ADC setup](#)
- [DAQ control](#)
- [Most recent MCA spectra](#)
- [Current run statistics](#)
- [Web interface](#)

Help

This set of pages allows DAQ and parameter control (after login). Proceed to ADC setup to boot and configure the input parameters. For more help, see

[Pixel-Net manual](#)

[XIA Pixel-Net website](#)

[or try the tooltips](#)

Current Status (cgi)

When no other task is in progress, view/refresh

- [ADC setup](#): Displays ADC waveforms together with parameter settings
- [DAQ control](#): Set run type and time, start DAQ
- [ADC traces](#): Displays ADC waveforms read just read from Pixie-Net
- [Run statistics](#): Displays Run statistics read just read from Pixie-Net (full)

Run executables as if typed in terminal:

- [progfippi](#)
- [startdaq](#)
- [acquire](#)
- [coincdaq](#)
- [findsettings](#)
- [gettraces](#)
- [runstats](#)

DAQ Monitoring

During or after the data acquisition, view most the recent

- [MCA spectra](#)
- [Run statistics \(short\)](#)
- [PSA histogram, with projections or surface plot](#)

DAQ Results

In addition, a basic graphical user interface is implemented in two additional pages: ADC setup and DAQ control. These pages allow modification of the settings file and starting of a data acquisition. For details see sections 5.11-5.13.

3.3.6 Web API

The webpage-only operation described in the previous section makes use of a number of cgi functions that are called by browser button clicks. Essentially, the browser issues an HTTP request to the Pixie-Net XL (e.g. <http://192.168.1.67/progfippi.cgi>), and the Pixie-Net XL's web server responds by executing the cgi function (here: programming parameters into the FPGA). While some of the cgi functions simply "print" a webpage (for example, `cgitraces.cgi` prints the ADC page with current ADC waveforms) the more sophisticated functions respond to http requests with more complex actions and return values. For example, `cgiwritesettings.cgi` parses the http request to update parameter values in `settings.ini`. These functions therefore essentially constitute a web API – a "programmatic interface consisting of one or more publicly exposed endpoints to a defined

request-response message system”¹. While limited in scope, this web API provides basic control of the Pixie-Net setup and data acquisition. It is primarily used by the webpage-only operation described above, but also can be used by any program that can issue http get commands. One such program is Igor Pro (using the “URLRequest” function in version 8 and higher) and the demo GUI described in section 14 can serve as a coding example. A possible C implementation might make use of LibCurl.

The functions are described in detail in section 4. This development is in progress and only the most common functions and parameters are supported at this time. Please contact XIA for more information.

3.3.6.1 Application Example

The web pages adcsetuppage (5.12) and daqpage (5.13) implement a browser based program on a remote PC utilizing the web API functions. (The program code, i.e. the javascript in the webpage, is provided by the Pixie-Net in the page itself but executed by the remote PC in the browser). For another implementation example of the web API we use Igor Pro (version 8 or higher). It supports a function “URLRequest” with the url given as a string argument [urlstring] and the server response returned in a string [ServerResponse]. User and password are handled automatically. Equivalent functions are assumed to exist in other tools.

Basic operation of the Pixie-Net would include the steps below. We use ip/wo as a shortcut to the webops folder on the Pixie-Net, e.g. “192.168.1.99/webops”. “PC” stands for actions on the remote PC, “PN” for actions triggered on the Pixie-Net. This example assumes RUN_TYPE 0x400.

1. **Read settings from file on Pixie-Net’s SD card to remote PC**
 PC: URLRequest with urlstring="ip/wo/cgireadsettings.cgi"
 PN: executes cgireadsettings.cgi, “prints” csv table of settings
 PC: receives csv table of settings in ServerResponse, sorts into local variables
2. **Change settings on remote PC**
 PC: change local variables corresponding to settings
3. **Write settings from remote PC to file on Pixie-Net’s SD card**
 PC: URLRequest with urlstring="ip/wo/cgiwritesettings.cgi"
 [plus a string defining what is written with what value – see description of API function]
 PN: executes cgiwritesettings.cgi, updating settings.ini
4. **Apply settings to pulse processing FPGAs for Pixie-Net**
 PC: URLRequest with urlstring="ip/wo/progfippi.cgi"
 PN: executes progfippi, writing parameters in settings.ini to FPGAs
5. **Start data acquisition for Pixie-Net**
 PC: URLRequest with urlstring="ip/wo/startdaq.cgi"
 PN: executes startdaq, which stores LM data on the SD card and accumulates MCA histograms
 PC: wait for URLRequest to complete, will take entire REQ_RUNTIME.

¹ Wikipedia definition of server side web API, 2022

6. Stop data acquisition for Pixie-Net

PC: when using `startdaq`, there is no method to stop the DAQ.

7. Collect output data

Copy LM data, MCA filess and run statistics from SD card files or from webpages

3.3.7 On-board ROOT Graphical User Interface

This option is no longer supported.

3.4 Optimizing Parameters

Optimization of the Pixie-Net's run parameters for best resolution depends on the individual systems and usually requires some degree of experimentation. Rough guidelines for setting parameters are described below.

3.4.1 Energy Filter Parameters

The main parameter to optimize energy resolution is the energy filter rise time (ENERGY_RISETIME). Generally, longer rise times result in better resolution, but reduce the throughput. Optimization should begin with scanning the rise time through the available range. Try 2 μ s, 4 μ s, 8 μ s, 11.2 μ s, take a run of 60s or so for each and note changes in energy resolution. Then fine tune the rise time.

The flat top (ENERGY_FLATTOP) usually needs only small adjustments. For a typical coaxial Ge-detector we suggest to use a flat top of 1.2 μ s. For a small detector (20% efficiency) a flat top of 0.8 μ s is a good choice. For larger detectors flat tops of 1.2 μ s and 1.6 μ s will be more appropriate. In general the flat top needs to be wide enough to accommodate the longest typical *signal rise time* from the detector. It then needs to be wider by one filter clock cycle than that minimum, but at least 3 filter clock cycles. Note that a filter clock cycle ranges from 0.026 to 0.853 μ s, depending on the filter range (FILTER_RANGE), so that it is not possible to have a very short flat top together with a very long filter rise time.

3.4.2 Threshold and Trigger Filter Parameters

In general, the trigger threshold (TRIGGER_THRESHOLD) should be set as low as possible for best resolution. If too low, the input count rate will go up dramatically and “noise peaks” will appear at the low energy end of the spectrum. If the threshold is too high, especially at high count rates, low energy events below the threshold can pass the pile-up inspector and pile up with larger events. This increases the measured energy and thus leads to exponential tails on the (ideally Gaussian) peaks in the spectrum. Ideally, the threshold should be set such that the noise peaks just disappear.

The settings of the trigger filter have only minor effect on the resolution. However, changing the trigger conditions might have some effect on certain undesirable peak shapes. A longer trigger filter rise time (TRIGGER_RISETIME) allows the threshold to be lowered more, since the noise is averaged over longer periods. This can help to remove tails on the peaks. A long trigger filter flat top (TRIGGER_FLATTOP) will help to trigger better on slow rising pulses and thus result in a sharper cut off at the threshold in the spectrum.

3.4.3 Decay Time

The preamplifier decay time τ (TAU) is used to correct the energy of a pulse sitting on the falling slope of a previous pulse. The calculations assume a simple exponential decay with one decay constant. A precise value of τ is especially important at high count rates where pulses overlap more frequently. If τ is off the optimum, peaks in the spectrum will broaden, and if τ is very wrong, the spectrum will be significantly blurred.

A first rough estimate of τ can be obtained from the ADC traces. Fine tuning of τ can be achieved by exploring small variations around the estimated value ($\pm 1\text{-}2 \mu\text{s}$). This is best done at high count rates, as the effect on the resolution is more pronounced. The value of τ found through this way is also valid for low count rates. Manually enter τ , take a short run, and note the value of τ that gives the best resolution.

3.4.4 Baselines and ADC calibration

Between detector pulses, the Pixie module continuously measures baselines, which is ultimately used to correct for the DC offset. Multiple baseline measurements can be averaged to reduce noise (BLAVG), and a threshold (BLCUT) can be set to exclude the occasional bad measurement from the average.

4 API functions

4.1 progfippi

Functions performed

- Parse .ini files, extract FPGA parameters
- Convert into “FPGA units”, e.g. number of samples instead of us
- Apply limits and dependencies, if not ok, give feedback and abort
- Read data from PROM and verify the current version of the Pixie-Net hardware is supported by the software
- Write to FPGA registers to apply settings
- Toggle I2C lines (0x002) to set gain etc. [May be moved to FPGA at some point]
- Issue DSP_CLR and RTC_CLR to PL resets

Arguments: fixed to “defaults.ini” and “settings.ini”**Output:** Errors for bad settings, prints hardware info from PROM and temperatures**Restrictions:** Do not execute during a data acquisition**Web API:**

- URL get request: <ip>/webops/progfippi.cgi
- Server action: See “functions performed” above
- Server response: Text as in “output” above
- Implementation example (Igor Pro):
URLrequest/AUTH={usr,pw} url=”<ip>/webops/progfippi.cgi”

4.2 gettraces, cgitraces

Read untriggered ADC data: 8K samples, 4 channels. Gettraces writes to a local file ADC.csv, cgitraces prints a webpage with the ADC data to std out, which can be piped into the webserver.

Functions performed

- Read ADC register in PL, write to file or print

Arguments: none**Output:** ADC.csv**Restrictions:** Do not execute during a data acquisition**Web API:**

- URL get request: <ip>/webops/gettraces.cgi
- Server action: See “functions performed” above

- Server response: csv data containing ADC samples in the following format:
header line
sample,adc0,adc1,adc2,adc3
values in format
0,%d,%d,%d,%d
repeated 8K times
- Implementation example (Igor Pro):
URLRequest/AUTH={usr,pw} url="/webops/gettraces.cgi"

Notes: For the cgi program to access the PL, its device space must be set to r+w permission to all(?) users: chmod 777 /dev/uio0.² The cgi program requires presence of the web page template adcpage.html in the same folder.

4.3 findsettings

Perform a series of tasks assisting in the optimization of gain, offset, tau, etc

Functions performed

- Resolve random channel swapping between channels 0/1 and 2/3.
- Ramp DACs and determine DAC setting for a baseline at 10% of the full ADC range
(Note: Pulse polarity has to be set correctly for this function to work properly)
- TODO Acquire baselines and determine Tau

Arguments: (possibly ini file name)

Output: prints found values for offset, tau, etc

Restrictions: Do not execute during a data acquisition

Web API:

- URL get request: <ip>/webops/findsettings.cgi
- Server action: See “functions performed” above
- Server response: error message or list of offset values in the form
“Channel %u: DAC value %u, offset %fV, ADC %u\n”
repeated for each channel
- Implementation example (Igor Pro):
URLRequest/AUTH={usr,pw} url="/webops/findsettings.cgi"

4.4 runstats, cgistats

These functions are used to read and output the run statistics registers. runstats writes them to a local file RS.csv. cgistats prints them as a webpage to std out, which can be piped into the

² This is done automatically in the Ubuntu 15 and 18 OS from software release 2.00 and higher.

webserver; this is displayed as the “Run statistics” webpage. These functions can be used for development, setup, and diagnostics, for example the run statistics include module revision and serial number, temperature, ICR and OOR.

Run statistics registers are also read and written to the file RS.csv by the data acquisition routines (acquire, startdaq, etc). During a data acquisition, do not execute runstats and cgistats (i.e. do not load webpage “Run statistics” = cgistats.cgi) to avoid conflicting access to the run statistics registers and possible delays and dead times. Instead monitor the file RS.csv (i.e. load webpage “Run status”= rpage.html)

Functions performed

- Read Runstats registers in PL
- Read I2C info from PROM
- write to file

Arguments: none

Output: RS.csv

Restrictions: Do not execute during a data acquisition

Notes: For the cgi program to access the PL, its device space must be set to r+w permission to all(?) users: chmod 777 /dev/uio0.³ The cgi program requires presence of the web page template rpage.html in the same folder.

4.5 startdaq

Start list mode run with or without waveforms (0x400, 0x500, 0x501, 0x502) or MCA run (0x301). Pulse shape analysis data is acquired in run types 0x400 and 0x502 for modules licensed for that function.

This functions is relatively simple and limited in throughput. It serves as an introductory example to users that may want to customize data acquisition. The function acquire is more sophisticated and has higher throughput.

Functions performed

- Parse .ini file, extract parameters
- Compute coefficients for E reconstruction etc
- Set bits in FPGA reg 0x000 to start run
 - o RunEnable -> 1 (an overall enable of the run)
 - o nLive -> 0 (can be used to temporarily pause acquisition (rarely used))
- Monitor DAQ
 - o Poll EVSTATS, if data ready:
read event data from PL,

³ This is done automatically in the Ubuntu 15 and 18 OS from software release 2.00 and higher.

- compute E,
- read waveforms from PL,
- write to LM file (if LM run),
- increment MCA
- Periodically save MCA to file (4Ki bins)
- Periodically read runstats from PL and write to file
- Periodically save PSA 2D histogram data to file
- Periodically read BL data from PL, compute BLavg
- Stop when time is up
- Save final run statistics, PSA, and MCA to file (32Ki bins)

Arguments: List mode file name (including extension). Defaults to LMdata.bin/txt/dat etc.

Output: MCA.csv, RS.csv, PSA.csv, LMdata.xxx (or per argument)

Web API:

- URL get request: <ip>/webops/startdaq.cgi
- Server action: See “functions performed” above
- Server response: error message or record of count times
- Implementation example (Igor Pro):
URLRequest/AUTH={usr,pw} url="<http://<ip>/webops/startdaq.cgi>"

4.6 acquire

Start list mode run with or without waveforms (0x400), coincidence list mode run (0x402), or MCA run (0x301). A more sophisticated and faster version of startdaq. Saves binary list mode data compatible with Pixie-4e.

Functions performed

- Parse .ini file, extract parameters
- Compute coefficients for E reconstruction etc
- Set bits in FPGA reg 0x000 to start run
 - RunEnable -> 1 (an overall enable of the run)
 - nLive -> 0 (can be used to temporarily pause acquisition (rarely used))
- Monitor DAQ
 - Poll EVSTATS, if data ready:
read event data from PL,
compute E,
read waveforms from PL,
write to LM file (if LM run),
increment MCA
 - Periodically save MCA to file (4 Ki bins)

- Periodically read runstats from PL and write to file
- Periodically read BL data from PL, compute BLavg
- Stop when time is up
- Save final run statistics and MCA to file (32 Ki bins)

Arguments: optional filename for LM file, optional filename for .ini file with parameters, other file names fixed

Output: MCA.csv, RS.csv, LMdata.b00 (binary)

4.7 coincdaq

Start list mode run in coincidence mode without waveforms (0x503). Coincidence mode runs build 4-channel event records that reduce or eliminate the need to parse through list mode data and find records close in time. This function is relatively simple and limited in throughput. It serves as an introductory example to users that may want to customize data acquisition. The function `acquire` is more sophisticated and has higher throughput.

Functions performed

- Parse .ini file, extract parameters
- Compute coefficients for E reconstruction etc
- Set bits in reg 0x000 to start run
 - RunEnable -> 1 (an overall enable of the run)
 - nLive -> 0 (can be used to temporarily pause acquisition (rarely used))
- Monitor DAQ
 - Poll EVSTATS, if data ready from ALL channels:
read event data from PL,
compute E,
read waveforms from PL,
write to LM file,
increment MCA
 - Periodically save MCA to file (4Ki bins)
 - Periodically read runstats from PL and write to file
 - Periodically read BL data from PL, compute BLavg
- Stop when time is up
- Save final run statistics, and MCA to file (32Ki bins)

Arguments: List mode file name (including extension). Defaults to LMdata.dt3

Output: MCA.csv, RS.csv, LM file (text only)

4.8 clockprog

Programs the clock PLL that buffers PTP or external clocks for FPGA and ADCs. A number of modes are hardcoded in the program; others can be added with the CDCE813-Q1 data sheet and TI's ClockPro utility as a reference. This allows for example using an external clock of arbitrary frequency. See also description of PTP variant.

Functions performed

- Program PLL for PTP and external clock

Arguments: mode (read and display, write to EEPROM, program PLL registers)

Output: display current register settings

Restrictions: Do not execute during a data acquisition

4.9 pollcsr

Reports the 16bit Control and Status Register value, which can be used to check if a run is in progress.

Functions performed

- Read CSR register, print and return value

Arguments: none

Output: print and return CSR value

Restrictions: None

Web API:

- URL get request: <ip>/webops/pollcsr.cgi
- Server action: See "functions performed" above
- Server response: text string of a 4-digit hexadecimal number, i.e. "0x#####" with # = 0-F
- Implementation example (Igor Pro):
URLRequest/AUTH={usr,pw} url="<http://<ip>/webops/pollcsr.cgi>"

4.10 avgadc, cgiavgtraces

Captures 4Ki averaged ADC samples at user specified sampling intervals. The data capture is triggered by the ADC going over a user defined absolute threshold; the first 500 samples are pre-trigger data.

Functions performed

- Compute time out and scaling factor from parameter ADC_AVG
- Arm trigger and wait for data to be captured
(the trigger occurs when the ADC exceeds the level set by the parameter THRESH_ADC_AVG)

- Read ADC data, scale as a single ADC value (12bit number), save to file (or “print” to webpage”)

Arguments: fixed to “settings.ini”

Output: text file ADCAVG.csv with sample numbers and ADC values

Restrictions: Do not execute during a data acquisition. Channels without a trigger are not read out, instead their waveform is set to 1/2/3/4/1/2/3/4...

4.11 cgireadsettings

Reads key parameters from the settings file and “prints” them so that a webpage can import them into controls

Functions performed

- Read default.ini, then settings.ini
- Report for each channel
 - polarity
 - offset
 - analog gain
 - digital gain
 - tau
- Report Run Type and Required run time

Arguments: none

Output: print to std out

Restrictions: none

Web API:

- URL get request: <ip>/webops/cgireadsettings.cgi
- Server action: See “functions performed” above
- Server response: csv data containing parameters in the following format:
header line
channel,polarity,offset,analog gain,digital gain,tau
values in format
 %d,%d,%04f,%02f,%04f,%04f,
repeated for each channel, and
followed by module parameters
 RUN_TYPE,0x%x,
 REQ_RUNTIME,%d,
note trailing commas
- Implementation example (Igor Pro):
URLrequest/AUTH={usr,pw} url=<ip>/webops/cgireadsettings.cgi”
for(ch=0;ch<MaxNchannels;ch+=1)
 polarity[ch] = str2num(StringFromList(7+6*ch, ServerResponse, ","))
 voffset[ch] = str2num(StringFromList(8+6*ch, ServerResponse, ","))

```

analog_gain[ch] = str2num(StringFromList( 9+6*ch, ServerResponse, ","))  

digital_gain[ch] = str2num(StringFromList(10+6*ch, ServerResponse, ","))  

tau[ch]          = str2num(StringFromList(11+6*ch, ServerResponse, ","))  

endfor  

Run_Type     = str2num(StringFromList(6*(MaxNchannels+1)+2, ServerResponse, ","))  

Req_Runtime = str2num(StringFromList(6*(MaxNchannels+1)+4, ServerResponse, ","))
```

4.12 cgiwritesettings

Receives a list of parameters from a webpage and uses them to update the settings file (settings.ini)

Functions performed

- Extract key words, parameter values from webpage Query string
- Updates matching line in setting.ini with the new parameters

Arguments: webpage query string

Output: change file

Restrictions: Do not execute during a data acquisition

Web API:

- URL get request:
`<ip>/webops/cgiwritesettings.cgi?<PARAMETER>=<TYPE>&v<ch>=<value>`
 where
 <PARAMETER> is the parameter name in the settings file
 <TYPE> is “MODULE” or “CHANNEL”
 <ch> is the channel number
 <value> is the new parameter value
- Server action: See “functions performed” above
- Server response: error message or success message
- Implementation example (Igor Pro):
`cmd = "192.168.1.100/webops/cgiwritesettings.cgi?TAU=CHANNEL
for(ch=0;ch<MaxNchannels;ch+=1)
 sprintf chval,"&v%d=%4f",ch, tau[ch]
 cmd = cmd + chval
endfor
URLRequest/AUTH={usr,pw} url=cmd`

5 Web Pages

The Pixie-Net web pages are located in /var/www; this is the default directory for the installed lighttpd webserver. Browsing to the Pixie-Net's IP address will bring up index.html, from which all other pages can be accessed.

5.1 index.html

The screenshot shows the Pixie-Net Home Page. On the left, there is a sidebar with the XIA logo and links to Home, Current ADC traces, Current run statistics, Most recent MCA spectra, and Web interface. Below this is a Help section with links to the Pixie-Net manual, XIA Pixie-Net website, and tooltips. The main content area has three sections: **Current Status (cgi)** (with links to ADC traces, Averaged ADC traces, and Run statistics (full)), **DAQ Monitoring** (with links to MCA spectra, Run statistics (short), and PSA histogram), and **DAQ Results** (with a list of data types like List mode data with waveforms, List mode data without waveforms, List mode data with PSA, List mode coincidence data, Binary list mode data, MCA spectra as csv file, Run statistics as csv file (full), and PSA histogram as csv file). Each section also contains descriptive text and links to view data as tables or plots.


This is the home page for the Pixie-Net.

At the top of the page, there are a few shortcuts to common tasks or pages. Do not use the Run Statistics link during a data acquisition, instead use the Run Status link in the next section.

Under **DAQ Monitoring**, there are links to view (as plots or tables in the browser) the csv files from the most recent data acquisition for MCA spectra and run status.

Under **DAQ Results**, the final data files from the most recent tasks can be downloaded or viewed in the browser. This requires that a task in the Linux terminal, such `startdaq`, `runstats`, `acquire` or `gettraces` has been executed and completed. The screenshot below shows opening/downloading the MCA file. The file can then be opened, and its data displayed and analyzed, in any suitable program.


A further link runs a CGI script to extract and display a list mode waveform from the most recent 0x500 data acquisition (see below).



Under **CGI Current Data**, procedures are executed directly on the Pixie-Net, their output generating webpages for ADC traces and other results instead of files. This combines the two steps of i) executing a function on the Pixie-Net terminal to create data and ii) refreshing the appropriate webpage to view the results. Do not execute these links during a data acquisition.

A further link opens the web operations page (see below) which allows execution of the terminal functions from the web browser. Login is required to prevent unauthorized access.

5.2 adcpage.html, cgitraces.cgi




The adcpage contains a chart showing untriggered waveforms read from the Pixie-Net's ADCs. Internally, this is a dygraph javascript that links to the file ADC.csv. The csv file has to be generated or refreshed by executing `gettraces` on the Pixie-Net terminal.

Mouse click and drag operations allow to zoom in and pan. See notes under the plot for details. Use the browser **Refresh** button to update for new data.

An equivalent page reading and displaying the data can be generated by a cgi script from the web browser when no data acquisition is in progress.

5.3 mcapage.html



The mcapage contains a chart showing MCA spectra from the current or most recent data acquisition. Internally, this is a dygraph javascript that links to the file MCA.csv. The file is generated and periodically refreshed by executing startdaq or acquire on the Pixie-Net terminal.

5.4 rspage.html, cgistats.cgi

The figure shows a screenshot of the rspage.html page. At the top, a blue header bar reads "Pixie-Net Run Statistics (current)". Below the header is the XIA logo and a navigation menu with links to Home, Current ADC traces, Current run statistics, Most recent MCA spectra, Web interface, and Help. The main content area contains a table titled "Run Statistics (current)". The table has columns for Parameter, Module, Parameter, Chan. 0, Chan. 1, Chan. 2, and Chan. 3. The table lists various run parameters and their values. The "Help" section contains instructions for navigating the page.

Parameter	Module	Parameter	Chan. 0	Chan. 1	Chan. 2	Chan. 3
RUN_TIME	0	COUNT_TIME	0	0	0	0
TOTAL_TIME	0	INPUT_COUNT_RATE	0	0	0	0
EVENT_RATE	0	OUTPUT_COUNT_RATE	0	0	0	0
PSI_CODE_VERSION	0x220	FTDT	0	0	0	0
ACTIVE	0	SFDT*	0	0	0	0
PSA_LICENSED	1	PASS_PILEUP_RATE*	0	0	0	0
PTP_REQ	0	GATE_RATE*	0	0	0	0
--	0	GDT*	0	0	0	0
reserved	0	reserved	0	0	0	0
CSRROUT	0xBE000C04	OOR*	0	4095	9158	43702
SYSTIME	0x9A82EA80	ICR	1545	0	0	0
RUNTIME	0	COUNTTIME	0	0	0	0
RUNTIME	0	COUNTTIME	0	0	0	0
TOTALTIME	0	NTRIG	0	0	0	0
TOTALTIME	0	NTRIG	0	0	0	0
NUMEVENTS	0	FTDT	0	0	0	0
NUMEVENTS	0	FTDT	0	0	0	0
BHL_EHL	2097152	SFDT*	0	0	0	0
CHL_FILELENGTH	2101248	SFDT*	0	0	0	0


The rspage contains a table showing the Run Status information: the run statistics from the most recent data acquisition (which can be the one in progress). Internally, this is a d3 javascript that links to the file RS.csv. The file is generated and periodically refreshed by executing ./startdaq or ./acquire on the Pixie-Net terminal. It can also be

generated outside a data acquisition by executing `./runstats` on the Pixie-Net terminal (actual run statistics will not change, but a real time counter increments and some hardware and status information may be of interest).

A similar page reading and displaying the data can be generated by the script `cgistats.cgi` from the web browser. This should only be used when no data acquisition is in progress. This page is named Run Statistics to differentiate for the Run Status page described in the previous paragraph.

Units in the pages (and the underlying csv file) are in seconds or counts/s for the first ~8 lines, then raw internal units (counts and ns).

5.5 psahistpage.html




The psahistpage shows results of the pulse shape analysis (PSA) as a 2D histogram. The PSA, as described in section 12.1, computes two sums over characteristic regions of the detector pulse, and calculates the ratio (PSA value) of the two sums. The PSA value is a condensed characteristic of the pulse shape, and can be used with suitable detectors to distinguish event or particle types, for example gammas and neutrons or gammas and alphas.

In the psahistpage, the PSA value (y) is plotted against the pulse energy E (x), and each pixel is colored by intensity. Typically neutrons and gammas fall into two separate branches in the plot.

Internally, this is a plotly javascript that links to the file `PSA.csv`. The file is generated and periodically refreshed by executing `startdaq` on the Pixie-Net terminal. Hovering over

the plot makes visible options to zoom and save. The histogram has 100 bins in each direction.

5.6 psahistprojpage.html




The psahistprojpage shows the same data as the psahistpage, but additionally computes

- a projections to the y axis for all bins $> E_{\text{min}}$
- a projection to the x axis for all bins $> \text{n/g threshold}$
- a projection to the x axis for all bins $< \text{n/g threshold}$
- the number of gammas and neutrons ($E > E_{\text{min}}$, $\text{PSA value} >/< \text{n/g threshold}$)

E_{min} and n/g threshold can be entered below the plot. Clicking the browser's refresh button will recalculate the projections.

5.7 psasurfacepage.html



The psasurfacepage shows the same data as the psahistpage, but as a 3D surface plot instead of a 2D histogram. Hovering over the plot makes visible options to rotate and pan the plot.

5.8 lmtablepage.html

Pixie-Net List Mode Table				
	Module	Run Type	Run Start (ticks)	Run Start (s)
	0	-1107295228	1487722084	-- --
No		Hit		Time_H Time_L Energy
0	0	0x110121	0	1106976 11208
1	1	0x110121	0	1762336 11223
2	2	0x110121	0	2417696 11219
3	3	0x110121	0	3073056 11222
4	4	0x110121	0	3728416 11218
5	5	0x110121	0	4383776 11219
6	6	0x110121	0	5039136 11217
7	7	0x110121	0	5694496 11207
8	8	0x110121	0	6349856 11222
9	9	0x110121	0	7005216 11219
10	10	0x110121	0	7660576 11227
11	11	0x110121	0	8315936 11226
12	12	0x110121	0	8971296 11222
13	13	0x110121	0	9626656 11224
14	14	0x110121	0	10282016 11229
15	15	0x110121	0	10937376 11228
16	16	0x110121	0	11592736 11235
17	17	0x110121	0	12248006 11244


The lmtablepage contains a table showing the results from a list mode run of run type 0x501, which generates a csv table with hit pattern, time stamps, and energy (but no waveforms). The first two lines of the table list run type and start time.

The time stamps units are nanoseconds. The energies reported are in internal units, calibration to keV is required.


Note: This page will load very slowly for large data files. Download of the data file and analysis in a text editor or spreadsheet program is recommended.

5.9 cgiwaveforms.cgi

Through a link from the Pixie-Net home page (under DAQ results), the Pixie-Net can execute a cgi script to extract the numbered waveform from the LMdata.txt file created in run type 0x500. When called from the home page, the event number defaults to zero; once the waveform page is displayed, a new event number can be entered which reloads the page with that event's waveform.



5.10 avgadcpage.html, cgiavgtraces.cgi



The avgadcpage contains a chart showing triggered waveforms read from the Pixie-Net's ADCs. The ADC data is averaged and buffered at user specified sampling intervals (ADC_AVG) following a trigger (threshold THRESH_ADC_AVG). Internally, this is a dygraph javascript that links to the file ADCAVG.csv. The csv file has to be generated or refreshed by executing avgadc on the Pixie-Net terminal.

Mouse click and drag operations allow to zoom in and pan. See notes under the plot for details. Use the browser **Refresh** button to update for new data.

An equivalent page reading and displaying the data can be generated by a cgi script from the web browser when no data acquisition is in progress.

5.11 Web Operations ([webops/webopsindex.html](#))

The web operations page allows execution of the terminal functions from the web browser. Login is required to prevent unauthorized access. Default ID/password are **webops/xia17pxn** (*please change*). Most of the links and functions from the home page are duplicated, with the following additions and differences:

Pixie-Net Web Operations

Current Status (cgi)

When no other task is in progress, view/refresh

- [ADC setup](#): Displays ADC waveforms together with parameter settings
- [DAQ control](#): Set run type and time, start DAQ
- [ADC traces](#): Displays ADC waveforms read just read from Pixie-Net
- [Run statistics](#): Displays Run statistics read just read from Pixie-Net (full)

Run executables as if typed in terminal:

- [progfippi](#)
- [startdaq](#)
- [acquire](#)
- [coindaq](#)
- [findsettings](#)
- [gettraces](#)
- [runstats](#)

DAQ Monitoring

During or after the data acquisition, view most the recent

- [MCA spectra](#)
- [Run statistics \(short\)](#)
- [PSA histogram, with projections or surface plot](#)

DAQ Results

After the data acquisition, open/download

- [List mode data with waveforms](#) (from run type 0x500, text)
- [List mode data without waveforms](#) (from run type 0x501, csv)
- [List mode data with PSA](#) (from run type 0x502, csv)
- [List mode coincidence data](#) (from run type 0x503, csv)
- [Binary list mode data](#) (from run types 0x400, 0x402)
- [MCA spectra as csv file](#)
- [Run statistics as csv file \(full\)](#)
- [PSA histogram as csv file](#)

View most recent data in plots and tables


- [MCA spectra](#)
- [Run status](#)
- [PSA histogram, with projections or surface plot](#)
- [ADC traces](#)

- Links to ADC setup and DAQ control, to setup key parameters and start a DAQ from the webpage.
- List of API functions to be executed as CGI scripts.
Clicking on one of these links executes the API function as if typed into the terminal.
- Data files are created in a new subfolder: /var/www/webops

- API function output (e.g. error messages) are reported as a “plain text” web page; which is empty if no message. Use the browser back button to return to the webops page.
- The API functions use the settings files from /var/www/webops.

5.12 ADC Setup (webops/adcsetuppage.html)

The ADC Setup page not only displays the ADC waveforms captured from the module, but also lets the user change key parameters, such as gain, offset, and polarity. Users should always first initialize the page and the module by clicking “Program FPGA” and “Read Settings” to apply the defaults and read them into the control fields. When editing a field it will turn yellow, and also the “Apply” button will turn yellow to indicate that only the settings file has changed, but not yet the parameters applied to the FPGA.



At this time, the webpage functionality is under development and overly eager in responding with alerts. We recommend not clicking from one control field into another as that will create a cascade of alerts.

5.13 DAQ Control (webops/ daqpage.html)

The DAQ Control page allows the user to start DAQ runs from the web interface. Initialize the page by clicking “Read Settings”. Optionally modify Run Time and Run Type and click “Apply”. Then click “Start DAQ” which executes the API function “startdaq”. The progress bar will advance during the run, but the time is counted in the browser only. Please wait for a popup alert message from the Pixie-Net indicating that the DAQ has finished.

The screenshot shows the Pixie-Net DAQ Control page. At the top, there is a blue header bar with the title "Pixie-Net DAQ Control". Below the header, on the left, is a sidebar with the XIA logo and the tagline "Instruments That Advance The Art". The sidebar contains links: Home, ADC setup, DAQ control, Most recent MCA spectra, Current run statistics, Web interface, and Help. In the Help section, there is a note: "This page can be used to start DAQ runs (function startdaq). Click 'Read Settings' before making changes". The main content area is titled "DAQ Control" and contains three buttons: "Read Settings", "Apply (progfippi)", and "Start DAQ". Below these buttons is a progress bar. Underneath the progress bar are two input fields: "REQ_RUNTIME (s)" with a value of "0" and "RUN_TYPE" with a value of "0x400". To the right of the main content area is a box titled "DAQ Results" containing a list of options for viewing data acquisition results. The list includes: List mode data with waveforms (from run type 0x500, text), List mode data without waveforms (from run type 0x501, csv), List mode data with PSA (from run type 0x502, csv), List mode coincidence data (from run type 0x503, csv), Binary list mode data (from run types 0x400, 0x402), MCA spectra as csv file, Run statistics as csv file (full), and PSA histogram as csv file. Below this list is another section titled "View most recent data in plots and tables" with two items: MCA spectra and Run status.

5.14 All Settings (webops/allsettingspage.html)

This page allows to read in the settings file from /var/www/webops and displays the rows as editable text. Changes can be transmitted back to the settings file and applied to the pulse processing registers.

The screenshot shows the 'Pixie-Net Settings' page. On the left, there is a sidebar with links: XIA Logo, Home, ADC setup, DAQ control, Most recent MCA spectra, Current run statistics, and Web interface. Below these is a 'Help' section with instructions: 'This page displays the parameters from settings.ini in the webops folder.', 'First click "Read Settings" to initialize', and 'Click "Apply" after changing parameters'. The main area has a blue header 'Pixie-Net Settings'. It contains three buttons: 'Read Settings File', 'Apply (progfippi)', and 'clear'. Below these buttons is a table with two columns: 'Parameter' and 'Values'. To the right of the table is a 'Response' section containing the word 'ready'.

6 Parameters in the Settings Files

The ini files contain the parameter settings for the data acquisition. There are two files, *defaults.ini* and *settings.ini*. The file *defaults.ini* should be considered read-only; it contains defaults for all parameters. The file *settings.ini* contains a subset of most relevant parameters, which will overwrite the defaults. Parameter lines can be added or removed from *settings.ini* to focus better on parameters relevant for a certain application. The .ini files are ASCII text files, one line per parameter. Parameter name spelling must be maintained, but the order is not essential. (Users customizing code can add parameters at the end of the file.) The parameter values are in physical units, and will be translated by the `progfippi` routine into values and bit patterns and then written into PL input registers.

Several control bit patterns are broken out as one bit per line. For other, less commonly used bit patterns, their value can be written as decimals or hexadecimals, for example 65536 or 0xFFFF.

The following sections describe the parameters. Unused parameters are shown in gray. Key parameters for *settings.ini* are shown in bold. NYI = not yet implemented.

6.1 System Parameters

Parameter Name	Units Limits	Description
NUMBER_CHANNELS	4	Number of channels
C_CONTROL	Bits, 0x0-FFFF	unused
REQ_RUNTIME	Seconds, 5..2^32	Requested run time in (full) seconds
POLL_TIME	Tbd, 100..2^32	Number of internal polling loops between updates of csv output files. In the order of microseconds
SYS_U11		unused
SYS_U10		unused
SYS_U9		unused
SYS_U8		unused
SYS_U7		unused
SYS_U6		unused
SYS_U5		unused
SYS_U4		unused
SYS_U3		unused
SYS_U2		unused
SYS_U1		unused
SYS_U0		unused

6.2 Module Parameters

Parameter Name	Units Limits	Description
MCSRA_CWGROU_00	0 or 1	In coinc mode runs (0x503 or 0x402), save only one record per coincidence window
MCSRA_U_01	0 or 1	Module control bit A.1, unused
MCSRA_U_02	0 or 1	Module control bit A.2, unused
MCSRA_U_03	0 or 1	Module control bit A.3, unused
MCSRA_U_04	0 or 1	Module control bit A.4, unused
MCSRA_FPVETO_05	0 or 1	Module control bit A.5, if 1, enables MMCX input as global Veto, NYI (always enabled)
MCSRA_U_06	0 or 1	Module control bit A.6, unused
MCSRA_FPPEDGE_07	0 or 1	Module control bit A.7, toggles active edge for front panel pulse counter, NYI
MCSRA_U_08	0 or 1	Module control bit A.8, unused
MCSRA_U_09	0 or 1	Module control bit A.9, unused
MCSRA_U_10	0 or 1	Module control bit A.10, unused
MCSRA_U_11	0 or 1	Module control bit A.11, unused
MCSRA_U_12	0 or 1	Module control bit A.12, unused
MCSRA_U_13	0 or 1	Module control bit A.13, unused
MCSRA_U_14	0 or 1	Module control bit A.14, unused
MCSRA_U_15	0 or 1	Module control bit A.15, unused
MCSR_B_00	0 or 1	Module control bit B.0, unused
MCSR_B_TERM01_01	0 or 1	Module control bit B.1, if 1, termination for ch.0 and 1 is 50 Ohm, else “high impedance”
MCSR_B_TERM23_02	0 or 1	Module control bit B.2, if 1, termination for ch.2 and 3 is 50 Ohm, else “high impedance”
MCSR_B_03	0 or 1	Module control bit B.3, unused
MCSR_B_PDCH0_04	0 or 1	Module control bit B.4, power down ADC driver for ch.0, NYI
MCSR_B_PDCH1_05	0 or 1	Module control bit B.5, power down ADC driver for ch.0, NYI
MCSR_B_PDCH2_06	0 or 1	Module control bit B.6, power down ADC driver for ch.0, NYI
MCSR_B_PDCH3_07	0 or 1	Module control bit B.7, power down ADC driver for ch.0, NYI
MCSR_B_08	0 or 1	Module control bit B.8, unused
MCSR_B_09	0 or 1	Module control bit B.9, unused
MCSR_B_10	0 or 1	Module control bit B.10, unused
MCSR_B_11	0 or 1	Module control bit B.11, unused
MCSR_B_12	0 or 1	Module control bit B.12, unused
MCSR_B_13	0 or 1	Module control bit B.13, unused
MCSR_B_14	0 or 1	Module control bit B.14, unused
MCSR_B_15	0 or 1	Module control bit B.15, unused
COINC_PATTERN_0000	0 or 1	If 1, record events with no channel hit. Useful only for external triggers
COINC_PATTERN_0001	0 or 1	If 1, record events with hitpattern ch 3210 = #####
COINC_PATTERN_0010	0 or 1	

COINC PATTERN 0011	0 or 1	(#### are the last 4 digits of the parameter name)
COINC PATTERN 0100	0 or 1	For example, if COINC_PATTERN_0011=1, events with pulses in both channel 0 and 1 will be recorded (if rising edges occur within coincidence window length)
COINC PATTERN 0101	0 or 1	
COINC PATTERN 0110	0 or 1	
COINC PATTERN 0111	0 or 1	
COINC PATTERN 1000	0 or 1	If multiple COINC_PATTERN_#### are 1, events matching any of the patterns are recorded.
COINC PATTERN 1001	0 or 1	For example if
COINC PATTERN 1010	0 or 1	COINC_PATTERN_0111=1 and
COINC PATTERN 1011	0 or 1	COINC_PATTERN_1011=1 and
COINC PATTERN 1100	0 or 1	COINC_PATTERN_1101=1 and
COINC PATTERN 1101	0 or 1	COINC_PATTERN_1110=1,
COINC PATTERN 1110	0 or 1	pulses are recorded if exactly 3 channels have a pulse, but no matter which.
COINC_PATTERN_1111	0 or 1	
COINCIDENCE_WINDOW	μs, 0.040- 4.088	Coincidence window length
RUN_TYPE	0x301, 0x400, 0x402, 0x500, 0x501, 0x502, 0x503	MCA only run List mode run with waveforms (binary .b00) Coincidence list mode run (binary .b00) List mode run with waveforms (text .txt) List mode run without waveforms (text .dat) List mode run with PSA, no waveforms (text dt2) Coincidence list mode run (text .dt3)
FILTER_RANGE	1..6	Decimation/averaging for energy filter See note 1
ACCEPT_PATTERN	Bits, 0x0020	Controls what type of event to accept (MODULEPATTERN)
SYNC_AT_START	0..1	Reset timers at runstart
HV_DAC	0..5V	Voltage on HV control output
SERIAL_IO	Bits, 0x0-FFFF	Bit pattern for offboard serial data
AUX_CTRL	Bits, 0x0-FFFF	Bit pattern for pulser, LED, etc Bit0: pulser enabled Bit1: reserved for LED control Bit2: reserved Bit3: if set, require PTP trigger to begin DAQ
MOD U7		Unused
MOD U6		Unused
MOD U5		Unused
MOD U4		Unused
MOD U3		Unused
MOD U2		Unused
MOD U1		Unused
MOD U0		Unused

6.3 Channel Parameters

Parameter Name	Units Limits	Description
CCSRA_GROUP_00	0 or 1	Channel control bit A.0, if 1, respond to distributed group triggers, not local triggers. Ignored (always 1) in Run Types 0x402, 0x503
CCSRA_U_01	0 or 1	Channel control bit A.1, unused
CCSRA_GOOD_02	0 or 1	Channel control bit A.2, if 0, channel will not be processed
CCSRA_U_03	0 or 1	Channel control bit A.3, unused
CCSRA_TRIGENA_04	0 or 1	Channel control bit A.4, if 1, enable trigger (local and distributed)
CCSRA_INVERT_05	0 or 1	Channel control bit A.5, if 1, ADC data is inverted before processing (for falling edge pulses)
CCSRA_VETO_REJLO_06	0 or 1	Channel control bit A.6, if 1, reject events when global Veto is low
CCSRA_U_07	0 or 1	Channel control bit A.7, unused
CCSRA_NO_OVERLAP_08	0 or 1	Channel control bit A.8 if 1, do not record events with overlapping waveforms
CCSRA_NEGE_09	0 or 1	Channel control bit A.9, if 1, allow negative numbers as result of energy computation, NYI
CCSRA_U_10	0 or 1	Channel control bit A.10, unused
CCSRA_U_11	0 or 1	Channel control bit A.11, unused
CCSRA_GATE_REJLO_12	0 or 1	Channel control bit A.12, if 1, reject events when channel-specific GATE signal is low
CCSRA_U_13	0 or 1	Channel control bit A.13, unused
CCSRA_U_14	0 or 1	Channel control bit A.14, unused
CCSRA_TRIGGER16X_15	0 or 1	Channel control bit A.15, If 1, trigger filter is slowed 16x
CCSRB_U_00	0 or 1	Channel control bit B.0, unused
CCSRB_U_01	0 or 1	Channel control bit B.1, unused
CCSRB_U_02	0 or 1	Channel control bit B.2, unused
CCSRB_U_03	0 or 1	Channel control bit B.3, unused
CCSRB_U_04	0 or 1	Channel control bit B.4, unused
CCSRB_U_05	0 or 1	Channel control bit B.5, unused
CCSRB_U_06	0 or 1	Channel control bit B.6, unused
CCSRB_U_07	0 or 1	Channel control bit B.7, unused
CCSRB_U_08	0 or 1	Channel control bit B.8, unused
CCSRB_U_09	0 or 1	Channel control bit B.9, unused
CCSRB_U_10	0 or 1	Channel control bit B.10, unused
CCSRB_U_11	0 or 1	Channel control bit B.11, unused
CCSRB_U_12	0 or 1	Channel control bit B.12, unused
CCSRB_U_13	0 or 1	Channel control bit B.13, unused

CCSRB_U_14	0 or 1	Channel control bit B.14, unused
CCSRB_U_15	0 or 1	Channel control bit B.15, unused
CCSRC_VETO_REJHI_00	0 or 1	Channel control bit C.0, if 1, reject events when global Veto is high
CCSRC_GATE_REJHI_01	0 or 1	Channel control bit C.1, if 1, reject events when channel-specific Gate signal is high
CCSRC_GATE_FROMVETO_02	0 or 1	Channel control bit C.2, if 1, use global Veto as the input for this channel's Gate logic
CCSRC_PILEUP_DISABLE_03	0 or 1	Channel control bit C.3, if 1, disable pileup rejection, including the MAXWIDTH rejection
CCSRC_RBADC_DISABLE_04	0 or 1	Channel control bit C.4, if 1, disable rejection of out-of-range events
CCSRC_PILEUP_INVERT_05	0 or 1	Channel control bit C.5, if 1, accept only pulses that are piled up
CCSRC_PILEUP_PAUSE_06	0 or 1	Channel control bit C.6, if 1, disable pileup inspection for 32 clock cycles after trigger. For ringing input signals.
CCSRC_GATE_FEDGE_07	0 or 1	Channel control bit C.7, if 1, count Gate pulses on falling edge
CCSRC_GATE_STATS_08	0 or 1	Channel control bit C.8, if 1, run statistics are in GATE mode, only counting while GATE is on
CCSRC_VETO_FEDGE_09	0 or 1	Channel control bit C.9, if 1, count Veto pulses on falling edge
CCSRC_GATE_ISPULSE_10	0 or 1	Channel control bit C.10, if 1, logic to re-pulse incoming Gate signal with specified GATE_WINDOW is enabled
CCSRC_TRACE4X_11	0 or 1	Channel control bit C.11, If 1, trace and trigger filter are slowed 4x
CCSRC_U_12	0 or 1	Channel control bit C.12, unused
CCSRC_U_13	0 or 1	Channel control bit C.13, unused
CCSRC_CPC2PSA_14	0 or 1	Channel control bit C.14, if 1, report gate pulse count as PSA value of list mode record
CCSRC_GATE_PULSEFEDGE_15	0 or 1	Channel control bit C.15, if 1, start pulse GATE_WINDOW at falling edge of Gate input signal
ENERGY_RISETIME	µs, 0.032 .. 62.976	Energy filter rise time See Note 1) and section 3.4.1
ENERGY_FLATTOP	µs, 0.048 .. 62.976	Energy filter flat top See Note 1) and section 3.4.1
TRIGGER_RISETIME	µs, 0.016 .. 0.480	Trigger filter rise time See note 2) and section 3.4.2

TRIGGER_FLATTOP	μs, 0.048 .. 0.0488	Trigger filter flat top See note 2) and section 3.4.2
TRIGGER_THRESHOLD	(ADC steps) 0..4096	Trigger threshold See note 3) and section 3.4.2
ANALOG_GAIN	2 or 5	Gain with switches/relays/VGAs Values may vary for different HW variants
DIG_GAIN	Positive float	Digital gain adjustment factor. Measured ADC amplitude is multiplied with this factor before histogramming and reporting in list mode file. Binning artefacts can appear with very small or very large numbers
VOFFSET	V -1.25..1.25	Analog offset Used to compensate detector baseline offsets
TRACE_LENGTH	μs, 0..16	Captured waveform length
TRACE_DELAY	μs, 0..16	Pre-trigger delay
PSA_START	μs, 0..16	Start for PSA in waveform, reserved
PSA_END	μs, 0..16	End for PSA in waveform, reserved
BINFACTOR	1-16	MCA binning factor: divide measured pulse height by by 2^N before binning
TAU	μs positive float	Preamplifier decay time See section 3.4.3
BLCUT	Positive int	Threshold for bad baseline measurements See section 3.4.4
XDT	μs	Sampling interval in untriggered traces, NYI
BASELINE_PERCENT	0-99	Target offset for baseline, nominally in percent, NYI
PSA_THRESHOLD	ADC steps, 0..2044	Threshold in CFD and PSA,
INTEGRATOR	0..2	Filter mode: 0-trapezoidal, 1-gap sum integral, NYI 2-ignore gap sum, NYI
GATE_WINDOW	μs, 0..2.04	Coincidence window with gate
GATE_DELAY	μs, 0..2.04	Delay of external gate signal
COINC_DELAY	μs, 0..1.02	Delay of ADC signal before coincidence test, equivalent to a cable delay
BLAVG	65535.. 65528 and 0	Baseline averaging See section 3.4.4
QDC0_LENGTH	samples 2..60	Length of PSA sum See section 12.1

QDC1_LENGTH	samples 2..60	Length of PSA sum See section 12.1
QDC0_DELAY	samples 0..250	Delay of PSA sum relative to trigger point See section 12.1
QDC1_DELAY	Samples 0..250	Delay of PSA sum relative to trigger point See section 12.1
QDC_DIV8	0..1	If 1, divide PSA sums by an extra factor 8 (to avoid overflow for long sums) See section 12.1
MCA2D_SCALEX	Positive float <655	The energy (max 64Ki) is divided by this factor before binning into the 2D PSA histogram (max 100 bins)
MCA2D_SCALEY	Positive float <655	The PSA value (max 64Ki) is divided by this factor before binning into the 2D PSA histogram (max 100 bins)
PSA_NG_THRESHOLD	Positive float	Threshold for PSA value to distinguish neutrons and gammas, NYI
ADC_AVG	1..65535	Number of samples to average in triggered oscilloscope mode
THRESH_ADC_AVG	1..4095	Trigger threshold (absolute ADC steps) in triggered oscilloscope mode
MAXWIDTH	8ns cycles 0..255	If the time over threshold exceeds MAXWIDTH cycles, events are rejected (or marked, if rejection is disabled). A value of 0 (default) disables the MAXWIDTH test. Pulses are counted as NFILE
CHAN_U0		Unused

Notes

1. Energy filter rise time and flat top depend on FILTER_RANGE (FR). Higher filter ranges have allow longer filter times but with increased coarseness. Maximum combined length is $126 \times 0.008\mu s \cdot 2^F R$

FILTER_RANGE	Filter granularity	max. $T_{rise} + T_{flat}$	min. T_{rise}	min. T_{flat}
1	$0.016\mu s$	$2.032\mu s$	$0.032\mu s$	$0.048\mu s$
2	$0.032\mu s$	$4.064\mu s$	$0.064\mu s$	$0.096\mu s$
3	$0.064\mu s$	$8.128\mu s$	$0.128\mu s$	$0.192\mu s$
4	$0.128\mu s$	$16.256\mu s$	$0.256\mu s$	$0.384\mu s$
5	$0.256\mu s$	$32.512\mu s$	$0.512\mu s$	$0.768\mu s$
6	$0.512\mu s$	$65.024\mu s$	$1.024\mu s$	$1.536\mu s$

Table 6-1: Filter clock decimations and filter time granularity

2. Trigger filter rise time and flat top maximum combined length is $63 \times 0.008\mu s$
3. The internal triggering compares the output of the trigger filter (technically an area) with $(TRIGGER_THRESHOLD * TRIGGER_RISETIME / 8)$, which must be < 1024 . The maximum for TRIGGER_THRESHOLD thus depends on TRIGGER_RISETIME. Fractional values for TRIGGER_THRESHOLD are acceptable. TRIGGER_THRESHOLD=0 turns off triggering for this channel.

7 Data Formats

7.1 List Mode Data Files

There are currently six types of list mode data acquisition, with waveforms and without, binary or text, and for special purposes. The following table gives an overview of their differences. It is quite straightforward to modify the code in e.g. startdaq to generate application specific output files.

Run Type	File format	Wave-forms	Function	File extension	Notes
0x400	binary	Yes	startdaq, acquire	.b00	General purpose, fast, compatible with Pixie-4e
0x402	binary	Yes	acquire	.b00	Coincidences, compatible with Pixie-4e
0x500	text	Yes	startdaq	.txt	General purpose, slow
0x501	text	No	startdaq	.dat	General purpose
0x502	text	No	startdaq	.dt2	PSA
0x503	text	No	coincdaq	.dt3	Coincidences

As a general rule, times and time stamps are in units of 1ns unless explicitly stated otherwise. Note that time counters are incremented at a rate of 125 MHz, i.e. by 8 ticks every 8 ns.

7.1.1 List mode files with waveforms (Run Type 0x500)

The default filename for list mode files with waveforms is **LMdata.txt**. Data is in text format and organized as one value per line. The first 4 lines report run type and run start time information. After that, for each event there are 8 header lines and N waveform sample lines. (N can be computed from the TRACE LENGTH in μ s specified in the ini file.)

Line	Value	Example
0	File header: module number	Module: 0
1	File header: run type	Run Type: 0x500
2	File header: start time per FPGA clock counter, in units of ns	Run Start Time Stamp (ticks) : 4
3	File header: start time per Linux clock, in units of s since epoch	Run Start Time (s) : 1477668839
4	Event header: Event number	0
5	Event header: Channel number	0
6	Event header: Hit pattern	0x110321
7	Event header: upper 32 bit of FPGA time stamp (in units of $2^{32} \times 1$ ns)	0
8	Event header: lower 32 bit of FPGA time stamp (in units of 1 ns)	26711904
9	Event header: energy	855
10	Event header: PSA result	0
11	Event header: CFD result	0
12	Event waveform: sample 0	539
13	Event waveform: sample 1	511
14	Event waveform: sample 2	525

The hit pattern is a bit mask, which tells which channels were recorded detected within the specified coincidence window plus some additional status information, as listed in table 7.1.

Bit #	Description
0..3	If set, indicates that data for channel 0..3 have been recorded ¹
4..7	4: Logic level of FRONT panel input 5: Result of LOCAL acceptance test 6: reserved 7: reserved
8..11	If set, indicates that channel 0..3 has been hit in this event ⁴ (i.e. if zero, energy reported is invalid or only an estimate)
12..15	If set, indicates that the GATE input of channel 0..3 has been high at time of fast trigger
16	Coincidence test result
17	Logic level of backplane VETO line
18	If set, indicates event is piled up
19	If set, indicates waveform FIFO full
20	If set, indicates this channel was hit (else the event was recorded based on distributed trigger)
21	If set, indicates that the GATE input of this channel has been high at time of fast trigger
22	If set, indicates this channel was out of ADC range at time of fast trigger
23	If set, indicates a fast pileup condition was detected (time over threshold exceeds MAXWIDTH processing cycles)
24..30	Reserved
31	If set, indicates a data transmission error has been detected for this event. Parts of header and waveform may be corrupted

Table 7-1: Event pattern and Event info in Run Type 0x400, 0x500, 0x501, total 32 bits.

7.1.2 List mode files without waveforms (Run Type 0x501)

The default filename for list mode files without waveforms is **LMdata.dat**. Data consists of comma separated values and is organized as one event per line. The first 2 lines are names and values of run start information. Line 3 lists the column headers for the following event data. For example,

```
Module,RunType,Run_Start_ticks,Run_Start_sec,Unused1,Unused2
0,0x501,4,1477668787,--,--
No,Ch,Hit,Time_H,Time_L,Energy
0,0,0x110321,0,5148104,361
1,1,0x110322,0,5148104,373
2,0,0x110321,0,5960704,360
3,1,0x110322,0,5960704,372
```

lists in line 2 the module number, run type, and run start time in ns (FPGA) and s (Linux). Line 4 and beyond show the event number, channel number, hit pattern, upper and lower time stamp, energy. (See above for definition of these values).

⁴ As event records are for a single channel at a time, only one bit in [0..3] is set. If there was a coincident pulse in any other channel, the corresponding hits in [8..11] are set. However, recording of those other channels follows those channels' rules. For example, if a channel is piled up it will only be recorded if pileup rejection is turned off. Event records thus may show coincidence patterns with more channels than actually being recorded.

7.1.3 List mode files with PSA (Run Type 0x502)

In run type 0x502, the data acquisition program creates list mode files without waveforms named **LMdata.dt2**. Similar to data in run type 0x501, it lists in the first 2 lines are names and values of run start information. Line 3 lists the column headers for the following event data. For example,

```
Module,Run_Type,Run_Start_ticks,Run_Start_sec,Unused1,Unused2
0,0x502,-1107295228,1487638335,---,--
Event_No,Channel_No,Hit_Pattern,Event_Time_H,Event_Time_L,Energy,
Amplitude,CFD,Base,Q0,Q1,PSAvalue
0,0,0x110121,0,396065120,4972,695,0,122,766,289,377
1,0,0x110121,0,396136216,4496,554,0,124,693,305,440
2,0,0x110121,0,396342104,2367,593,0,122,652,287,440
3,0,0x110121,0,396342848,2367,253,0,123,346,172,497
4,0,0x110121,0,396422920,355,520,0,122,496,290,584
```

lists in line 2 the module number, run type, and run start time in ns (FPGA) and s (Linux). Line 4 and beyond show the event number, channel number, hit pattern, upper and lower time stamp, energy, and results of the PSA. (See above for definition of these values). In addition, run type 0x502 creates a file PSA.csv that contains the histogram data of PSA value vs energy (see below).

7.1.4 Coincidence list mode files without waveforms (Run Type 0x503)

The default filename for list mode files without waveforms is **LMdata.dt3**. Data consists of comma separated values and is organized as one 4-channel event per line. The first 2 lines are names and values of run start information. Line 3 lists the column headers for the following event data. For example,

```
Module,Run_Type,Run_Start_ticks,Run_Start_sec,Unused1,Unused2
0,0x503,3204391957,1490636304,---,--
Event_No,Hit_Pattern,Event_Time_H,Event_Time_L,PPStime,Time0,Time1,Time2,Time3,Energy0,Energy1,Energy2,Energy3
1,0x11032F,0,515640,0,515472,515400,0,0,3654,3726,0,0
2,0x11032F,0,1171000,0,1170832,1170760,0,0,3656,3726,0,0
3,0x11032F,0,1826360,0,1826192,1826120,0,0,3659,3727,0,0
4,0x11032F,0,2481720,0,2481552,2481480,0,0,3655,3727,0,0
5,0x11032F,0,3137080,0,3136912,3136840,0,0,3655,3725,0,0
6,0x11032F,0,3792440,0,3792272,3792200,0,0,3660,3732,0,0
7,0x11032F,0,4447800,0,4447632,4447560,0,0,3657,3727,0,0
```

lists in line 2 the module number, run type, and run start time in ns (FPGA) and s (Linux). Line 4 and beyond show the event number, hit pattern, upper and lower time stamp of the event, and local time stamp (24 bit) and energy for each channel. (See above for definition of these values). It also reports a PPStime, which is the local time latched by an external trigger signal. The local time stamp is captured at the rising edge of the pulse in that channel, the event time stamp is latched when the data is recorded in all channels.

7.1.5 Binary list mode files with waveforms (Run Type 0x400)

Run type 0x400 creates single-channel event records in binary format, **LMdata.b00**. This format is compatible with the Pixie-4e. XIA provides a utility to convert this data format to the upcoming IEC63047 list mode standard. The file starts with a file header of 32 words. The 32 words (16 bit unsigned integer, low byte first) are:

Word #	Variable	Description
0	BlkSize	Block size (16-bit words)
1	ModNum	Module number
2	RunFormat	Format descriptor = Run Type
3	ChanHeadLen	Channel Header Length
4	CoincPat	Coincidence pattern
5	CoincWin	Coincidence window in 8ns clock ticks
6	MaxCombEventLen	Maximum length of traces plus headers from all 4 channels (in blocks)
7	BoardVersion	Module type and revision
8	EventLength0	Length of traces from channel 0 plus header (in blocks)
9	EventLength1	Length of traces from channel 1 (in blocks)
10	EventLength2	Length of traces from channel 2 (in blocks)
11	EventLength3	Length of traces from channel 3 (in blocks)
12	SerialNumber	Serial number of that module
13--31	unused	Reserved

Table 7-2: File header data format, total 32 words (16bit).

Following the file header, the single channel event records are stored in sequential order. Each event starts out with a channel header of 32 words. The 32 words (16 bit) are:

Word #	Variable	Description
0	EvtPattern	Hit pattern.
1	EvtInfo	Event status flags.
2	NumTraceBlks	Number of blocks of Trace data to follow the header
3	NumTraceBlksPrev	Number of blocks of Trace data in previous record (for parsing back)
4	TrigTimeLO	Trigger time, low word (in units of 1 ns)
5	TrigTimeMI	Trigger time, middle word (in units of $2^{16} \times 1$ ns)
6	TrigTimeHI	Trigger time, high word (in units of $2^{32} \times 1$ ns)
7	TrigTimeX	Trigger time, extra 8 bits (in units of $2^{48} \times 1$ ns)
8	Energy	Pulse Height
9	ChanNo	Channel number
10--15	PSA Values	
16--31	reserved	

Table 7-3: Channel header for Run Type 0x400, total 32 words (16bit).

The hit pattern is a bit mask, which tells which channels were recorded detected within the specified coincidence window plus some additional status information, as listed in table 7.1. The channel header may be followed by waveform data. An offline analysis program can recognize this by reading the number of waveform blocks from the NumTraceBlks word. The block size is defined in the file header.

7.1.6 Binary coincidence list mode files with waveforms (Run Type 0x402)

Run type 0x402 creates 4-channel event records in binary format, **LMdata.b00**. This format is compatible with the Pixie-4e. The file starts with a file header of 32 words, same as Run Type 0x400.

Following the file header, the 4-channel event records are stored in sequential order. Each event starts out with a channel header of 32 words. The 32 words (16 bit) are

Word #	Variable	Description
0	EvtPattern	Hit pattern.
1	EvtInfo	Event status flags.
2	NumTraceBlks	Number of blocks of Trace data to follow the header (all channels)
3	NumTraceBlksPrev	Number of blocks of Trace data in previous record (for parsing back)
4	TrigTimeHI	Event trigger time, high word
5	TrigTimeX	Event trigger time, extra 8 bits
6	Energy_sum	Sum of channel energies
7	NumUserDataBlks	Number of blocks of user header data to follow
8	LocalTimeLO_0	Local trigger time, low word (ch. 0)
9	LocalTimeMI_0	Local trigger time, middle word (ch. 0)
10	Energy_0	Pulse Height (ch. 0)
11	NumTraceBlks_0	Number of blocks of Trace data to follow the header (ch. 0)
12	LocalTimeLO_1	Local trigger time, low word (ch. 1)
13	LocalTimeMI_1	Local trigger time, middle word (ch. 1)
14	Energy_1	Pulse Height (ch. 1)
15	NumTraceBlks_1	Number of blocks of Trace data to follow the header (ch. 1)
16	LocalTimeLO_2	Local trigger time, low word (ch. 2)
17	LocalTimeMI_2	Local trigger time, middle word (ch. 2)
18	Energy_2	Pulse Height (ch. 2)
19	NumTraceBlks_2	Number of blocks of Trace data to follow the header (ch. 2)
20	LocalTimeLO_3	Local trigger time, low word (ch. 3)
21	LocalTimeMI_3	Local trigger time, middle word (ch. 3)
22	Energy_3	Pulse Height (ch. 3)
23	NumTraceBlks_3	Number of blocks of Trace data to follow the header (ch. 3)
24	reserved	reserved
25	reserved	reserved
26	TrigTimeLO	Event trigger time, low word
27	TrigTimeMI	Event trigger time, middle word
28--31	reserved	reserved

Table 7-4: Channel header for Run Type 0x402, total 32 words (16bit).

7.2 Run Statistics Files

Run Statistics files contain comma separated values. The first row lists the column headers. The columns are

ParameterM	Name of module parameter
Module	Value of module parameter
ParameterC	Name of channel parameter
Channel#	Value of channel parameter for channel #

The units of the reported values are generally in seconds, nanoseconds, or counts per seconds. For full definition and explanation of the values, please see sections 8.3 and 9.3.

For example, the line

```
TOTAL_TIME,5.78441,INPUT_COUNT_RATE,1231.04,1231.04,0,0
```

reports an acquisition TOTAL TIME of 5.78441s and an input rate of 1231.04 counts/s for channel 0 and channel 1.

7.3 MCA Files

MCA files contain comma separated values. The first row lists the column headers (bin number and channel number). The following rows contain the values. For example,

```
bin,MC Ach0,MC Ach1,MC Ach2,MC Ach3  
0,575,563,0,0  
1,55,54,0,0  
2,48,62,0,0  
3,59,53,0,0  
4,56,66,0,0  
5,69,51,0,0
```

7.4 PSA Files

PSA files, generated in Run Type 0x502, contain comma separated values. The first row lists the column headers, i.e. PSA value bin numbers – 100 bins per channel numbered from 0 to 99. The first column lists the energy bin number – 100 bins numbered from 0 to 99.

```
,0,1,2,3,4,5,6,7,8,9,10,11,12,13,14,15 ...  
0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0  
1,0,927,5030,4657,4735,5798,6045,6773  
2,0,4801,3505,4590,4712,5995,6901,769  
3,0,1993,1978,2165,2370,2984,3618,425  
4,0,496,577,642,795,1084,1318,1474,15  
5,0,208,234,255,356,509,626,692,716,7  
6,0,138,137,199,250,337,435,512,528,5  
7,0,78,98,140,205,258,336,402,479,545  
8,0,49,69,110,155,240,303,403,467,506  
9,0,42,51,77,143,206,309,349,437,514,  
...
```

8 Module Registers Visible to Linux

The FPGA (PL) registers described below are used to apply settings to the pulse processing firmware and read back event data. This is generally handled by XIA's API functions and users do not need to go in depth to understand this functionality. The primary way to set registers is by specifying parameters in the .ini file and call XIA's API function `proggfippi` to convert and apply as appropriate. XIA may change register addresses and bits in future code revision, but will try to keep the settings file format constant.

FPGA (PL) I/O registers are organized into 4 blocks. All registers are 32bit wide. All writeable registers are in block 0. To read registers, the output block number has to be written to address 0x003; this sets the upper digit of the read addresses. For example, writing 2 to the OUTBLOCK register (0x003) selects read address range 0x200-0x2FF.

8.1 Input Registers

Address range is 0x000 – 0x00F. Can be read back to verify I/O

Use these to specify parameters that control the data acquisition

Register	Address	R/W	Description
CSRIN	0x000	R/W	Run Control Register bits 0 RunEnable (set to start DAQ run) 9 nLive (set to 1 to pause DAQ run)
COINCPATTERN	0x001	R/W	Allowed coincidence pattern and other control bits 0..15 CoincPattern 16 LMRUN402 (coincidence mode) 17 MCARUN (no trace out mode) 18 CWGROUP (only 1 record per CW)
I2C	0x002	R/W	Control the SDA and SCL lines 0 SDA 1 SCL 2 SDA ENA (SDA output enable)
OUTBLOCK	0x003	R/W	Specifies address range for reads If 0: 0x000-0x04F If 1: 0x100-0x14F If 2: 0x200-0x29F If 3: 0x300-0x303
HV_DAC	0x004	R/W	HV DAC value (16 bit)
SERIAL_IO	0x005	R/W	Value for offboard serial IO (16 bit)
AUX_CTRL	0x006	R/W	Aux Control bits for HW 0 pulser enable 1 LED red on/off (NYI) 2 reserved 3 synchronize to PTP triggers
ADC_CTRL	0x007	R/W	Controls certain aspects of ADC operation 0 swap channel 0/1 data streams 1 swap channel 2/3 data streams
DSP_CLR	0x008	W	Writing to this register issues a dspclr pulse (processing init)
COUNTER_CLR	0x009	W	Writing to this register issues a pulse to clear runstats counters and arms the average ADC capture logic

RTC_CLR	0x00A	W	Writing to this register issues a pulse to clear RTC time counter
	0x00C-0x00F	R/W	Reserved

8.2 Event Registers

Address range is 0x100 – 0x10F. Read only

Use these during the run to get info of the current status

Register	Address	R/W	Description
CSROUT	0x100	R	Run Status info bits 0 RunEnable (set to start DAQ run) 2 SDA readback 4 zdtfull 5 PTPenable required 7 PTPenabled 9 nLive 10 PSA licensed 11 VetoIn 13 ACTIVE (=RunEnable) 15..31 debug
EVSTATS	0x101	R	EVSTATS (Event status information) 0 DataReadyA (if 1, there is data in channel's ZDT buffer) 1 DataReadyB 2 DataReadyC 3 DataReadyD
reserved	0x102	R	
PPSTIME	0x103	R	Current PPStime (local time latched with external trigger)
reserved	0x104	R	
EVTIME_L	0x105	R	Event time stamp M, L (mode 0x402, 503)
EVTIME_H	0x106	R	Event time stamp X, H (mode 0x402, 503)
EVPPS	0x107	R	Event PPS time (mode 0x402, 503)
ADCTRIG	0x108	R	0 if 1, averaging ADC capture is waiting for trigger (ch.0) 1 if 1, averaging ADC capture is waiting for trigger (ch.1) 2 if 1, averaging ADC capture is waiting for trigger (ch.2) 3 if 1, averaging ADC capture is waiting for trigger (ch.3) 4 if 1, averaging ADC capture is done (ch.0) 5 if 1, averaging ADC capture is done (ch.1) 6 if 1, averaging ADC capture is done (ch.2) 7 if 1, averaging ADC capture is done (ch.3)
reserved	0x109-F	R	

8.3 Run Statistics Registers

Address range is 0x200 – 0x21F. Read only

Used for run statistics and other output values. Sometimes two 16bit words per address

Unit “ticks” means 2ns clock ticks

Index in runstats parameter list	PL address	units	Parameter name	Description
0	0x200	Bits	L CSROUT H CSROUT	See above, addr 0x100
1	0x201	ns	L SYSTIME_L H SYSTIME_M	Time since last STC reset (lower 32 bit)
2	0x202	ns	L RUNTIME_L H RUNTIME_M	RunTime for current/last run (lower 32 bit)
3	0x203	ns	L RUNTIME_H H RUNTIME_X	RunTime for current/last run (upper 32 bit)
4	0x204	ns	L TOTALTIME_L H TOTALTIME_M	TotalTime for current/last run (lower 32 bit)
5	0x205	ns	L TOTALTIME_H H TOTALTIME_X	TotalTime for current/last run (upper 32 bit)
6	0x206		L NUMEVENTS_L H NUMEVENTS_M	Number of events in current/last run (lower 32 bit)
7	0x207		L NUMEVENTS_H H NUMEVENTS_X	Number of events in current/last run (upper 32 bit)
8	0x208		L EHL H BHL	Event Header Length Buffer Header Length
9	0x209		L FIFOLENGTH H CHL	Length of waveform capture FIFO Channel Header Length
10	0x20A		L FIPREVISION H SYSREVISION	FW Revision numbers
11	0x20B		L SERIAL_NUMBER H --	Serial number of the module
12-31	0x20C – 0x21F		reserved	

The full value of e.g. RUNTIME is computed as

$$\begin{aligned} \text{RUNTIME} = & \text{ RUNTIME_L} + \\ & \text{ RUNTIME_M} * 2^{16} + \\ & \text{ RUNTIME_H} * 2^{32} + \\ & \text{ RUNTIME_X} * 2^{48} \end{aligned}$$

Times are in units of 1ns.

Output values derived from the run statistics parameters are

1. EVENT_RATE = NUMEVENTS / RUNTIME

9 Channel Registers Visible to Linux

The FPGA (PL) registers described below are used to apply settings to the pulse processing firmware and read back event data. This is generally handled by XIA's API functions and users do not need to go in depth to understand this functionality. The primary way to set registers is by specifying parameters in the .ini file and call XIA's API function `progfippi` to convert and apply as appropriate. XIA may change register addresses and bits in future code revision, but will try to keep the settings file format constant.

Channel I/O registers are organized into 4 blocks. All registers are 32bit wide. All writeable registers are in block 0. To read registers, the output block number has to be written to address 0x003; this sets the upper digit of the read addresses. For example, writing 2 to the OUTBLOCK register (0x003) selects read address range 0x200-0x2FF.

9.1 Input Registers

Address range is 0x0N0 – 0x0NF, N=1..4. Can be read back to verify I/O

Use these to specify parameters that control the data acquisition

Register	Address	R/W	Description
0	0x0N0	R/W	CCSRA, CCSRC: 0 GROUPTRIG (local or dist. trigger) 1 reserved 2 GOOD (enables triggers) 3 reserved 4 TRIGENA (trigger enabled) 5 INVERT (ADC input polarity) 6 VETOENA (GFLT required) 7 reserved 8 reserved 9 NEGE (NYI) 10 CFD TIME (NYI) 11 reserved 12 GATE_ENA (enable GATE rejection) 13 LOCALTIME (channel time stamp source) 14 ESTIMATE_E (NYI) 15 TRIGGER16X (slow down trigger by factor 16) 16 VETO_INV (invert GFLT/Veto) 17 GATE_INV (polarity for TrigCtrl) 18 VETO2GATE (use GFLT/Veto for Gate) 19 PILEUP_DISABLE 20 RBAD_DISABLE (disable Rangebad) 21 PILEUP_INVERT 22 PILEUP_PAUSE 23 GATE_EDGEINV (select r/f edge for GATE) 24 GATE_STATS (gate statistics, NYI) 25 GDT_ALLOW (ignored) 26 GATE_NOPULSE (use input directly, no edge) 27 TRACE4X (slow down trigger and trace capture by factor 4) 28 GateIsBit0 29 GATE_OUT (to FP after invert/repulse etc)
1	0x0N1	R/W	0-6 SL (Slow Length)

			8-14 SLSG (Slow length + gap) 16-22 SG (slow filter gap for BL pileup) 24-30 RDEL2-8 (delay for clearing Rangebad, bits 0,1=0)
2	0x0N2	R/W	0-5 FL (Fast Length) 8-13 FLFG (Fast length + gap) 16-25 THRE (trigger threshold) 26-29 DEC (filter decimation) 31 HALT (stop filters)
3	0x0N3	R/W	0-6 PEAKSAM (sample slow filter for E sum) 13-25 PEAKSEP (pileup inspection period) 26+ GAIN
4	0x0N4	R/W	0-15 DAC value
5	0x0N5	R/W	0-8 User Delay/4 (pretrigger trace) 29 NONZERO_TRACE
6	0x0N6	R/W	0-9 TRACELENGTH/4 16-23 coincwindow 24-31: PSATH (PSA threshold/4)
7	0x0N7	R/W	0-7 GATEWINDOW (stretch length of GATE pulse) 8-14 GATEDELAY (input delay for GATE)
8	0x0N8		Reserved for ADC programming
9	0x0N9	R/W	0-7 CoincDelay
10	0x0NA	R/W	0-4 QDC0length (length) 5 QDCDIV0 6-7 QDCshift (shift within a group of 4 samples) 8-14 QDC0delay (length+delay) 15 QDC0correct (correct for 4 sample coarseness) 16-20 QDC1length 21 QDCDIV1 24-30 QDC1delay 31 QDC1correct
11	0x0NB	R/W	0-15: number of ADC samples to average 16-31: trigger threshold (ADC steps)
12-15	0x0NC-0x0NF	R/W	Reserved

9.2 Event Registers

Address range is 0x1N0 – 0x1NF, and 0x30N, N=1..4. Read only

Use these during the run to read event data

Register	Address	R/W	Description
EVDATAA	0x1N0	R	Hitpattern
EVDATAB	0x1N1	R	Event or local time stamp M, L Time units: ns (Exception in run task 0x402, 0x503: local TS contains lower 24 bits * 256)
EVDATAC	0x1N2	R	Event time stamp X, H Time units: ns
PSAA	0x1N3	R	PSA value
PSAB	0x1N4	R	PSA value or gate pulse counter
CFDA	0x1N5	R	CFD values
CFDB	0x1N6	R	CFD values
EVDATAD	0x1N7	R	Lsum
EVDATAE	0x1N8	R	Tsum

EVDATAF	0x1N9	R	Gsum, read advances event buffers and increments NOUT
REJECT	0x1NA	R	Read advances event buffers without incrementing NOUT
BLDATA_L	0x1NB	R	Lsum for BL avg
BLDATA_T	0x1NC	R	Tsum for BL avg
BLDATAG	0x1ND	R	Gsum for BL avg
ADC_AVG	0x1NE	R	ADC buffered and averaged value
ADC	0x1NF	R	ADC value

Register	Address	R/W	Description
WF0	0x300	R	Waveform FIFO channel 0
WF1	0x301	R	Waveform FIFO channel 1
WF2	0x302	R	Waveform FIFO channel 2
WF3	0x303	R	Waveform FIFO channel 3

9.3 Run Statistics Registers

Address range is 0x2[2N]0 – 0x2[2N+1]F, N=1..4. Read only

Used for run statistics and other output values.

Index in runstats parameter list	PL address	Units	Parameter name	Description
0	0x2[2N]0		L_OOR	Out of range fraction
1	0x2[2N]1		L_ICR	Input count rate
2	0x2[2N]2	ns	L_COUNTTIME_L H_COUNTTIME_M	Count Time
3	0x2[2N]3	ns	L_COUNTTIME_H H_COUNTTIME_X	
4	0x2[2N]4		L_NTRIG_L H_NTRIG_M	Number of triggers (P4e: FastPeaks)
5	0x2[2N]5		L_NTRIG_H H_NTRIG_X	
6	0x2[2N]6	ns	L_FTDT_L H_FTDT_M	Fast trigger dead time
7	0x2[2N]7	ns	L_FTDT_H H_FTDT_X	
8	0x2[2N]8	ns	L_SFDT_L H_SFDT_M	Slow filter dead time*
9	0x2[2N]9	ns	L_SFDT_H H_SFDT_X	
10	0x2[2N]A		L_GCOUNT_L H_GCOUNT_M	Number of gate pulses*
11	0x2[2N]B		L_GCOUNT_H H_GCOUNT_X	
12	0x2[2N]C		L_NOUT_L H_NOUT_M	Number of output counts
13	0x2[2N]D		L_NOUT_H H_NOUT_X	
14	0x2[2N]E	ns	L_GDT_L	Gate dead time*

			H GDT_M	
15	0x2[2N]F	ns	L GDT_H H GDT_X	
16	0x2[2N+1]0		L NPPI_L H NPPI_M	Number of counts passing pileup inspection*
17	0x2[2N+1]1		L NPPI_H H NPPI_X	
18	0x2[2N+1]2		L NFPILE_L H NFPILE_M	Number of pulses that stayed above trigger threshold for more than MAXWIDTH processing cycles.
19	0x2[2N+1]3		L NFPILE_H H NFPILE_X	
20-31	0x2[2N+1]4- 0x2[2N+1]F		Reserved	

Properties marked with * are omitted in the PSA version of the firmware

The full value of e.g. COUNTTIME is computed as

$$\begin{aligned} \text{COUNTTIME} = & \quad \text{COUNTTIME_L} + \\ & \quad \text{COUNTTIME_M} * 2^{16} + \\ & \quad \text{COUNTTIME_H} * 2^{32} + \\ & \quad \text{COUNTTIME_X} * 2^{48} \end{aligned}$$

Times are in units of 1ns.

Output values derived from the run statistics parameters are

1. OUTPUT_COUNT_RATE = NOUT / COUNTTIME
2. INPUT_COUNT_RATE = NTRIG / (COUNTTIME-FTDT)
3. PASS_PILEUP_RATE = NPPI / COUNTTIME
4. GATE_RATE = GCOUNT / COUNTTIME

10 Linux Configuration

10.1 Licensing Information

The Pixie-Net software includes several components that are licensed with the GNU general public license (GPL). For most of them, the software is unchanged, and the source code is provided on the Pixie-Net SD card with the corresponding GPL license files. A small portion of the software is modified by XIA and the modified source code is provided both on the SD card and on XIA's website. The source code for the Linux kernel built by XIA for the Pixie-Net and for the full collection of Ubuntu Linux programs is too large for the SD card or to host by XIA, but we can provide it upon request. XIA strives to keep those programs up to date and our own code compatible with the latest version, however, the best source of the programs may be their official repository.

List of key GPL programs:

- LinuxPTP source code on SD card or
 at <http://linuxptp.sourceforge.net/>
- ptp-mii-tool source code on SD card or
 at <https://github.com/giftnuss/net-tools> (original mii-tool) or
 at <http://support.xia.com/default.asp?W772> (XIA modification)
- Linux kernel source code per request or
 at <https://github.com/Xilinx/linux-xlnx>
- Ubuntu files source code and configuration files on SD or
 at <https://releases.linaro.org/ubuntu/images/developer/latest/linaro-vivid-developer-20151215-714.tar.gz>
 or per request
 - includes
 - Lighttpd
 - Samba
 - g++
 - i2c-tools

10.2 Software Information

The Pixie-Net Linux system prior to SW version 1.20 was based on Xillinux (1.3), which is based on Ubuntu LTS 12.04. The initial distribution can be downloaded from the Xillinux website (<http://xillybus.com/xillinux>). In what is distributed by XIA, the initial setup steps as described in the Xillinux documentation have been applied, including copying the Linux OS image on an SD card and increasing the “disk space” to 16GB. (http://xillybus.com/downloads/doc/xillybus_getting_started_zynq.pdf)

Starting from SW version 2.0, Ubuntu 15 with kernel version 4 is used. This has no major effect on the Pixie-Net operation, but more apps from the Linux universe are available. In 2019, the OS was upgraded to Ubuntu 18.04 LTS.

The SD card contains mainly the Linux OS (not visible to Windows) and 4 boot files (visible) in a small FAT partition. FPGA configuration updates have to be copied to that partition.

10.2.1 Ubuntu 15

In the Ubuntu 15 release, the following Linux applications are installed with apt-get install.

- lighttpd
`/etc/lighttpd/lighttpd.conf` modified as in `/var/www/other_settings` to allow cgi and web operations.

Create `"/var/www/webopspasswords`

`webops:xia17pxn`

This file should be modified to change the password. For sensitive environments, change to encrypted passwords.

Create folder `/var/www/webops`

change owner to `www-data (=lighttpd)`

in webops, make links to ini, jpg, js, html files from `/var/www`:

```
root@pixie-net:/var/www/webops# ls
ADC.csv           coincdaq.cgi      psahistprojpage.html
LMdata.txt        d3.v3.min.js     psasurfacepage.html
MCA.csv          defaults.ini      rpage.html
RS.csv           dygraph-combined.js runstats.cgi
Kia_LLC_web_header.jpg findsettings.cgi settings.ini
acquire.cgi       gettraces.cgi    startdaq.cgi
adcpage.html     mcapage.html     webopsindex.html
cgistats.cgi     pashistpage.html webopsindex.html.backup
cgitraces.cgi    plotly-latest.min.js
cgrowaveforms.cgi progfippi.cgi
```

(white: data files created by webops, blue: links, green: webop specific html page)

- g++
- i2c-tools
- boost version 1.55 from Ubuntu
- samba
- xfce4
- root-system-bin (ROOT)

Other configurations

- Zync temperature
For kernel 4.x, raw files are `/sys/devices/soc0/amba/f8007100.adc/iio:device0`, which is difficult to open/read from a program because of the colon.
So we made a symbolic link :
`ln -s /sys/devices/soc0/amba/f8007100.adc/iio\:device0/in_temp0_raw temp0_raw`
to access it from `PixieNetCommon.c` and compute T in Celsius.
- To automatically give permission to all users to `/dev/uio0` (avoiding the initial chmod command):
insert the following line in the file `/etc/udev/rules.d/10-local.rules`:
`KERNEL=="uio0", MODE=="666"`

10.2.2 Ubuntu 18

In the latest Ubuntu 18 release, the main differences to Ubuntu 15 are

- added support for ntfs drives
- removal of ROOT
- removal of remote desktop login
- login required for UART/USB terminal
- bugfix applied in kernel for transmission of large files (Xilinx kernel release 2017.4)

On Ubuntu 18, The following Linux applications are installed with apt-get install.

- lighttpd
`/etc/lighttpd/lighttpd.conf` modified as in `/var/www/other_settings` to allow cgi and web operations.

Create `"/var/www/webopspasswords`

`webops:xia17pxn`

This file should be modified to change the password. For sensitive environments, change to encrypted passwords.

Create folder `/var/www/webops`

change owner to `www-data` (=lighttpd)

in webops, make links to ini, jpg, js, html files from `/var/www:`

```
root@pixie-net:/var/www/webops# ls
ADC.csv           coincdaq.cgi      psahistprojpage.html
LMdata.txt        d3.v3.min.js     psasurfacepage.html
MCA.csv          defaults.ini     rspage.html
RS.csv           dygraph-combined.js runstats.cgi
Kia_LLC_web_header.jpg   findsettings.cgi settings.ini
acquire.cgi       gettraces.cgi    startdaq.cgi
adcpage.html     mcapage.html     webopsindex.html
bgistats.cgi     pashistpage.html webopsindex.html.backup
bgitraces.cgi    plotly-latest.min.js
cgiwaveforms.cgi progfippi.cgi
```

(white: data files created by webops, blue: links, green: webop specific html page)

- g++
- i2c-tools
- samba (see configuration file in `/var/www/other_settings`)
 - + sudo smbpasswd -a root xia17pxn
 - + sudo service smbd restart
- python-dev
- libboost-all-dev
- minicom
- ntfs-3g (with fuse_fs driver enabled in kernel)
- ntfs-config
- ethtool
- linuxptp

The desktop xfce4 for graphical remote login and ROOT are **not** installed by default in Ubuntu 18 (ROOT is no longer an apt package).

10.2.3 Systemd startup routine to configure parameters

A *systemd* startup routine is called at boot time to set the parameters (i.e. ./progfippi). The routine `pixie_boot.service` is located in `/etc/systemd/system/` and calls the shell script `autoboot.sh` in `/var/www/`. Output from the script is captured in `autoboot.log`.

The script can be modified as necessary and executed from the command line or automatically at the next boot. The service file can be modified as well, but requires restarting the service with

```
systemctl disable pixie_boot.service
systemctl start pixie_boot.service
systemctl enable pixie_boot.service
```

A backup copy of `pixie_boot.service` is located in the folder `other_settings`

10.2.4 Other configurations

- Sync temperature
For kernel 4.x, raw files are `/sys/devices/soc0/amba/f8007100.adc/iio:device0`, which is difficult to open/read from a program because of the colon.
So we made a symbolic link :
`ln -s /sys/devices/soc0/amba/f8007100.adc/iio\:device0/in_temp0_raw temp0_raw`
to access it from `PixieNetCommon.c` and compute T in Celsius.
- To automatically give permission to all users to `/dev/uio0` (avoiding the initial chmod command):
insert the following line in the file `/etc/udev/rules.d/10-local.rules`:
`KERNEL=="uio0", MODE="666"`
and also in `/etc/udev/uio.rules` as it seems to overwrite the 10-local rules.

10.3 Other Settings

10.3.1 Static IP address

In some networks, it is required that the Pixie-Net has a static IP. This is usually configured by the “local network administrator” but here are some notes that may be helpful:

- Ubuntu 18
As Ubuntu 18.04 uses netplan to manage the network, you can create a file ending in `.yaml` in the `/etc/netplan/` directory. As an example, see the `01-netplan.yaml` in the “other settings” folder on the Pixie-Net. You would need to modify the IP address/gateway and may also be necessary to add additional DNS.
After that, you can use the command `netplan apply` to apply the changes, or you can reboot.
- Ubuntu 18, more detail
Perform the following steps on the Pixie through the terminal:
 1. Run: `nano /etc/netplan/01-netcfg.yaml`
 2. Inside the `01-netcfg.yaml`, we have put following:
network:
version: 2
renderer: networkd
ethernets:
ens3:
dhcp4: no

addresses:

- 192.168.1.86/24

3. Run: sudo netplan apply

With this the static IP is preserved even if the system is halted or shut down

- Ubuntu 15

Ubuntu15 configures static IP by modifying the file /etc/network/interfaces. An example is also located in the “other settings” folder on the Pixie-Net. When using static IP, uncomment the 4-11 lines in the file and make the corresponding changes.

11 Theory of Operation

11.1 Digital Filters for γ -ray Detectors

Energy dispersive detectors, which include such solid state detectors as Si(Li), HPGe, HgI₂, CdTe and CZT detectors, are generally operated with charge sensitive preamplifiers as shown in Figure 6.1 (a). Here the detector D is biased by voltage source V and connected to the input of preamplifier A which has feedback capacitor C_f and feedback resistor R_f.

The output of the preamplifier following the absorption of an γ -ray of energy E_x in detector D is shown in Figure 6.1 (b) as a step of amplitude V_x (on a longer time scale, the step will decay exponentially back to the baseline, see section 6.3). When the γ -ray is absorbed in the detector material it releases an electric charge Q_x = E_x/ ϵ , where ϵ is a material constant. Q_x is integrated onto C_f, to produce the voltage V_x = Q_x/C_f = E_x/(ϵ C_f). Measuring the energy E_x of the γ -ray therefore requires a measurement of the voltage step V_x in the presence of the amplifier noise σ , as indicated in Figure 11-1 (b). Scintillator detectors read out with a photomultiplier tube generate pulses in a different mechanism, but for the most part they can still be described as fast rise followed by exponential decay, so the processing described below equally applies.




Figure 11-1: (a) Charge sensitive preamplifier with RC feedback; (b) Output on absorption of a γ -ray.

Reducing noise in an electrical measurement is accomplished by filtering. Traditional analog filters use combinations of a differentiation stage and multiple integration stages to convert the preamp output steps, such as shown in Figure 11-1 (b), into either triangular or semi-Gaussian pulses whose amplitudes (with respect to their baselines) are then proportional to V_x and thus to the γ -ray's energy.

Digital filtering proceeds from a slightly different perspective. Here the signal has been digitized and is no longer continuous. Instead it is a string of discrete values as shown in Figure 11-2. Figure 11-2 is actually just a subset of Figure 11-1 (b), in which the signal was digitized by a Tektronix 544 TDS digital oscilloscope at 10 MSPS (mega samples per second). Given this data set, and some kind of arithmetic processor, the obvious approach to determining V_x is to take some sort of average over the points before the step and subtract

it from the value of the average over the points after the step. That is, as shown in Figure 11-2, averages are computed over the two regions marked “Length” (the “Gap” region is omitted because the signal is changing rapidly here), and their difference taken as a measure of V_x . Thus the value V_x may be found from the equation:

$$V_{x,k} = - \sum_{i(\text{before})} W_i V_i + \sum_{i(\text{after})} W_i V_i \quad (1)$$

where the values of the weighting constants W_i determine the type of average being computed. The sums of the values of the two sets of weights must be individually normalized.




Figure 11-2: Digitized version of the data of Figure 6.1 (b) in the step region.

The primary differences between different digital signal processors lie in two areas: what set of weights W_i is used and how the regions are selected for the computation of Eqn. 1. Thus, for example, when larger weighting values are used for the region close to the step while smaller values are used for the data away from the step, Eqn. 1 produces “cusp-like” filters. When the weighting values are constant, one obtains triangular (if the gap is zero) or trapezoidal filters. The concept behind cusp-like filters is that, since the points nearest the step carry the most information about its height, they should be most strongly weighted in the averaging process. How one chooses the filter lengths results in time variant (the lengths vary from pulse to pulse) or time invariant (the lengths are the same for all pulses) filters. Traditional analog filters are time invariant. The concept behind time variant filters is that, since the γ -rays arrive randomly and the lengths between them vary accordingly, one can make maximum use of the available information by setting the length to the interpulse spacing.

In principle, the very best filtering is accomplished by using cusp-like weights and time variant filter length selection. There are serious costs associated with this approach however, both in terms of computational power required to evaluate the sums in real time and in the complexity of the electronics required to generate (usually from stored coefficients) normalized W_i sets on a pulse by pulse basis.

The Pixie-Net takes a different approach because it was optimized for high speed operation. It implements a fixed length filter with all W_i values equal to unity and in fact computes this sum afresh for each new signal value k . Thus the equation implemented is:

$$LV_{x,k} = - \sum_{i=k-2L-G+1}^{k-L-G} V_i + \sum_{i=k-L+1}^k V_i \quad (2)$$

where the filter length is L and the gap is G . The factor L multiplying $V_{x,k}$ arises because the sum of the weights here is not normalized. Accommodating this factor is trivial.

While this relationship is very simple, it is still very effective. In the first place, this is the digital equivalent of triangular (or trapezoidal if $G \neq 0$) filtering which is the analog industry's standard for high rate processing. In the second place, one can show theoretically that if the noise in the signal is white (i.e. Gaussian distributed) above and below the step, which is typically the case for the short shaping times used for high signal rate processing, then the average in Eqn. 2 actually gives the best estimate of V_x in the least squares sense. This, of course, is why triangular filtering has been preferred at high rates. Triangular filtering with time variant filter lengths can, in principle, achieve both somewhat superior resolution and higher throughputs but comes at the cost of a significantly more complex circuit and a rate dependent resolution, which is unacceptable for many types of precise analysis. In practice, XIA's design has been found to duplicate the energy resolution of the best analog shapers while approximately doubling their throughput, providing experimental confirmation of the validity of the approach.

11.2 Trapezoidal Filtering in a Pixie Module

From this point onward, we will only consider trapezoidal filtering as it is implemented in a Pixie module according to Eqn. 6.2. The result of applying such a filter with Length $L=1\mu s$ and Gap $G=0.4\mu s$ to a γ -ray event is shown in Figure 6.3. The filter output is clearly trapezoidal in shape and has a rise time equal to L , a flattop equal to G , and a symmetrical fall time equal to L . The basewidth, which is a first-order measure of the filter's noise reduction properties, is thus $2L+G$.

This raises several important points in comparing the noise performance of the Pixie module to analog filtering amplifiers. First, semi-Gaussian filters are usually specified by a *shaping time*. Their rise time is typically twice this and their pulses are not symmetric so that the basewidth is about 5.6 times the shaping time or 2.8 times their rise time. Thus a semi-Gaussian filter typically has a slightly better energy resolution than a triangular filter of the same rise time because it has a longer filtering time. This is typically accommodated in amplifiers offering both triangular and semi-Gaussian filtering by stretching the triangular rise time a bit, so that the *true* triangular rise time is typically 1.2 times the selected semi-Gaussian rise time. This also leads to an apparent advantage for the analog system when its energy resolution is compared to a digital system with the same nominal rise time.

One important characteristic of a digitally shaped trapezoidal pulse is its extremely sharp termination on completion of the basewidth $2L+G$. This may be compared to analog filtered pulses whose tails may persist up to 40% of the rise time, a phenomenon due to the finite bandwidth of the analog filter. As we shall see below, this sharp termination gives the digital filter a definite rate advantage in pileup free throughput.




Figure 11-3: Trapezoidal filtering of a preamplifier step with $L=1\mu s$ and $G=0.4\mu s$.

11.3 Baselines and Preamplifier Decay Times

Figure 11-4 shows an event over a longer time interval and how the filter treats the preamplifier noise in regions when no γ -ray pulses are present. As may be seen the effect of the filter is both to reduce the amplitude of the fluctuations and reduce their high frequency content. This region is called the *baseline* because it establishes the reference level from which the γ -ray peak amplitude V_x is to be measured. The fluctuations in the baseline have a standard deviation σ_e which is referred to as the *electronic noise* of the system, a number which depends on the rise time of the filter used. Riding on top of this noise, the γ -ray peaks contribute an additional noise term, the *Fano noise*, which arises from statistical fluctuations in the amount of charge Q_x produced when the γ -ray is absorbed in the detector. This Fano noise σ_f adds in quadrature with the electronic noise, so that the total noise σ_t in measuring V_x is found from

$$\sigma_t = \sqrt{(\sigma_f^2 + \sigma_e^2)} \quad (3)$$

The Fano noise is only a property of the detector material. The electronic noise, on the other hand, may have contributions from both the preamplifier and the amplifier. When the preamplifier and amplifier are both well designed and well matched, however, the amplifier's noise contribution should be essentially negligible. Achieving this in the mixed analog-digital environment of a digital pulse processor is a non-trivial task, however.

With a RC-type preamplifier, the slope of the preamplifier is rarely zero. Every step decays exponentially back to the DC level of the preamplifier. During such a decay, the baselines are obviously not zero. This can be seen in Figure 11-4, where the filter output during the exponential decay after the pulse is below the initial level. Note also that the flat top region is sloped downwards.

Using the decay constant τ , the baselines can be mapped back to the DC level. This allows precise determination of γ -ray energies, even if the pulse sits on the falling slope of a previous pulse. The value of τ , being a characteristic of the preamplifier, has to be determined by the user and host software and downloaded to the module.




Figure 11-4: A γ -ray event displayed over a longer time period to show baseline noise and the effect of preamplifier decay time.

11.4 Thresholds and Pile-up Inspection

As noted above, we wish to capture a value of V_x for each γ -ray detected and use these values to construct a spectrum. This process is also significantly different between digital and analog systems. In the analog system the peak value must be “captured” into an analog storage device, usually a capacitor, and “held” until it is digitized. Then the digital value is used to update a memory location to build the desired spectrum. During this analog to digital conversion process the system is dead to other events, which can severely reduce system throughput. Even single channel analyzer systems introduce significant dead time at this stage since they must wait some period (typically a few microseconds) to determine whether or not the window condition is satisfied.

Digital systems are much more efficient in this regard, since the values output by the filter are already digital values. All that is required is to take the filter sums, reconstruct the energy V_x , and add it to the spectrum. In the Pixie-Net, the filter sums are continuously updated in the FPGA and are captured into event buffers. Reconstructing the energy and incrementing the spectrum is done by the ARM processor, so that the FPGA is ready to take new data immediately (unless the buffers are full). This is a significant source of the enhanced throughput found in digital systems.

The peak detection and sampling in a Pixie module is handled as indicated in Figure 11-5. Two trapezoidal filters are implemented, a *fast filter* and a *slow filter*. The fast filter is used to detect the arrival of γ -rays, the slow filter is used for the measurement of V_x , with reduced noise at longer filter rise times. The fast filter has a filter length $L_f = 0.1\mu s$ and a gap $G_f = 0.1\mu s$. The slow filter has $L_s = 1.2\mu s$ and $G_s = 0.35\mu s$.

The arrival of the γ -ray step (in the preamplifier output) is detected by digitally comparing the fast filter output to THRESHOLD, a digital constant set by the user. Crossing the threshold starts a delay line to wait PEAKSAMP clock cycles to arrive at the appropriate time to sample the value of the slow filter. Because the digital filtering processes are deterministic, PEAKSAMP depends only on the values of the fast and slow filter constants.

The slow filter value captured following PEAKSAMP is then the slow digital filter's estimate of V_x . Using a delay line allows to stage sampling of multiple pulses even within a PEAKSAMP interval (though the filter values themselves are then not correct representations of a single pulse's height).




Figure 11-5: Peak detection and sampling in a Pixie module.




Figure 11-6: A sequence of 3 γ -ray pulses separated by various intervals to show the origin of pileup and demonstrate how it is detected by the Pixie module.

The value V_x captured will only be a valid measure of the associated γ -ray's energy provided that the filtered pulse is sufficiently well separated in time from its preceding and succeeding neighbor pulses so that their peak amplitudes are not distorted by the action of the trapezoidal filter. That is, if the pulse is not *piled up*. The relevant issues may be understood by reference to Figure 11-6, which shows 3 γ -rays arriving separated by various

intervals. The fast filter has a filter length $L_f = 0.1\mu s$ and a gap $G_f = 0.1\mu s$. The slow filter has $L_s = 1.2\mu s$ and $G_s = 0.35\mu s$.

Because the trapezoidal filter is a linear filter, its output for a series of pulses is the linear sum of its outputs for the individual members in the series. Pileup occurs when the rising edge of one pulse lies under the peak (specifically the sampling point) of its neighbor. Thus, in Figure 6.6, peaks 1 and 2 are sufficiently well separated so that the leading edge of peak 2 falls after the peak of pulse 1. Because the trapezoidal filter function is symmetrical, this also means that pulse 1's trailing edge also does not fall under the peak of pulse 2. For this to be true, the two pulses must be separated by at least an interval of $L + G$. Peaks 2 and 3, which are separated by less than $1.0\mu s$, are thus seen to pileup in the present example with a $1.2\mu s$ rise time.

This leads to an important point: whether pulses suffer slow pileup depends critically on the rise time of the filter being used. The amount of pileup which occurs at a given average signal rate will increase with longer rise times.

Because the fast filter rise time is only $0.1\mu s$, these γ -ray pulses do not pileup in the fast filter channel. The Pixie module can therefore test for slow channel pileup by measuring the fast filter for the interval PEAKSEP after a pulse arrival time. If no second pulse occurs in this interval, then there is no trailing edge pileup and the pulse is validated for acquisition. PEAKSEP is usually set to a value close to $L + G + 1$. Pulse 1 passes this test, as shown in Figure 6.6. Pulse 2, however, fails the PEAKSEP test because pulse 3 follows less than $1.0\mu s$. Notice, by the symmetry of the trapezoidal filter, if pulse 2 is rejected because of pulse 3, then pulse 3 is similarly rejected because of pulse 2.

11.5 Filter Range

To accommodate a wide range of energy filter rise times from tens of nanoseconds to tens of microseconds, the filters are implemented in the FPGA with different clock decimations (filter ranges). The ADC sampling rate is always 8ns (2ns or 4ns in 500 MSPS or 250 MSPS variants), but in higher clock decimations, several ADC samples are averaged before entering the energy filtering logic. In filter range 1, 2^1 samples are averaged, 2^2 samples in filter range 2, and so on. Since the sum of rise time and flat top is limited to 127 decimated clock cycles, filter time granularity and filter time are limited to the values listed in Table 6.1.

11.6 Data Capture Process

The data capture in the Pixie-Net is based on the principle that for every detected rising edge, one record is assembled from the continuously running processes for waveform capture and energy filters. As some of the processes are not finished by the time of the rising edge, input data or capture signals are delayed appropriately. For example, incoming ADC data is delayed for the waveform capture by the user specified pre-trigger delay. The signal to capture energy filter sums is sent through a delay line of length (energy filter rise time plus energy filter flat top) to capture the output after filtering.

Consequently, for every rising edge, the following information is latched into front end buffers:

- 56 bit time stamp of latch signal
- 32 bit time stamp of last rising edge in this channel
- Energy filter sums for last rising edge in this channel
- Pileup inspection flags
- Coincidence flags
- Starting address of waveform memory

and the (delayed) waveform data begins to flow into the waveform memory, for the user specified length of trace. The front end buffers hold 500 such records and the waveform memory holds 8Ki samples.

When the front end buffers are not empty, a flag is raised for the ARM processor. On this flag, the ARM processor reads one record and checks if it is to be recorded per the user defined pileup and coincidence conditions. If so, the ARM processor computes final energies, increments the MCA histogram, and reads and writes the list mode data to file. If the event is piled up or otherwise rejected, it is cleared from the front end buffer without recording.

Closely following rising edges still capture one record per edge, with the limitation of one record per 1/8 of a decimated clock cycle in filter range 3 and higher. If such events are piled up, the energy will not be a valid measure of the pulse height and waveforms may overlap from pulse to pulse, but some of the information in the record may still be useful for offline re-analysis. The recording of overlapping waveforms is disabled by default (CCSRA_NO_OVERLAP_08 = 1 in defaults.ini) so that there is only one record per waveform length. It still may contain multiple rising edges, but they do not capture new records.

11.7 Dead Time and Run Statistics

11.7.1 Definitions

Dead time in the Pixie-Net data acquisition can occur at several processing stages. For the purpose of this document, we distinguish three types of dead time (described below), each with a number of contributions from different processes.

Please note: There is a conceptual difference between momentary dead time (associated with a pulse) and cumulative dead time (sum of dead time contributions during an acquisition). Their relation is not trivial.

Live time is often used to describe the portion of the overall time during which the system was not dead. However, since dead time can occur on several levels, this term is prone to misunderstandings and not used here.

11.7.1.1 Dead time associated with each pulse

1. Filter dead time

At the most fundamental level, the energy filter implemented in the FPGA requires a certain amount of pulse waveform (the “filter time”) to measure the energy. Once a rising edge of a pulse is detected at time T0, the FPGA computes three filter sums using the waveform data from T- (a energy filter rise time before T0) to T1 (a flat top time plus filter rise time after T0), see section 11.4 and figure 11-7. If a second pulse occurs during this time, the energy measurement will be incorrect. Therefore, processing in the FPGA includes pileup rejection which enforces a minimum distance between pulses and validates

a pulse for recording only if no more than one pulse occurred from T0 to T1. Consequently, each pulse creates a dead time $T_d = (T1 - T0)$ equal to the filter time. This dead time, simply given by the time to measure the pulse height, is unavoidable unless pulse height measurements are allowed to overlap (which would produce false results).

Assuming randomly occurring pulses, the effect of dead time on the output count rate is governed by Poisson statistics for paralyzable systems with pileup rejection⁵. This means the output count rate OCR (valid pulses) is a function of filter dead time T_d and input count rate ICR given by

$$OCR = ICR * \exp(-ICR * 2 * T_d), \quad (4)$$

which reaches a maximum $OCR_{max} = ICR_{max}/e$ at $ICR_{max} = 1/(2*T_d)$. Simply speaking, the factor 2 for T_d comes from the fact that not only is an event E2 invalid when it falls into the dead time of a previous event E1, but E1 is rejected as piled up as well. This filter dead time is accumulated in the SFDT counter in each processing channel.




Figure 11-7: Filter dead time. A pulse arriving at T0 will incur slow filter dead time (for energy measurement) until T1. At T1, the pileup status is latched – for a single pulse, it is logic low and the event is accepted. A second pulse arriving at T0' will extend the dead time and cause the pileup status to be logic high. Unless pileup rejection is disabled, both events are rejected.

2. Fast trigger dead time (FTDT)

A second type of dead time only affects the trigger filter. Triggers are issued when the trigger filter output goes above the trigger threshold set by the user. However, the trigger filter output will remain above threshold for a finite amount of time, depending on the length of the trigger filter and the rise time of the input signal. During this time, no second trigger can be issued⁶. Therefore triggers are not counted during this time, and when computing the input count rate, the time lost has to be taken into account. FTDT is thus purely a correction for the computation of the input count rate.

⁵ G. Knoll, Radiation and Measurement, J Wiley & Sons, Inc, 2000, chapters 4 and 17.

⁶ The MAXWIDTH parameter, re-introduced in release 2.30, can be used to define a maximum acceptable time over threshold and thus to reject events piled up “on the rising edge”.




Figure 11-8: Fast Trigger Dead Time (FTDT). A second pulse is not detected if the trigger filter output is still above threshold.

3. Other

In the Pixie-Net, up to 500 events (and/or total 8Ki waveform samples) are buffered in the FPGA. Thus new events are accepted while captured ones are read out and processed further. If the buffers fill up, the channel pauses acquisition and stops the count time counter.

11.7.1.2 Dead time associated with external conditions

There are three dead time effects that originate from outside the trigger/filter FPGA. The first two have the effect of stopping the Pixie-4 Express count time counter, the last is counted separately.




Figure 11-9: The count time counter is stopped when the signal is out of range and when events are rejected because of a processing backlog (e.g. local buffer memory full or file write process busy). SFDT and FTDT are only counted when the count time is on. The gate dead time is counted in a separate counter, but also only when the count time is on. Run time and total time are always on unless the run is stopped (see below).

1. Signal out of range

When detector gains or offsets drift, or an unusual large pulse is generated in the detector, the analog input of the ADC may go out of range. In this condition, the FPGA can not accumulate meaningful filter sums and thus is considered dead. This condition persists during the actual out-of-range time and several filter times afterwards until the bad ADC samples are purged from filter memory. The count time counter is stopped during the out-of-range condition because no triggers can be issued and no pulses are counted.

2. On-board pulse processing limit

The on-board pulse processing by the ARM processor computes the pulse height (energy) from raw energy filter sums, which is then stored in list mode memory and/or binned into spectrum memory. In the Pixie-Net, the computation itself takes only a few cycles, but there is significant readout and other overhead. In List mode with nonzero waveforms, the limit is strongly dependent on the length of the captured waveform. Bursts of pulses may still exceed the processing rate momentarily, fill the buffers, and so prevent the channel from acquiring more data. Thus the count time counter is stopped during such buffer full (processing overload) conditions.

3. Gate or Veto

If an external signal prohibits acquisition using the *Gate* or *Veto* signals, the channel is also dead (disabled on purpose). The appropriate way to count *Gate* or *Veto* dead time may depend on the experiment. The Pixie-Net counts both gate time and number of gate pulses. Please contact XIA for details.

11.7.2 Count time and dead time counters

The Pixie-Net firmware has been optimized to reduce the dead time as much as possible, and a number of counters measure the remaining dead times as well as the number of counts to provide information for dead time correction. The result of these counters is stored in the following output variables:

TOTAL TIME

The TOTAL TIME is an attempt to measure the real laboratory time during which the Pixie module was requested to take data. It essentially counts the time from the command to start a data acquisition to the command to end it. The TOTAL TIME includes the time spent for run start initialization and host readout. However, since it is based on the Zynq internal clock and only updated periodically, it may not be as precise as a “laboratory wall clock” over long time spans.

RUN TIME

The RUN TIME variable tracks the time during which the Pixie-Net was “switched on” for data acquisition. It’s currently identical to the TOTAL TIME

COUNT TIME

The COUNT TIME is counted in the FPGA independently for each channel and measures the time the channel is ready for acquisition. The COUNT TIME counter starts when the ARM processor finished all setup routines at the beginning of a run, omits the times the ADC signal is out of range, each channel’s local 500-event buffer is full, and ends when the ARM encounters an end run condition. Internally, the “counter on” signal is called LCE. It is thus the time during which triggers are counted and can cause recording (or pile up) of data, the best available measurement of the time the channel was active. The difference between COUNT TIME and TOTAL TIME can be used to determine how long

the local 500-event buffers were full and waiting for readout or other events prevented the channel from data taking (e.g. out of range).

FTDT (fast trigger dead time)

The fast trigger dead time counts the time the trigger filter is unable to issue triggers because the trigger filter output is already above threshold (and can not recognize a second pulse). It does not include the time triggers have been “paused” for a short time after a first trigger (an advanced user option to suppress double triggering), because the concept is that all triggers occurring during the pause are counted as only one trigger. When computing the input count rate, one should divide the number of triggers counted (FASTPEAKS) by the difference (COUNT TIME – FTDT) since triggers are not counted during FTDT.

SFDT (slow filter dead time)

The slow filter dead time counts the time new triggers will not lead to the recording of new data. This is the time the pileup inspection is taking place and the summation of energy filter sums is in progress (section 11.7.1.1). In case pileup inspection is inverted or disabled, there is no contribution to SFDT.

GDT (*GATE* dead time)

The dead time from *Veto* /GFLT is counted separately from SFDT for each channel. As mentioned above, the use of these signals may depend on the application.

In the current firmware, the time during which GDT is counted depends on several user options on signal source and polarity. The source options result in a signal GCE to be counted, the polarity selects whether to count while GCE is high or low, as listed in the following table.

Use Veto	Gate Mode	GCE	Count @ Fall	GDT incremented
0	0	(<i>Veto</i> OR <i>Gate</i> *) AND LCE	0	GCE high
1	0	<i>Gate</i> * AND LCE	0	GCE high
0	1	(<i>Veto</i> OR <i>Gate</i> *)	0	GCE high
1	1	<i>Gate</i> *	0	GCE high
0	0	(<i>Veto</i> OR <i>Gate</i> *) AND LCE	1	GCE low
1	0	<i>Gate</i> * AND LCE	1	GCE low
0	1	(<i>Veto</i> OR <i>Gate</i> *)	1	GCE low
1	1	<i>Gate</i> *	1	GCE low

* possibly shaped and delayed

For the case that the *Veto* input is used for a GFLT-type validation pulse, it may be more useful to work with the number of pulses issued. They can be counted by using the *Veto* input as the source for GATE PULSEs, which are counted in the variable GCOUNT.

11.7.3 Count Rates

Besides the count time and dead times, the Pixie-Net counts the numbers of triggers in each channel, NTRIG, the number of valid single channel events, NUMEVENTS, and the number of valid pulses stored for each channel, NOUT. To accommodate dead time correction for pileup even in cases where events are not recorded for other reasons (e.g. not matching coincidence or veto requirements), a counter NPPI counts the number of locally triggered events passing pileup inspection. In addition, it counts the number of gate pulses for each channel, GCOUNT. FASTPEAKS and GCOUNT are inhibited when the COUNT TIME counter is not incrementing. NUMEVENTS and NOUT by nature only count events captured when the COUNT TIME counter is incrementing.

Count rates are then computed as follows:

Input count rate	ICR	= NTRIG / (COUNT TIME – FTDT)
Event rate	ER	= NUMEVENTS / RUN TIME
Channel output count rate	OCR	= NOUT / COUNT TIME
Channel Pass Pileup Rate	PPR	= NPPI / COUNT TIME
Gate count rate	GCR	= GCOUNT / COUNT TIME

Users are free to use the reported values to compute rates and time better matching their preferred definitions.

Notes:

- Output pulse counters are updated whenever an event has been processed; input, gate and all time counters are updated every ~7ms. Therefore reading rates at random times, e.g. clicking *Update* in the Pixie Viewer, might return slight inconsistencies between input rates and output rates. At the end of the run, all rates are updated and these effects should disappear.
- NOUT is counted for each event a channel is processed no matter if the channel had a valid hit or not. Thus a channel that is processed in “group trigger” mode may have an output count rate even though its input count rate is zero.
- Since COUNT TIME counters are paused local 500-event buffers are full, the input and output count rates should be considered as “rates while active” as opposed to actual rates per elapsed lab time. For input count rates, this is the more intuitive case, since the detector will not stop generating pulses when the channel becomes inactive due to a full buffer and the input count rate should closely correspond to the detector’s rate. For output count rates, it is a matter of perspective – should it mean the total number of counts per acquisition lab time or the number of counts processed while the Pixie module is taking date? The former would produce unreasonably low count rates when e.g. the signal goes out of range periodically, since it will not account for the duty cycle of the signal source. The latter would produce unreasonably high rates if the system is near its processing limit and often paused full buffers, though it will better reflect the pileup rejection statistics. The choices made in the current firmware select the latter case, but by multiplying the output count rate with COUNT TIME / TOTAL TIME, the former can be recovered.

11.7.4 Dead time correction in the Pixie-Net

Historically, dead time correction in analog systems relied on the system dead time measurements taken directly from the acquisition system and the recorded output count rate. For example, a peak sensing ADC module might output a “dead time” signal during the several microseconds it would require to capture the peak value. Thus reconstruction of true count rate required the knowledge of dead times associated with various stages of acquisition and the subsequent mathematical modeling to tie this quantity to the input rate. The classic paralyzable and non-paralyzable models of pulse acquisition do exactly that. For example, the dead time from a non-paralyzable ADC conversion process simply “takes away” active counting time (T_d for each output count) and so one can use the classical model of $OCR = ICR / (1 + T_d * ICR)$, derive⁷ $OCR/ICR = (real\ time - dead\ time) / (real\ time)$, and solve for ICR as a function of measured OCR, real time and dead time.

⁷ $OCR(1+T_d*ICR) = ICR$ can be written as $OCR = ICR(1-OCR*Td)$. The measured cumulative dead time DT is $DT = OCR*Td*RT$. Therefore $OCR/ICR = RT-DT/RT$.

In the Pixie-Net, the input count rate is measured directly with the trigger filter, and so the system dead time bears only theoretical or diagnostic value. For any measurements where accurate determination of true (source) counts are required (activity measurements), the empirical ratio ICR/OCR is the only really unbiased quantity for dead time correction. No matter what the actual dead time the acquisition process incurs on the system, the ICR/OCR ratio applied to any region of interest in the energy spectrum correctly reconstructs the true counts in this region, assuming a random source so that pulses are lost with equal probability in each region or in time. **For cases where events are added by group trigger or removed by coincidence or veto requirements, PPR should be used instead of OCR.**

In the Pixie-Net firmware design, the counter SFDT attempts to independently account for the system dead time. SFDT counts the time during which the pileup rejection will reject this and any subsequent pulse that are too close in time. Essentially it measures – cumulative for all pulses – the time from the first trigger until a new trigger is again allowed, extended by any trigger during the interval. This is a paralyzable dead time with pileup rejection, closely matching the classical model. SFDT correctly measures the *time* during which pulses are not recorded, but unless simplified to the assumptions in the classical model, it is not trivial to compute from that the *number* of pulses lost. The detailed mathematical treatment is beyond the scope of this writing.

Please also see a related application note: XIA Pixie-4e Dead Time Correction

11.8 Other Functions

11.8.1 Capturing triggered, averaged ADC waveforms

The Pixie-Net can capture ADC data in two ways:

1. Raw, untriggered samples just as captured from the ADC. This is implemented in the function `gettraces` that effectively samples at ~200ns intervals.
2. Triggered ADC waveforms sampled at user specified sampling intervals. The recorded values are averaged over the interval. This is implemented in the function `avgadc`.

The `avgadc` function requires the parameter `ADC_AVG` in the ini file to be set to the number of samples to average (2 – 65534) and the parameter `THRESH_ADC_AVG` to be set to the trigger level (0-4095). The data capture is initiated by arming the capture logic by a write to register `COUNTER_CLR` (0x009). Successful capture of data is indicated in register `ADCTRIG` (0x108). Data can then be read out from the channels' `ADCAVG` register (0x1NE).

In the FPGA, the data is captured in an 18-bit, 4K FIFO memory. Depending on the number of samples to average, the average is down shifted to avoid overflows. The function `avgadc` adjusts for these shifts so that the data recorded is scaled equivalent to a single ADC sample. The pre-trigger delay is fixed at 500 samples.

Users can write shell scripts to capture multiple waveforms, or modify the function `avgadc` to execute the acquisition repeatedly and/or write to different files and in different formats. The number of samples to read (4Ki) is defined as a C constant, however unlike in the function `gettraces` this constant must not be changed in C since it is tied to the actual length of the buffer in FPGA memory. The pretrigger delay of 500 samples is hardcoded in the firmware, please contact XIA if this needs to be made more flexible.

12 Hardware and Firmware Variants

This sections describe hardware and firmware variants of the Pixie-Net. Typically, they are purchased separately as a licensed add-on to the standard hardware, firmware, and software. Please contact XIA for details.

12.1 Pulse Shape Analysis and Constant Fraction Timing

A variety of radiation detectors have the ability to discern between different types of radiation, such as neutrons and gamma rays, by creating different pulse shapes for different types of interactions. In addition, phoswich detectors, consisting of multiple layers of different scintillators, produce different pulse shapes depending on which layer absorbs the radiation. A suitable pulse shape analysis (PSA) can detect such differences, which then can be used for particle identification. The Pixie-Net firmware includes such PSA functions (enabled for specifically licensed units).

12.1.1 Overview




Figure 12-1: The PSA quantities and input parameters

The approach used by the Pixie-Net is a digital version of the Charge Comparison Method, where two sums over characteristic regions of the pulse are accumulated and a suitable ratio expresses the difference in pulse shape. This is an established method used in a variety of applications, well suited for online processing due to its simplicity. In this case, the functions compute baseline average sum B , amplitude A , and two sums $QDC0$ and $QDC1$ over characteristic areas of the pulse, as shown in Fig.1. The first 8 samples of the waveform are summed and normalized to obtain B . The maximum sample M in the waveform is located, then subtracted by B to obtain A . Four input parameters ($L0$, $L1$, $S0$, $S1$), specified prior to the data acquisition, define the length and delay of the sums $QDC0$ and $QDC1$ relative to the trigger T , as shown in Fig. 1. The sums $QDC0$ and $QDC1$ are baseline subtracted by B (scaled according to $L0$ and $L1$, respectively). Another return

value, or PSA ratio $R = QDC1/QDC0$ is computed as the final result to differentiate pulse types. (Other ratios or combinations can be implemented on request). These data, plus the timestamp *TrigTime* and overall pulse height E computed with a trapezoidal filter, are written into the list mode data stream, followed by optional storage of the full waveform for each event.

An additional function of the PSA firmware is to compute a constant fraction timing value for the rising edge. This is illustrated in Figure 12-2. Having found the maximum of the pulse, the firmware logic computes the CFD level as 50% of the amplitude, and finds the two closest points to that level, *cfdlow* and *cfdhight*. The CFD time of arrival x is then computed by the DSP through interpolation between *cfdhight* and *cfdlow*:

$$x / 1 = (\text{cfdhight} - \text{cfdlow}) / (\text{CFD level} - \text{cfdlow})$$

In the Pixie-Net, time stamps are latched by local or distributed triggers issued at the rising edge of a pulse. To accommodate delayed pulses in coincidence systems, the *CFD time* is captured at the end of the user specified coincidence window (1/2 of the “COINCIDENCE_WINDOW” specified in the settings file). The reported *CFD time* value is the time from the interpolated CFD level crossing to the end of the coincidence window. Therefore one can compute [in units of 1ns sampling intervals] the fractional (subsampling) time of arrival x from *cfdlow*

$$x = 1 - \text{frac}((\text{CFD time})/256)$$

and the absolute time of the CFD crossing is

$$\text{CFD crossing} = \text{TrigTime} - (\text{CFD time})/256 + \frac{1}{2} \text{ window width}$$

For example, for a user specified coincidence window 400ns, the Pixie module may report an event with a *TrigTime* of 1234 and a *CFD time* of 12832. Then one can compute

$$x = 1 - \text{frac}(50.125) = 0.875 \quad (\text{or } 0.875\text{ns})$$

and

$$\begin{aligned} \text{CFD crossing} &= 1234 [\text{x } 1\text{ns}] - (12832/256) [\text{x } 1\text{ns}] + \frac{1}{2} \times 400\text{ns} \\ &= 1484.125 \text{ ns after last reset of the time stamp counter} \end{aligned}$$




Figure 12-2: CFD timing definitions

Restrictions for the CFD:

- The CFD level is fixed to 50%
- The rising edge, from 50% level to maximum, must be less than 12 samples (48ns)
- If more than one pulse occurs within the coincidence window, results are invalid
- To measure time-of-arrival differences between channels, all channels must be in group trigger mode so data is captured on the same trigger.
- As *CFD time* has a maximum value of 512 ns, the coincidence window width must be less than 1024ns
- As the value is captured at the end of the coincidence window, the coincidence window width must be at least 2 times the pulse rise time. This ensures that the maximum is included in the CFD analysis.

12.1.2 PSA Input Parameters

PSA input parameters are specified in the settings file. For each channel, the parameter QDC0_LENGTH corresponds to L0, QDC1_LENGTH corresponds to L1, QDC0_DELAY corresponds to S0, and QDC1_DELAY corresponds to S1. In addition, the Boolean QDC_DIV8 can be set to 1 for long sums, where the result of QDC0 or QDC1 may overflow its 16-bit output variable. The parameter PSA_TESHOLD is used to detect the rising edge of a pulse. The threshold applies to both sums and is also used for the CFD maximum detection.

The sum lengths and delays can be set individually, with the following limitations:

- QDC1 must finish last (i.e. S1+L1 > S0+L0)
- L0, L1 must be between 2 and 60, and a multiple of 2
- L0+S0, L1+S1 must be between 0 and 250
- The difference of S0 and S1 must be a multiple of 2 (e.g S0 = 1, S1 = 17)

Two additional input parameters are used by the ARM C code, which accumulates a 2D histogram of the PSA data. This histogram plots PSA value R vs energy E. both R and E are 16 bit numbers which can range from 0 to 65536. The histogram has 100 bins⁸ in each direction. Therefore R and E must be divided by a scaling factor to map the value to a bin. These factors are

- MCA2D_SCALEX, i.e. bin x = E / MCA2D_SCALEX
- MCA2D_SCALEY, i.e. bin y = R / MCA2D_SCALEY

To see the full range, MCA2D_SCALEX/Y should be 655. In practice, a smaller value is often useful to “zoom in” to a particular range.

12.1.3 PSA Return Values

The ARM processor writes the PSA return values to the list mode data stream. The PSA values are placed into words 10-15 of the channel header in run type 0x400 as described above. Table 11-1 lists the mapping of the values to the channel header locations. To accommodate fractions for the ratio R, the number recorded in the file is 1000*R. To

⁸ The 2D histogram can be recreated offline from list mode data with arbitrary number of bins. 100 was chosen for online binning to keep processor load and website rendering speed within reason. The number is a compile parameter and can be modified by experienced users if necessary.

accommodate fractional samples for the CFD time, the number recorded in the file is 256* CFD time (1 LSB = 3.91ps). Divide the reported value by 256 to match units with the Trigger time (1ns).

For text output in Run Type 0x500 and 0x502, see sections 7.1.1 and 7.1.3

Word #	Variable	Description
0	EvtPattern	Hit pattern.
1	EvtInfo	Event status flags.
2	NumTraceBlks	Number of blocks of Trace data to follow the header
3	NumTraceBlksPrev	Number of blocks of Trace data in previous record (for parsing back)
4	TrigTimeLO	Trigger time, low word
5	TrigTimeMI	Trigger time, middle word
6	TrigTimeHI	Trigger time, high word
7	TrigTimeX	Trigger time, extra 8 bits
8	Energy	Pulse Height
9	ChanNo	Channel number
10	PSA Values	Amplitude A
11	PSA Values	CFD time *4*256 (divide by 256 for dt in ns)
12	PSA Values	Base B
13	PSA Values	QDC0
14	PSA Values	QDC1
15	PSA Values	Ratio R *1000
16--32	reserved	

Table 11-1: Channel header data format for PSA data acquisition in Run Type 0x400.

12.1.4 Reduced General Purpose Functionality

Due to resource limitations in the PL, the following output parameters are not computed in the PSA variant of the firmware:

- No gate pulse count in the event record
- No GDT counters in the channel run statistics
- No NPPI or PPR counters in the channel run statistics
- No SFDT counters in the channel run statistics
- No GCOUNT or GATE_RATE counters in the channel run statistics
- No CSFDT and CCT counters in the module run statistics

and the following functions are simplified or removed

- No delay and window for external gates
- No offboard serial I/O
- No coincidence mode acquisition (0x503, 0x402) with PSA and vice versa

These parameters and functions can be reinstated as necessary if other trade-offs are made.

12.2 IEEE 1588 Precision Timing Protocol

While traditionally detector data acquisition electronics use dedicated clock and trigger connections to synchronize multiple units, the Pixie-Net has the option to instead use the IEEE 1588 Precision Timing Protocol (PTP) to synchronize modules. Each Pixie-Net operates from its local clock, but clock frequencies and timestamps are adjusted by software that uses special PTP messages exchanged through the data network. With suitable network configurations, this can achieve sub-nanosecond precision.

12.2.1 Overview

The Zynq SoC used as the Pixie-Net's processor has a number of PTP functions built into its standard Ethernet controller. With suitable Linux kernel options and PTP stack software (see below), the Zynq PTP clock can be synchronized to other PTP nodes in the network with a precision of ~ 1500 ns. However, as there are no useful connections between the Zynq PTP clock controller and FPGA fabric, this is of limited use for the detector pulse processing.




Figure 12-3: Block diagram of the clocking of the Pixie-Net (Revision B), with PTP features shown in red. The output from the clock PLL is only available in the PTP variant, but the connector can be used as a clock input in any variant.

Therefore, a special PTP variant of the Pixie-Net Revision B hardware implements the following alternate PTP functions:

- Redirect Ethernet data to a secondary Ethernet PHY.
- Perform PTP time stamping in the secondary Ethernet PHY.
- Generate a programmable PTP clock that can be used to clock the FPGA pulse processing, the ADCs, and external devices.
- Generate programmable PTP triggers for internal and external use, e.g. a pulse per second signal or an enable signal that allows data acquisition to begin at a specific time.
- Connect PTP PHY to CAT-5 cable through the GPIO connector (with adapters).

These hardware features require a number of (open source) control software for operation, as described in the following sections. Timing resolutions between 300 ns and 200 ps have been achieved with this technique, depending strongly on the network capabilities.

12.2.2 PTP Stack Software: LinuxPTP

The PTP stack software manages the clock adjustments based on PTP messages exchanged between the PTP nodes. The PTP PHY is supported by the open source software LinuxPTP⁹, which is installed in the Pixie-Net's Ubuntu 15 operating system. To work with the PTP PHY, LinuxPTP needs specific kernel drivers and firmware, which is part of the boot files provided for the PTP variant. (The standard boot files will let LinuxPTP communicate only with the built-in Zynq PTP functions).

To start LinuxPTP in the foreground with status messages, type

```
ptp4l -i eth0 -m -q
```

in the Pixie-Net terminal session. If another PTP node is present in the network, the Pixie-Net will try to link with it. The master clock node is determined automatically; for a defined setup we recommend start ptp4l in one Pixie-Net as shown above and wait until it assigns itself as the clock master, then start ptp4l in the second/third Pixie-Net with the added **-s** option to force it to clock slave mode.

It is often more convenient to start LinuxPTP as a service, or a background task and the Pixie-Net data acquisition as a foreground task. Please see the LinuxPTP documentation for the various options. As long as LinuxPTP is running, the clock generated by the PTP PHY is synchronized to the network's PTP master. The Linux system clock can be additionally synchronized to the PTP clock with a second LinuxPTP utility, phx2sys.

12.2.3 PTP PHY Control Software: ptp-mii-tool

The secondary Ethernet PHY with PTP function has a number of registers that specify additional functions, such as the frequency of the generated PTP clock and the timing of GPO triggers. To program these registers, XIA adapted the *mii-tool* Linux utility to specifically communicate with the PTP PHY. The adapted program, *ptp-mii-tool*, is invoked by typing:

- `ptp-mii-tool` print basic status information, including PTP time
- `ptp-mii-tool -v` print more status information
- `ptp-mii-tool -v -v` print even more status information
- `ptp-mii-tool -s` toggle on/off synchronous Ethernet mode (PTP clock derived from upstream Ethernet device)
- `ptp-mii-tool -p` turn on the pulse per second (PPS) signal on the Pixie-Net's PPS output 3 seconds from “now”
- `ptp-mii-tool -t` print current PTP and system time
- `ptp-mii-tool --enable=TON --duration=DUR` create PTP triggers at PTP time TON and TON+DUR which are used by the Pixie-Net to enable data acquisition starting at TON and ending at TON+DUR. The Pixie-Net time stamp counter is reset to 0 at TON.

⁹ <http://linuxptp.sourceforge.net/>

The functions provided by *ptp-mii-tool* are useful but optional for the PTP synchronization and data acquisition process, and more functions will be added as necessary.

12.2.4 PTP Clock PLL Control Software: *clockprog*

By default, the Pixie-Net's input clock PLL buffers the PTP clock generated by the PTP PHY (25 MHz) for the FPGA and optionally also for the "CLK" output on the Pixie-Net rear panel. However, this chip is very flexible and can be programmed to divide or multiply the input clock frequencies to generate frequencies other than 25 MHz for the "CLK" output. Such changes can be applied with the *clockprog* utility. A few standard modes are hardcoded in the program; expert users can modify the register settings with the help of the PLL's data sheet (CDCD813-Q1) and TI's ClockPro utility. The program is invoked by typing

```
./clockprog m
```

where m stands for one of the following mode numbers:

Mode	clockprog function
0	Report the register values
1	Program the current register values into the PLL's EEPROM to make them the new power-up defaults.
2 (default)	Enable the clock output for the FPGA (25 MHz), assuming a 25 MHz input signal from the PTP PHY.
3	Enable the clock output for the FPGA (25 MHz) and the rear panel connector (25 MHz), assuming a 25 MHz input signal from the PTP PHY.

The clock PLL can also be used to clock the FPGA from an external clock source. This is not accomplished by programming, but by setting internal jumpers to use the rear panel CLK connector as an input to the PLL (instead of the PTP PHY). This option is available even for standard Rev. B hardware. We recommend a 2.5V, 25 MHz clock signal; otherwise the PLL has to be programmed to work with the alternate input clock frequency.

The functions provided by *clockprog* are optional for the PTP synchronization and data acquisition process, and more modes will be added as necessary. A possible cause of missing Ethernet connection or lack of ADC data is a wrong or missing clock from the PLL; in case of problems try execution of

```
./clockprog 2
./ifconfig eth1 up
```

and if the Ethernet connection is successfully restored, execute *./clockprog 1* to write the working PLL configuration to PROM for the next powerup cycle.

12.2.5 PTP parameter settings

The following parameters are important for PTP data acquisitions:

- AUX_CTRL bit 3
If bit 3 is set, the Pixie-Net data acquisition is enabled by a first PTP trigger and disabled again when a second PTP trigger is received. This is similar to applying an external VETO signal to the Pixie-Net, except that the PTP triggers are generated at

user specified date/time as programmed by the *ptp-mi-tool* utility. If bit 3 is set, the first PTP trigger also clears the Pixie-Net's time stamp counter, thus correlating the user specified trigger time (a UTC related date/time) with list mode data time stamps.

For non-PTP operation, the bit has to be set to zero, else data acquisition will wait (forever) for the PTP triggers to enable data taking.

12.2.6 Linux Shell Scripts for PTP operation

A number of Linux shell scripts have been written by XIA to make the PTP-synchronized operation of multiple Pixie-Net modules easier to use. The scripts are currently written to run on a Linux host PC connected via the network to 3 Pixie-Net units, but can be easily modified by interested users.

It is recommended to ensure settings and connections are correct by executing single-unit data acquisition with terminal login, i.e. before executing the *ptpdaq* script, log in and execute *./acquire* to make sure data files are created correctly.

All scripts rely on ssh communication between the various Linux systems. To avoid being prompted for passwords at every step, it is recommended to set up public key login¹⁰. For example, to set up a key on a Pixie-Net at 192.168.1.71, execute the following on the Linux host PC running the scripts:

```
ssh-keygen -t rsa                                // create a key
ssh-copy-id -o ControlPath=none root@192.168.1.71    // copy key to Pixie-Net
ssh-add                                         // this is a bug fix of some sort
```

Say yes to defaults and/or type <enter> to all prompts. Enter the Pixie-Net password when requested. Usually there is no need to specify a password for the key (just hit <enter>).

1. ***ptpsetup_3x.sh***

The setup script has the following key steps after defining the Pixie-Nets' IP numbers in variable IP1-3:

a) Execute the standard initial Linux commands to apply settings and find offsets. In addition, program the PTP clock PLL to generate a 25 MHz output to the Zynq processor:

```
ssh root@$IP1 'cd /var/www; ./clockprog 2; ./progfippi; ./findsettings'
ssh root@$IP2 'cd /var/www; ./clockprog 2; ./progfippi; ./findsettings'
ssh root@$IP3 'cd /var/www; ./clockprog 2; ./progfippi; ./findsettings'
```

b) kill any previous instances of LinuxPTP:

```
ssh root@$IP1 'pkill ptp41'
ssh root@$IP2 'pkill ptp41'
ssh root@$IP3 'pkill ptp41'
```

c) Start LinuxPTP in the background as the clock master in Pixie-Net 1, and as clock slaves in Pixie-Net 2 and 3:

```
ssh root@$IP1 "sh -c 'nohup ptp41 -i eth2 > /dev/null 2>&1 &'"
ssh root@$IP2 "sh -c 'nohup ptp41 -i eth2 -s > /dev/null 2>&1 &'"
ssh root@$IP3 "sh -c 'nohup ptp41 -i eth2 -s > /dev/null 2>&1 &'"
```

2. ***ptpdaq_3x.sh sss***

The acquisition script has the following key steps after defining the Pixie-Nets' IP

¹⁰ <https://help.ubuntu.com/community/SSH/OpenSSH/Keys>

numbers in variable IP1-3:

- a) prompt for requested run time (DUR), and update the settings files on the Pixie-Nets. Additional 10s are added to accommodate overheads.

```
echo "PTP enabled run time in s?"
read DUR
RRT=$((DUR + 10))
CMD="sed -i '/REQ_RUNTIME/c REQ_RUNTIME $RRT ' /var/www/settings.ini"
ssh root@$IP1 "$CMD"
ssh root@$IP2 "$CMD"
ssh root@$IP3 "$CMD"
```

- b) get the current PTP and System time from Pixie-Net 1. Compute the start time of the acquisition (TON) in PTP time units as EXTRATIME seconds from current PTP time (empirically EXTRATIME is set to 8s to accommodate overheads).

```
TIME1=`ssh root@$IP1 '/var/www/ptp-mii-tool/ptp-mii-tool -t'`
PTPTIME=$(echo $TIME1 | cut -c 21-32)
TON=`expr "$PTPTIME" + "$EXTRATIME" `
```

- c) set up the PTP triggers for time TON and TON+DUR on all Pixie-Nets

```
CMD="/var/www/ptp-mii-tool/ptp-mii-tool --enable=$TON --duration=$DUR"
ssh root@$IP1 "$CMD"
ssh root@$IP2 "$CMD"
ssh root@$IP3 "$CMD"
```

- d) Start the acquire function in the background on all Pixie-Nets. The script will then end, but each Pixie-Net will continue the acquisition for DUR+10s. The PTP triggers will create a time window of DUR during which the acquisition is enabled, synchronous in all Pixie-Nets.

```
ssh root@$IP1 "sh -c 'cd /var/www; nohup ./acquire > daq.log 2>&1 < /dev/null &'"
ssh root@$IP2 "sh -c 'cd /var/www; nohup ./acquire > daq.log 2>&1 < /dev/null &'"
ssh root@$IP3 "sh -c 'cd /var/www; nohup ./acquire > daq.log 2>&1 < /dev/null &'"
```

3. ptpcollect_3x.sh

The data file collection script, after defining the Pixie-Nets' IP numbers in variable IP1-3, copies MCA.csv, RS.csv, LMdata.b00 from each Pixie-Net to the host PC:

```
scp root@$IP1:/var/www/LMdata.b00 LMData_$IP1.b00
scp root@$IP1:/var/www/RS.csv RS_$IP1.csv
scp root@$IP1:/var/www/MCA.csv MCA_$IP1.csv
```

and equivalent for Pixie-Net 2 and 3

4. ptphalt_3x.sh

The shutdown script, after defining the Pixie-Nets' IP numbers in variable IP1-3, issues the halt command to all modules. This should be done before turning off power.

```
ssh root@$IP1 'halt'
ssh root@$IP2 'halt'
ssh root@$IP3 'halt'
```

12.2.7 List Mode Data Analysis

Each Pixie-Net records its data into a local file LMdata.xxx. The time stamps in different files are synchronized to a common starting time (all time stamp counters are reset to zero at the first PTP trigger), and increment at the same rate (clock frequencies are synchronized via the PTP mechanism). The precision of this synchronization depends on the network infrastructure. In the setup described above, with one Pixie-Net being the PTP clock master and communicating with the others through a standard Ethernet network, we observed relative time stamp uncertainties of about 300 ns. In a network where all nodes conform to

the PTP standard, uncertainties can be as low as 10ns, or even sub-nanosecond when synchronous Ethernet is used.

The data from the different list mode files can be assembled into a common file (or a spreadsheet), for example to extract coincidences across modules in offline processing¹¹. For real detector systems with random pulses, there will be events in one detector but not the other, and therefore in most cases only one channel of one Pixie-Net will record an event. While the events are ordered in increasing order *for each channel* in each file, the event records will not be a straightforward matched list; instead, time matching of the recorded events is required. For example, for each channel ch there are likely a random number of singles events NS(ch) between two coincident events captured in multiple channels at the same time. To match those coincidences in a spreadsheet, one would insert blank cells between the coincidences, based on time stamp differences, to bring the total cells between the coincidences to sum(NS(ch)). This is illustrated in the table below. No function is provided at this time by XIA; this kind of data processing is application dependent and beyond the scope of this manual.

Event No. in file	Event time stamps, PN1, Ch.1	Event time stamps, PN2, Ch.2	Overall Event No.	Event time stamps, PN1, Ch.1	Event time stamps, PN2, Ch.2
1	5005	6004	1	5005	
2	8006	7003	2		6004
3	9006	12002	3		7003
4	12008	15007	4	8006	
5	18002	...	5	9006	
6	6	12008	12002
7	7		15007
8	8	18002	

Table 12-4: Illustration of data ordering in multiple list mode files. Coincident events (red) will usually not appear at the same event number in the files and not match exactly (e.g. due to cable delays). By looking at time stamp differences and inserting cells, coincidences can be matched.

(Only one channel shown per Pixie-Net for clarity)

Note: For high rates and/or long waveforms, the Pixie-Net acquire function may not keep up with incoming data. When buffers fill up, acquisition [in that module] is paused, leading to time periods with no data. Such gaps will occur randomly in different Pixie-Nets, leading to partially active systems.

12.2.8 Reduced General Purpose Functionality

Due to resource limitations in the Zynq, the following features are not available in the PTP variant of the hardware and firmware:

- Gigabit Ethernet
The secondary Ethernet PHY operates only at 10/100 Ethernet.

¹¹ XIA is working on a project to do that in real time during the acquisition, please inquire

12.3 ADC Variant with 14 Bit Precision

The recently introduced 14-bit, 250 MHz variant of the Pixie-Net for the most part operates identically to the 12-bit variant. Notable differences are

- The ADC range is 0-16382 steps, but still corresponds to 0-2V
- The default DC offset of 10% corresponds to a baseline of ~1600 instead of ~400.
- Energy filters operate on 4x larger sample values. Therefore a scaling factor of 0.25 was introduced in the energy computation of the DAQ routines. **Any customized version of these DAQ routines will have to match this change.**
- The out-of-range test uses the limit of 16383 for 14-bit, 4095 for 12-bit variants
- Trigger thresholds are NOT automatically adjusted for the 4x larger samples. A given trigger threshold will trigger on 4x smaller pulses in the 14-bit firmware than in the 12bit firmware. This best accommodates the increased precision of the 14bit ADC.
- Trigger thresholds for the averaged ADC trace capture are still limited to the range 0-4095, i.e. it can only trigger within the lower quarter of the ADC range.
- The hardware version is defined as 0xA9A1. The firmware (in the boot partition of the SD card) has to match the hardware variant. This can be verified in the run statistics; for example for generic FW release 2.30, FW version = 0xA9A10230.

13 Hardware Information

13.1 Jumpers

13.1.1 Revision A Modules

Pixie-Net Revision A has no internal jumpers

13.1.2 Revision B Modules

Pixie-Net Revision B has the following internal jumpers

- **JP400, JP401**

When a shunt is connecting pin 1 and pin 2 in each jumper (position “=”), the rear panel PMOD pinout is identical to the MicroZed PMOD

When a shunt is connecting both pin 1 and another shunt is connection both pin 2 (position “||”), the rear panel PMOD pinout has pins 2 and 3 swapped. This is useful for some UART PMOD devices, e.g. the Digilent GPS module.

- **JP600, JP601**

When a shunt is placed on JP600 (“PTP”), the output of the PTP PHY ptpclock signal is connected to the input of the clock PLL, which in turn generates clocks for the FPGA and/or the MMCX connector “CLK”.

When a shunt is placed on the on JP601 (“EXT”), the output of the clock PLL is connected to the MMCX connector “CLK”.

When a shunt connects the neighboring pins of JP600 and JP601, the MMCX connector “CLK” is connected to the input of the clock PLL, which in turn generates a clock for the FPGA

To access the internal jumpers first remove the screw at the bottom of the unit. Then remove the 4 hex screws on the front panel (with the analog inputs). Slide the board assembly out of the box and locate the jumpers at the bottom side of the (green) ADC board. Reverse steps for re-assembly.

13.2 HDMI GPIO Connector Pinout

The GPIO connector on the Pixie-Net rear panel is a micro HDMI connector. (It does not carry a video signal). In the standard hardware variant, the HDMI pins are buffered with input/output buffers to FPGA pins. In the PTP hardware variant, the differential pairs in the HDMI connector are connected to the PHY I/O and Ethernet differential pairs as listed below. There are two HW revisions with different pinout:

Rev B.1

PHY	HDMI	HDMI	CAT-5	CAT-5	CAT-5	CAT-5
	Signal	wire color	receptacle	plug	pin	color
NC	CLK+	blue/white: white	NC	NC	8	brown
NC	CLK-	blue/white: blue	NC	NC	7	brown/white
NC	Data1+	green/white: green	NC	NC	5	blue/white
NC	Data1-	green/white: white	NC	NC	4	blue
TD-	Data0-	brown/white: brown	TD-	RX+	1	orange/white

TD+	Dat0+	brown/white: white	TD+	RX-	2	orange
RD-	Data2-	red/white: red	RD-	TX+	3	green/white
RD+	Data2+	red/white: white	RD+	TX-	6	green

Rev B.3

PHY	HDMI	HDMI	CAT-5	CAT-5	CAT-5	CAT-5
		Signal	wire color	receptacle	plug	pin
NC	CLK+	blue/white: white	NC	NC	8	brown
NC	CLK-	blue/white: blue	NC	NC	7	brown/white
RD-	Data1+	green/white: green	RD-	TX+	3	green/white
RD+	Data1-	green/white: white	RD+	TX-	6	green
TD-	Data0-	brown/white: brown	TD-	RX+	1	orange/white
TD+	Dat0+	brown/white: white	TD+	RX-	2	orange
NC	Data2-	red/white: red	NC	NC	5	blue/white
NC	Data2+	red/white: white	NC	NC	4	blue

It is quite difficult to find or make a CAT-5 cable with micro HDMI connector, but one can make use of commercial Ethernet to HDMI extenders:

1. Plug a male micro HDMI to female HDMI adapter cable into the Pixie-Net's GPIO port
2. Plug the "MOTONG 30M HDMI To Dual Port RJ45 Network Cable Extender Over by Cat 5e / 6 1080p up to Extender Repeater for PS3 HDTV HDPC STB", ASIN B01AQO57VQ, item # LYSB01AQO57VQ-CMPTRACCS from Amazon into the adapter cable (1)
This is a passive, direct wire adapter. Do not use active drivers.
3. Make a custom CAT-5 cable with the pinout below on one end, standard on the other. Essentially the Orange+Orange/White and Green+Green/White pairs of the CAT-5 cable must be connected to the active TD +/- and RD +/- pins of the PHY via HDMI, which are pins 1+2 and 7+8 (or 4+5) of the Motong adapter

Pinout HW Revision B.1

1,	2,	3,	4,	5,	6,	7,	8
Orange, Orange/White ,	Brown/White,	Blue/White,	Blue,	Brown,	Green/White, Green		

Pinout HW Revision B.3

1,	2,	3,	4,	5,	6,	7,	8
Orange, Orange/White ,	Blue/White,	Green, Green/White ,	Blue,	Brown/White,	Brown		

4. Plug the custom end of the CAT-5 cable into port (2) of the MOTONG adapter.
5. Plug the standard end of the CAT-5 cable in a standard network outlet.

13.3 PMOD Connector



By default, all pins of the PMOD connector are general purpose pins (GPIO), programmable from the Linux environment. They can also be customized for specific functions like UART and I2C. The pin configuration is defined in the file “boot.bin” on the Pixie-Net’s SD card (boot partition visible in Windows). As “boot.bin” is a compiled binary, it can not simply be edited to change pin configuration, but it can be replaced with a different file (same filename) with different contents.

To date, there is one alternative pin configuration option, named “UARTI2C”. The pinout is as follows:

7 GPIO	8 I2C int.	9 SCL	10 SDA	11 GND	12 3.3V
1 GPIO	2 UART RX	3 UART TX	4 GPIO	5 GND	6 3.3V

Note that UART TX and RX can be swapped using internal jumpers JP400, 401.

To use the UART I/O from Linux, it is recommended to use minicom (installed) or an equivalent utility. A simple test is also e.g. executing `cp //var/www/LMdata.txt /dev/ttysP1` which sends the data of the file to the UART port and therefore toggles the TX line

To use the I2C I/O from Linux, a possible utility is “i2C-tools” (installed). It provides functions like `i2cset`, `i2cget`, `i2cdetect` (see more information in the Linux manuals). For example, `i2cdetect -l` will list the installed busses, which should be `i2c-0 i2c Cadence I2C at 30004000 I2C adapter`

To use GPIO from Linux, one can use the built-in sysfs interface. For example,


```
echo 906 > /sys/class/gpio/export
echo in > /sys/class/gpio/gpio906/direction
```

will enable GPIO #906 and make it an input. The mapping of sysfs pin numbers to PMOD pin numbers is

7 906	8 914	9 920	10 921	11 GND	12 3.3V
1 919	2 916	3 917	4 918	5 GND	6 3.3V

unless the pins are used by UART and I2C. For more information see also <https://xilinx-wiki.atlassian.net/wiki/spaces/A/pages/18842398/Linux+GPIO+Driver>.

14 Igor Pro GUI



14.1 Introduction and Setup

A graphical user interface based on Igor Pro is intended to simplify operation of the Pixie-Net and Pixie-Net XL. The GUI provides a panel with control buttons to execute API functions on the Linux OS, manages key parameter settings, and displays results.

The interface requires the following “installation” steps:

1. Install Igor Pro version 8 or higher on the user’s control PC (“the PC” thereafter).
2. Copy the Igor extension VDT2.xop (by Wavemetrics) from the “More Igor Extensions” folder to the “Igor Extensions” folder. Make sure to get the correct version for 32 vs 64 bit application.
3. Extract the zip file from XIA containing Igor experiment and procedure files into any folder on the PC.
4. (Optional) From that folder, copy udp_xop##.xop to the “Igor Extensions” folder if the UDP receiver functionality is to be used within Igor.

Open the GUI program by double clicking on Pixie.pxp. This will open the Igor application with the PIXIE-NET XL panel shown above. (If not, got to top menu **XIA** and select **Pixie-Net XL panel** or type F2).


The following assumes that the Pixie-Net (XL) is powered up, the autoboot routine executed successfully to configure FPGAs and parameters, and the IP address is known.

14.2 Operation via web API (Recommended)


The web API operation uses the center block of controls in the PIXIE-NET XL panel. Operation is largely equivalent to the ADCsetup and ADCcontrol webpages; the same web API function are called, only from Igor instead of from the browser. Note that the communication target is the folder `/var/www/webops`.



The interface currently supports up to 4 Pixie-Net devices. Click on [IP setup] to open a table to specify the IP addresses, user names and passwords. Then choose the number of units in use [Number of active units] and [Select the unit number] to communicate with.




Some operations, such as writing parameters or starting a DAQ can be applied to all units. These operations are marked with * but the checkbox [Apply to all units] must be checked. Furthermore, make sure to check [webops operation] unless operating in serial port mode and to uncheck [Pixie-Net XL] unless using a Pixie-Net XL. (Blue text indicates a control is only relevant for Pixie-Net XL, green text only for Pixie-Net.) When the [Print Messages] box is checked, the full server response and other information is printed in the Igor history window.



Clicking the [Read Settings] button reads a number of key parameters from the settings file (from `/var/www/webops/settings.ini`). The values are displayed in a table and in the fields below the button. Values can be edited in the table and fields, then written back to


the settings file by clicking [**Write Settings**]. This will change the settings file, but values are only applied to the pulse processing FPGAs after clicking [**Apply (progfippi)**].

A common settings change is to adjust the DC offsets of the input, which can be performed by clicking [**Adjust Offsets**]. The function is rather slow to execute. While it changes the offsets in the Pixie-Net, it does not change the settings file automatically (to avoid overwriting previous values with something worse). Instead, verify the offsets are ok by clicking [**Refresh Traces**] and opening the Oscilloscope panel (top menu **XIA > Oscilloscope XL** or F3). Then manually update the values in the parameter table with the values printed in the Igor history window, click [**Write Settings**] and [**Apply**].



For the Pixie-Net XL, additional status information can be obtained with the [**Poll CSR**] and [**Poll WR Time**] button. Details are described elsewhere.

Before powering down the Pixie-Net, it is strongly recommended to shut down the Linux OS. This is not executed directly from Igor (Security concerns in the web API) but the [**Shutdown Linux**] button opens a Windows command window with an ssh session for root, in which (after specifying the password) the system can be shut down by typing `halt`.




Data acquisition can be started with the DAQ buttons. For the top 4 buttons, the button text matches the API functions, please see descriptions in section 4. Note that these DAQ functions run for the specified RUN TIME, and Igor will wait for the DAQ to finish.

The lower 4 DAQ buttons correspond to the API functions `udpena` and `udpdis`. This simplified run mode starts a list mode only DAQ, where the Linux OS is not involved. The [**Enable LM only DAQ**] simply turns on the DAQ in the FPGAs, and [**Disable LM only**

DAQ] turns it off. No function is running on the Linux OS and therefore the web API function call returns immediately.

Since the list mode data is streamed out as UDP packages in this mode, a receiver program has to capture the UDP packets and write them to file. If the file “udp_xop##.xop” is correctly installed for Igor to use, the buttons [**Enable local UDP receiver**] and [**Disable local UDP receiver**] can be used to start and stop the receiver program within the xop. Otherwise, the standalone program `udp_receive.exe` can be manually started from a Windows command line (or on a different PC altogether).



During and after a DAQ, the files created on the Pixie-Net’s SD card can be read into Igor using the buttons in the results block. *Note: The IP address shown here is only valid if the webops option is not selected.* Clicking any of the [**Read ...**] buttons will retrieve the files `ADC.csv`, `MCA.csv`, or `RS.csv` from the Pixie-Net XL SD card and display them in the OSCILLOSCOPE, MCA SPECTRUM, or RUN STATISTICS TABLE, respectively. The [**Use local files instead**] option can be used to select the files manually in a file open dialog instead of reading from the remote SD card.

14.3 Operation via Serial Port

If the Pixie-Net is connected to the PC with the UART/USB serial port, the controls in the upper left SETUP and OPERATION blocks can be used instead of web API calls. The button text matches the API function name, please see descriptions in section 4. Essentially, clicking a button is equivalent to typing the button name into the terminal window.

To change parameters in the ini file (located in `/var/www`), specify the parameter name in the [**for ____**] control field, and the values for all channels in the [**to ____**] field.


As in the web API operation, files created on the Pixie-Net’s SD card can be read into Igor using the buttons in the results block. However, you must specify the [**IP address**] and files are from the folder `/var/www`.

14.4 Results

The Pixie-Net generates 4 data files, which can be viewed in dedicated plots and tables:

Data	File	Plot/Table
ADC traces	ADC.csv	OSCILLOSCOPE
MCA spectra	MCA.csv	MCA SPECTRUM
Run statistics	RS.csv	RUN STATS TABLE
List mode data	LMdata.bin/b00/dat/dt2	LIST MODE TRACES

14.4.1 Oscilloscope




ADC traces are displayed in the OSCILLOSCOPE. It shows 8 channels in a common plot. Checkboxes in the upper left can be used to show/hide a channel. To accommodate configurations with more than 8 channels, the physical channels can be assigned arbitrarily to display channels. Display channels are always numbered 0 (red) to 7 (cyan), but the control field net to the checkbox specifies the physical channel. Buttons above the checkboxes can be used to show/hide all, or add/subtract 8 for all display channels.

The control buttons duplicate the [Refresh] and [Adjust offset] buttons in the main PIXIE-NET XL panel, for web API (network or serial communication, respectively). Pulses in the display channels can be fitted to exponential decay, which can help to estimate the TAU parameter for the settings file. Further options allow to print the noise (std deviation) of each trace in the Igor history window, and to save the ADC data to a file.

14.4.2 MCA Spectrum

MCA spectra are displayed in the MCA SPECTRUM plot. Selection of the channels to display is identical to the OSCILLOSCOPE. Display channels can be fitted with a Gaussian to determine peak resolution. The [Read MCA] button duplicates the button in the PIXIE-NET XL panel.

14.4.4 List Mode Traces



The List Mode Traces plot can be used to view individual pulses from the list mode data files. The file can be selected in a dialog with the [Select] button; then the event number can be selected with the [Event Number] control. Detection of the run type is (usually) automatic.

The display, for traditional reasons, displays 4 channels. For systems with more than 4 physical channels, physical channels ≥ 4 are mapped into display channels 0-3. Display channel is physical channel modulo 4. The physical channel is shown in the [Ch. __] field. The panel also shows a number of data extracted from the event hit patterns and event info records; this is still only partially implemented.

14.5 Web API coding example

The source code for the Igor GUI is part of the GUI distribution. Simply open the procedure window “PixieNetXL.ipf” and view the code as an application example. Actual communication with the Pixie-Net is contained in the function “PixieNet_WebIO”. Buttons in the Pixie-Net XL panel are serviced by the function “PNXL_ButtonControl”.

While a number of Igor-specific functions are used to assemble and parse the strings for web communication, we believe equivalent functions exist in C, C++ or other programming environments, which should make porting the code relatively straightforward. Please contact XIA if you need support.