

Cadmium sulfide doped with silver as CO₂ gas sensor using pyrolysis technique

Uday Ali Sabeeh Al-Jarah¹, Haidar Jawad Mohamad², Yahya Mustafa Abdul-Hussein³

¹Department of Science, College of Basic Education, University of Misan, Misan, Iraq

²Department of Physics, College of Science, Mustansiriyah University, Baghdad, Iraq

³DIRECTORATE OF MATERIALS RESEARCH, MINISTRY OF SCIENCE AND TECHNOLOGY, BAGHDAD, IRAQ

Article Info

Article history:

Received Mar 17, 2022

Revised Jul 23, 2022

Accepted Aug 4, 2022

Keywords:

Atomic force microscope

CdS/Ag thin films

Chemical spray pyrolysis
technique

CO₂ gas sensor

X-ray diffraction

ABSTRACT

The monitoring of CO₂ in our life safety, industrial, and chemical laboratory applications make it an inspiring task. The chemical spray pyrolysis technique was used to prepare CdS/Ag thin films. The nanocrystalline cadmium sulfide thin films were doped with Silver at different doping concentrations (0%, 2%, and 4%). The morphologies, structures, and gas sensing properties of CdS/Ag films are presented. The samples were characterized using X-ray diffraction (XRD) and atomic force microscope (AFM). The XRD results show that the films are a polycrystalline composition and hexagonal type with a favoured orientation along (111) direction. The average grain size (nm) of AFM is between 75 and 55 nm. As a result, Ag doping changes the sensitivity of the samples respectively with the percentage of doping with time. The synthesis samples show controlling sensitivity and the small response of sensitivity are the key point in this study.

This is an open access article under the [CC BY-SA](#) license.



Corresponding Author:

Haidar Jawad Mohamad

Department of Physics, College of Science, Mustansiriyah University

Falastin St, Baghdad, Iraq

Email: haidar.mohamad@uomustansiriyah.edu.iq

1. INTRODUCTION

Cadmium sulfide (CdS) belong to the II-VI group and considered popular material for a variety of devices. It has an average bandgap of 2.42 eV. For a heterojunction solar cell, used as the appropriate material as a window material. It has a high absorption coefficient, good transfer efficiency, reliable, and inexpensive [1]. CdS considered as interesting material because it used at different applications for instance diode sensor [2], transistor [3], photosensor [4], photodetectors [5], photodiodes [6]. CdS have been deposited by chemical bath deposition (CBD) method [7], sol-gel [8], pulses laser deposition technique (PLD) [9], chemical vapour deposition (CVD) [10], RF-sputtering [11]. Spray pyrolysis offers certain benefits over the other techniques when compared to them. It has a flexible process mechanism, can create large-area and nanostructured films, and has a low-cost yet effective method. Therefore, it is used to fabricate the samples within this work.

The nanomaterial sensors have been introduced based on multiple principles of absorption for the ultraviolet-infrared (UV-IR) range [12], [13], the resistance of electric circuit [14]–[16], amperometry [17]. Current sensing techniques have been proven to improve in order to test the effectiveness, stability, reaction time, and sensitivity when nanomaterials are used. Organic, inorganic or hybrid components are used in sensing applications. Organic materials have several desired characteristics such as mass transfer, surface chemistry, and gas conductivity. However, inorganic nanomaterials are better in terms of their physical stability, resistivity, and optical characteristics [18], while hybrid nanomaterials combine between the organic and inorganic materials which improve the functional details [19].


In order to track and regulate indoor air quality, carbon dioxide (CO_2) detectors are essential [20]. Ecological, industrial, and sensors are all interested in CO_2 sensing using cheap, remotely controlled, extremely important sensors that operate at ambient temperature [21]. Because of the immense effect of CO_2 pollution on climate change, CO_2 tracking is important in the area of sensing applications [22]. CO_2 detectors are also essential in the agriculture sector [23], as well as breathing monitoring systems in medicine [24], [25], atmospheric institutes in nanotechnology [26], and petroleum refineries [27]. In addition, CO_2 sensors are in high demand for space and industrial uses, such as moderate fire alarm that detects chemical compounds suggestive of a fire [28]. Despite this, owing to the increase chemical stability of CO_2 , there are about a few experiments in CO_2 detectors that can function at ambient temperature. In contrast to spectrometric CO_2 gas detectors, physical CO_2 gas sensors based on metal oxides have a low power consumption, convenience, and small size [29]. Gas sensors based on TiO_2 nanostructured has been introduced [30]. Gas sensing technology can be found in two leading commercial platforms: electronic (lambda sensors) and optical (nondispersive infrared (NDIR) sensors and optrodes) [31]

Danie *et al.* [32] synthesised a CdS/WO_x nanocomposite that exhibits photocapacitive solar energy storage. They performed spectroscopy characterization and temporary photocurrent reaction comparative to an effect attributed to the extinction of electron-hole reconnected in CdS due to hole transmission across the work sheds light on how the constituent materials could be used in the future self-charging solar device. Aishwarya et. al synthesized CdS nanoparticles under different concentrations of cadmium chloride and sodium sulphide used for applications in cancer therapy [33]. Under various doses of cadmium chloride and sodium sulfide, escherichia coli cells were utilized to produce CdS nanoparticles. Scanning electron microscopy (SEM) was used to examine the morphology of the nanoparticles, and X-ray spectroscopy (EDX) was utilized to examine the elemental composition of the nanoparticles. The functional groups of the nanoparticles were determined using Fourier-transform infrared spectroscopy. X-ray diffraction was used to determine the crystalline nature of nanoparticles. Foodborne pathogens were used to test the antibacterial properties of CdS nanoparticles. Zahra *et al.* [34] synthesized cadmium sulfide as quantum dots which have unique medical applications contains identifying cells, identifying viruses, and imaging intercellular proceedings.

This work is dedicated to fabricating CdS samples with Ag doping percentage (0%, 2%, and 4%). The method of the fabrication is Pyrolysis technique. The morphological, structural, and sensitivity towards CO_2 are presented. The homemade device was used to measure the sensitivity of the CO_2 for the three samples with the response time. The response time is very short compared to other works which open door for many applications. As a result, much effort has done into finding or developing new CO_2 sensitive mixtures that can operate at ambient temperature and provide particularly, ambient environment activities, fast response, and a rapid and reusable reaction.

2. PROPOSED METHOD

The CdS thin films were fabricated from a 0.1 M water solution of Cadmium Sulfide $\text{CdSO}_4 \cdot 8\text{H}_2\text{O}$, by spray pyrolysis technique, onto a glass substrate. The silver (Ag) doping silver nitrate (AgNO_3) powder dissolved in a precursor solution of CdSO_4 with different weight percentages (W.%). The Ag-doped specimens fabricated with the different ratios of 0, 2, and 4 W.% silver concentrations. The CdS specimens fabricated with the same settings, of solution volume 100 ml and nozzle, to the resulting solution sprayed on preheated glass. The chemical equations can be describing the prepared samples as (1), (2).



After that, the CdS layer added to the CdS samples that resulted from (1) to have the doped samples as (3).



The deposition parameters applied to the preparation of CdS thin films are present in Table 1.

Table 1. Deposition parameters applied in this research

Item	Details
CdSO ₄ .8H ₂ O solution concentration	0.1M
Gas pressure	1 bar
Substrate temperature (C _o)	350 C _o
Nozzle to substrate distance	25 cm
Solvent	Distilled water
Deposition of one time	10 Sec
Deposition total time (minutes)	15 min
Rat of spray	2.5 ml/ min
Spray time during each cycle	50 Sec

3. METHOD

The sensor element was linked in series with millimetre electrical impedance tests were done using two millimetres for current, external voltage measurements, and power source in the range of (0-20) Volt to examine the electrical characteristics of the examined specimens. Gas sensing tests carried out using a home-built gas sensing chamber (gas flow elements) as shown in Figure 1. Test chamber unit consists of a stainless steel almost cylindrical shape with diameter and height 20 cm and 16 cm respectively. The base has removable O – ring sealed. The chamber volume is 5024 cm³ with 50 mbar pressure. The device located at ministry of science and technology. Where CO₂ gas preparation by the (4).



The film surface adsorbed CO₂ gas which causes increasing the total resistance of the sample. It is promising to reduce the required effective temperature by reducing the heating power and improve the sensor productivity reaction. The nanoscale layer changes the surface exhaustion and can lead to a different reaction with the nanostructure. The increase of crystalline size increased boundary resistance, indicating that the roughness average contributes to gas sensitivity. This lead to a change in the response of the sensitivity of the doped sample. The literature shows that resistance of the detector at RT amplified or reduced because of the electrolytic separation of the tested gasses in the exterior sample [35]. Because Cd atoms occupy the majority of the tetrahedral sites and there are vacant sites, the specimen structure is rather open. As a result, CdS has plenty of places to tolerate inherent defects and immutable doping. The gas sensitivity of thin film elements for CO₂ gas was evaluated at room temperature.

For lowering and oxidizing gases, the resistance reaction of each sensor structure was converted into a sensitivity value using the frequently used formula 5 [36].

$$S = \Delta R/R$$

$$S = R_{air} - R_{gas} / R_{air} \quad (5)$$

where S is the sensitivity, R_{air} is the resistance in air and R_{gas} resistance with gas. Figure 1 shows the setup of the suggested system in the lab.



Figure 1. The setup of homemade gas sensing measurement

4. RESULTS AND DISCUSSION

In this section, it is explained the results of research and at the same time is given the comprehensive discussion. The results devided into three sections regarding to cover the details and data of the suggested samples. These sections are morphological, structural, and sensing properties.

4.1. Morphological properties

The morphology of the deposited films examined using an atomic force microscope (AFM) (Angstrom AA3000). Characteristic 3D and 2D AFM pictures of the CdS: Ag specimen synthesized at different doping concentrations (pure (0%), 2%, and 4%) are shown in Figure 2. Figure 2(a) has homogenous structure surface because it is pure without any adding materials. While Figures 2(b) and 2(c) have different surface morphology because of the metallic Ag.




Figure 2. 3D and 2D of AFM images of (a) pure (0%), (b) 2%, and (c) 4% Ag-doped CdS films

Table 2 shows the average crystal size, average roughness, and root mean square (RMS) roughness as determined by AFM. The crystallite size and RMS roughness of the film have risen as the doping concentration has grown. Columnar grain development in the structure might be causing the crystallite size to rise. The crystalline size findings acquired by AFM research differ from those obtained from X-ray diffraction (XRD) observations using the Scherrer equation [37]. This due to that AFM results were described exterior crystalline surface but the XRD results were described interior crystalline structure, as shown in Table 2.

Table 2. Structural characteristics of CdS: Ag specimen

Doping Concentration	RMS (nm)	Average grain size (nm) of AFM	Max crystalline size (nm) of XRD	Roughness average (nm)
pure	81.822	75	27.7	62.716
2%	131.893	65	37.5	100.479
4%	150.547	55	53.3	117.626

4.2. Structural properties

Structural details of the CdS/Ag samples presented by XRD technique of Shimadza-6000 using Cu $\text{K}\alpha$ radiation. Figure 3 shows the XRD data of pure and CdS doped with Ag thin film. These samples show polycrystalline and peaks that are ascribed to the hexagonal structure. The peaks of the film corresponding to Miller planes (111) and (102) reflections position at $2\theta=26.6$ and $2\theta=36.7$ with ($x=0, 2\%$ and 4%) respectively, for the pure and doping samples. The CdS structure films reported by many studies confirming the cubic and hexagonal crystalline shape [38].

There are no peaks associated to metallic Ag or Ag compounds. As a result, Ag atoms can be exchanged for sulphite atoms or integrated into the CdS lattice's interstitial sites. This indicates that the precursors have been fully converted to the CdS phase, and that Ag doping has had no effect on the CdS lattice's hexagonal structure. Despite the variations in the atomic radius of the server and the dopant, there are no changes in the peak position.

4.3. Sensing properties

The sensitivity response time is changed with the doping ratio 4% , which means we can control the sensitivity time. The previous reports show long sensitivity response time for CdS [35]. However, the sensitivity percentage is changed with changing the doping ratio. The lowest sensitivity (%) with the doping ratio 4% due to the effect of the Ag. The high interaction to CO_2 can be explain to the sample modification. In the two-dimensional system, the electron-electron interaction in the presence of periodically heightened disorders can establish the adsorption, ionization, and diffusion interaction resulting in different sensitivity.

There are two significant indicators for the time response and recovery curve to show sensor performance. The response time or the raising time describe the sensor resistance that reach 90% from the steady point, while the recovery or falling time describes the sensor resistance to recover about 90% from the total changing after test gas stopped pumping. The faster response and recovery sample time of the sensor is due to adsorption at the sample surface. The small response time means that sample has fast oxidization with gas. The sensitivity CdS:Ag thin films (0%, 2% and 4%) shown in Figure 4.




Figure 3. XRD data of pure, 2%, and 4% Ag-doped CdS films




Figure 4. The relation between the sensitivity and time in second

5. CONCLUSION

Pure and Ag-doped CdS specimens were deposited using the chemical spray pyrolysis technique. The size of the molecular of the doped samples is larger than that of the pure sample. In this research, we found CdS has a polycrystalline composition with Hexagonal type, and has favourite directions for the growth of granule (111) and (102). We observed the sensitivity was decreased with an increased doping ratio because Silver is oxidized before the formation of a crystalline compound. We observed the sensitivity was very low

because the CO₂ gas was inert gas. The roughness was increased with doping increased too. The response time is very short comparing with other studies which make these samples are desirable to detect CO₂.

REFERENCES

- [1] H. Sattarian, T. Tohidi, and S. Rahmatallahpur, "Effect of TEA on characteristics of CdS/PbS thin film solar cells prepared by CBD," *Materials Science-Poland*, vol. 34, no. 3, pp. 540–547, Sep. 2016, doi: 10.1515/msp-2016-0072.
- [2] S. Saravanan Kumar, R. Chandramohan, R. Premarani, J. J. Devadasan, and J. Thirumalai, "Studies on dilute magnetic semiconducting co-doped CdS thin films prepared by chemical bath deposition method," *Journal of Materials Science: Materials in Electronics*, vol. 28, no. 16, pp. 12092–12099, Aug. 2017, doi: 10.1007/s10854-017-7022-3.
- [3] S. Z. Werta, O. K. Echendu, F. B. Dejene, Z. N. Urgessa, and J. R. Botha, "Temperature-dependent properties of electrochemically grown CdS thin films from acetate precursor," *Applied Physics A*, vol. 124, no. 9, p. 576, Sep. 2018, doi: 10.1007/s00339-018-1996-4.
- [4] S. K. Shinde, H. D. Dhaygude, P. P. Chikode, and V. J. Fulari, "Structural, morphological, optical and hologram recording of the CdS and ZnS thin films by double exposure digital holographic interferometry technique," *Journal of Materials Science: Materials in Electronics*, vol. 28, no. 10, pp. 7385–7392, May 2017, doi: 10.1007/s10854-017-6427-3.
- [5] S. Yilmaz, İ. Polat, M. A. Olgar, M. Tomakin, S. B. Töreli, and E. Bacaksız, "Physical properties of CdS:Ga thin films synthesized by spray pyrolysis technique," *Journal of Materials Science: Materials in Electronics*, vol. 28, no. 4, pp. 3191–3199, Feb. 2017, doi: 10.1007/s10854-016-5908-0.
- [6] R. G. Solanki, P. Rajaram, and P. K. Bajpai, "Growth, characterization and estimation of lattice strain and size in CdS nanoparticles: X-ray peak profile analysis," *Indian Journal of Physics*, vol. 92, no. 5, pp. 595–603, May 2018, doi: 10.1007/s12648-017-1134-8.
- [7] Z. M. Kakhaki, A. Youzbashi, P. Sangpour, N. Naderi, and A. Kazemzadeh, "Effect of bath temperature and concentration of buffer salt on the optoelectronic characteristics of CdS thin films synthesised by chemical bath deposition method," *Micro & Nano Letters*, vol. 11, no. 2, pp. 81–85, Feb. 2016, doi: 10.1049/mnl.2015.0414.
- [8] M.-K. Son, H. Seo, S.-K. Kim, S. Park, M.-S. Jeong, and H.-J. Kim, "Improved performance of CdS and dye co-sensitized solar cell using a TiO₂ sol-gel solution," *physica status solidi (a)*, vol. 211, no. 8, pp. 1726–1731, Aug. 2014, doi: 10.1002/pssa.201330492.
- [9] W. S. Hussein, A. F. Ahmed, and K. A. Aadim, "Influence of laser energy and annealing on structural and optical properties of CdS films prepared by laser induced plasma," *Iraqi Journal of Science*, pp. 1307–1312, Jun. 2020, doi: 10.24996/ij.s.2020.61.6.8.
- [10] J. P. Ge and Y. D. Li, "Selective atmospheric pressure chemical vapor deposition route to CdS arrays, nanowires, and nanocombs," *Advanced Functional Materials*, vol. 14, no. 2, pp. 157–162, Feb. 2004, doi: 10.1002/adfm.200305051.
- [11] S. Rondiya, A. Rokade, A. Funde, M. Kartha, H. Pathan, and S. Jadkar, "Synthesis of CdS thin films at room temperature by RF-magnetron sputtering and study of its structural, electrical, optical and morphology properties," *Thin Solid Films*, vol. 631, pp. 41–49, Jun. 2017, doi: 10.1016/j.tsf.2017.04.006.
- [12] F. Starecki *et al.*, "All-optical carbon dioxide remote sensing using rare earth doped chalcogenide fibers," *Optics and Lasers in Engineering*, vol. 122, pp. 328–334, Nov. 2019, doi: 10.1016/j.optlaseng.2019.06.018.
- [13] L. Liu, S. P. Morgan, R. Correia, S.-W. Lee, and S. Korposh, "Multi-parameter optical fiber sensing of gaseous ammonia and carbon dioxide," *Journal of Lightwave Technology*, vol. 38, no. 7, pp. 2037–2045, Apr. 2020, doi: 10.1109/JLT.2019.2953271.
- [14] Y. Xiong *et al.*, "Effective CO₂ detection based on LaOCl-doped SnO₂ nanofibers: insight into the role of oxygen in carrier gas," *Sensors and Actuators B: Chemical*, vol. 241, pp. 725–734, Mar. 2017, doi: 10.1016/j.snb.2016.10.143.
- [15] A. B. A. Hammad, A. M. Elnahrawy, A. M. Youssef, and A. M. Youssef, "Sol gel synthesis of hybrid chitosan/calcium aluminosilicate nanocomposite membranes and its application as support for CO₂ sensor," *International Journal of Biological Macromolecules*, vol. 125, pp. 503–509, Mar. 2019, doi: 10.1016/j.ijbiomac.2018.12.077.
- [16] I. Stassen, J.-H. Dou, C. Hendon, and M. Dincă, "Chemiresistive sensing of ambient CO₂ by an autogenously hydrated Cu₃(hexaiminobenzene) 2 Framework," *ACS Central Science*, vol. 5, no. 8, pp. 1425–1431, Aug. 2019, doi: 10.1021/acscentsci.9b00482.
- [17] B. Ersöz, K. Schmitt, and J. Wöllensteiner, "Electrolyte-gated transistor for CO₂ gas detection at room temperature," *Sensors and Actuators B: Chemical*, vol. 317, p. 128201, Aug. 2020, doi: 10.1016/j.snb.2020.128201.
- [18] M. Rebber, C. Willa, and D. Ko ziej, "Organic-inorganic hybrids for CO₂ sensing, separation and conversion," *Nanoscale Horizons*, vol. 5, no. 3, pp. 431–453, 2020, doi: 10.1039/C9NH00380K.
- [19] V. P. Ananikov, "Organic-inorganic hybrid nanomaterials," *Nanomaterials*, vol. 9, no. 9, p. 1197, Aug. 2019, doi: 10.3390/nano9091197.
- [20] V. D. N. Bezzon *et al.*, "Carbon nanostructure-based sensors: a brief review on recent advances," *Advances in Materials Science and Engineering*, vol. 2019, pp. 1–21, Mar. 2019, doi: 10.1155/2019/4293073.
- [21] S. A. Sarkodie, E. B. Ntiamoah, and D. Li, "Panel heterogeneous distribution analysis of trade and modernized agriculture on CO₂ emissions: the role of renewable and fossil fuel energy consumption," *Natural Resources Forum*, vol. 43, no. 3, pp. 135–153, Aug. 2019, doi: 10.1111/1477-8947.12183.
- [22] V. R. Chopda *et al.*, "Real-time dissolved carbon dioxide monitoring I: Application of a novel in situ sensor for CO₂ monitoring and control," *Biotechnology and Bioengineering*, vol. 117, no. 4, pp. 981–991, Apr. 2020, doi: 10.1002/bit.27253.
- [23] J. Cunniff, G. Jones, M. Charles, and C. P. Osborne, "Yield responses of wild C3 and C4 crop progenitors to subambient CO₂: a test for the role of CO₂ limitation in the origin of agriculture," *Global Change Biology*, vol. 23, no. 1, pp. 380–393, Jan. 2017, doi: 10.1111/gcb.13473.
- [24] A. Tricoli, N. Nasiri, and S. De, "Wearable and miniaturized sensor technologies for personalized and preventive medicine," *Advanced Functional Materials*, vol. 27, no. 15, p. 1605271, Apr. 2017, doi: 10.1002/adfm.201605271.
- [25] D. Don, B. Osterbauer, S. Nour, M. Matar, R. Margolis, and G. Bushman, "Transcutaneous CO₂ monitoring in children undergoing tonsillectomy for sleep disordered breathing," *The Laryngoscope*, vol. 131, no. 6, pp. 1410–1415, Jun. 2021, doi: 10.1002/lary.29203.
- [26] B. Byrne *et al.*, "Improved constraints on northern extratropical CO₂ fluxes obtained by combining surface-based and space-based atmospheric CO₂ Measurements," *Journal of Geophysical Research: Atmospheres*, vol. 125, no. 15, Aug. 2020, doi: 10.1029/2019JD032029.
- [27] É. Yáñez, H. Meerman, A. Ramírez, É. Castillo, and A. Faaij, "Assessing bio-oil co-processing routes as CO₂ mitigation strategies in oil refineries," *Biofuels, Bioproducts and Biorefining*, vol. 15, no. 1, pp. 305–333, Jan. 2021, doi: 10.1002/bbb.2163.

- [28] S. Tarar and N. Bhasin, "Fire hazard detection and prediction by machine learning techniques in smart buildings (SBs) using sensors and unmanned aerial vehicles (UAVs)," *Digital Cities Roadmap*, pp. 63–95, 2021, doi: 10.1002/9781119792079.ch2.
- [29] K. S. S. Devi, A. Anantharamakrishnan, U. M. Krishnan, and J. Yakhmi, "Chemical sensors based on metal oxides," in *Smart Sensors for Environmental and Medical Applications*, Wiley, 2020, pp. 103–127.
- [30] X. Tian *et al.*, "Gas sensors based on TiO₂ nanostructured materials for the detection of hazardous gases: A review," *Nano Materials Science*, vol. 3, no. 4, pp. 390–403, 2021, doi: 10.1016/j.nanoms.2021.05.011.
- [31] J. Perkins and B. Gholipour, "Optoelectronic gas sensing platforms: from metal oxide lambda sensors to nanophotonic metamaterials," *Advanced Photonics Research*, vol. 2, no. 7, p. 2000141, Jul. 2021, doi: 10.1002/adpr.202000141.
- [32] D. R. Jones, R. Phillips, W. J. F. Gannon, B. Rome, M. E. A. Warwick, and C. W. Dunnill, "Photocapacitive CdS/WO_x nanostructures for solar energy storage," *Scientific Reports*, vol. 9, no. 1, p. 11573, Dec. 2019, doi: 10.1038/s41598-019-48069-5.
- [33] A. Shivasankarappa and K. R. Sanjay, "Escherichia coli-based synthesis of cadmium sulfide nanoparticles, characterization, antimicrobial and cytotoxicity studies," *Brazilian Journal of Microbiology*, vol. 51, no. 3, pp. 939–948, Sep. 2020, doi: 10.1007/s42770-020-00238-9.
- [34] D. Thueman and T. Gaewdang, "Structural, optical and electrical properties of (CdS) 1-x (ZnTe) x solid solution thin films prepared by vacuum thermal evaporation method," *Journal of Physics: Conference Series*, vol. 1259, no. 1, p. 012006, Sep. 2019, doi: 10.1088/1742-6596/1259/1/012006.
- [35] N. Zhang *et al.*, "Excellent gas sensing of CdS nanowires decorated with Ag nanoparticles," *Journal of Nanoscience and Nanotechnology*, vol. 19, no. 11, pp. 7083–7088, Nov. 2019, doi: 10.1166/jnn.2019.16720.
- [36] H. J. Mohamad, Y. M. Abdul-Husaain, and U. A. S. Al-Jarah, "The structural, optical, and morphological properties of NiO-Cu prepared by spray pyrolysis technique," *Microwave and Optical Technology Letters*, vol. 62, no. 11, pp. 3519–3526, Nov. 2020, doi: 10.1002/mop.32500.
- [37] A. Mirzaei *et al.*, "Resistive gas sensors based on metal-oxide nanowires," *Journal of Applied Physics*, vol. 126, no. 24, p. 241102, Dec. 2019, doi: 10.1063/1.5118805.
- [38] V. De Waele and S. Mintova, "Photoactive metal-containing zeolitic materials for sensing and light-to-chemical energy conversion," in *Chemistry of Silica and Zeolite-Based Materials*, Elsevier, 2019, pp. 331–349.

BIOGRAPHIES OF AUTHORS



Dr. Uday Ali Sabeeh Al-Jarah received the B.Sc. degree in physics science from Mustansiriyah University, Iraq (1998), the M.Sc. degree in Physics from Mustansiriyah University, Iraq (2003), and the Ph.D. degree in Physics from University of Exeter, U.K, (2013). He is a Senior Lecturer, and the Head of the Renewable Energy Committee at the University of Misan since 2016. He has authored or coauthored more than 7 publications, with 3 H-index. His research interests include spectroscopy, Nano-optics, ultrafast magnetic phenomena, and laser applications. He can be contacted at email: drudayaaljarah@uomisan.edu.iq.



Dr. Haidar Jawad Mohamad received the B.Sc. degree in physics science from the Mustansiriyah University, Iraq, the M.Sc. degree in Physics from Mustansiriyah University, Iraq, and the Ph.D. degree in Physics from The University of Exeter, U.K, 2015. He used to hold several administrative positions with the department of physics, Mustansiriyah University from 2016 to 2018, including administer of Postgraduate students. He is currently Assis. Professor with the Department of Physics, Mustansiriyah University. He has supervised and co-supervised more than 4 masters and 1 Ph.D. students. He has authored or coauthored more than 35 publications, with 3 H-index. His research interests include soft computing, machine learning, intelligent systems and, optics. He can be contacted at email: haidar.mohamad@uomustansiriyah.edu.iq.



Yahya Mustafa Abdul-Hussein received the B.Sc. degree in physics science from the Mustansiriyah University, Iraq, M.Sc. degree in Republic of India, University of acharya, Nagarjuna university of Science college, Department of Physics, 2016.employee at ministry of science and technology. He can be contacted at email: yahyamus1975@gmail.com.