R2.2 HUMAN REVIEW PACK

1. OWNER ENSUITE

[illegible] FCStd [illegible]

[illegible] front clearance: -120.8 / target 800 / CONFLICT / shortfall 920.8 mm / HUMAN DECISION REQUIRED

[illegible] internal footprint: 1.44 / target — / TO_VERIFY / area is reference only / HUMAN DECISION REQUIRED

Owner ensuite door/opening: — / target — / TO_VERIFY / not measurable as a named FCStd door / HUMAN DECISION REQUIRED

2. MOTHER BEDROOM + MOTHER BATH

[illegible] FCStd[illegible]

[illegible] side clearance: 173.6 / target 600 / CONFLICT / shortfall 426.4 mm / HUMAN DECISION REQUIRED

[illegible] foot clearance: 1387.9 / target 600 / PASS / none / NO CHANGE REQUIRED

[illegible] front clearance: -71.1 / target 800 / CONFLICT / shortfall 871.1 mm / HUMAN DECISION REQUIRED

[illegible] footprint: 1.57 / target — / TO_VERIFY / area reference only / HUMAN DECISION REQUIRED

3. GUEST BATH

[illegible] FCStd [illegible]3kg [illegible] FCStd [illegible]

[illegible] front clearance: 1044.0 / target 800 / PASS / none / NO CHANGE REQUIRED

[illegible] footprint: 1.64 / target — / TO_VERIFY / area reference only / HUMAN DECISION REQUIRED

3kg small washer: — / target 600 / TO_VERIFY / not available: no named latest-FCStd object / HUMAN DECISION REQUIRED

4. MIDDLE GUEST ROOM + OWNER BEDROOM

[illegible] owner bedroom [illegible] FCStd [illegible]/[illegible]

[illegible]1.2 side clearance: 215.4 / target 600 / CONFLICT / shortfall 384.6 mm / HUMAN DECISION REQUIRED

[illegible]1.2 foot clearance: 1437.8 / target 600 / PASS / none / NO CHANGE REQUIRED [illegible] side clearance: 233.4 / target 600 / CONFLICT / shortfall 366.6 mm / HUMAN DECISION REQUIRED

[illegible] foot clearance: 1412.8 / target 600 / PASS / none / NO CHANGE REQUIRED

[illegible] / balcony door: — / target 100 / CONFLICT / 0 mm minimum distance; overlap 22,014.6 mm² / HUMAN DECISION REQUIRED

5. STUDY

[illegible] FCStd [illegible]+[illegible]

Formal workstation / chair pull-back: — / target 900 / TO_VERIFY / no named printer/NAS or explicit operating-zone object / HUMAN DECISION REQUIRED
Bookcase / tea-table topology: — / target — / PASS / no numerical target in source report / NO CHANGE REQUIRED

Study printer/NAS provision: — / target — / TO_VERIFY / missing named object in latest FCStd / HUMAN DECISION REQUIRED

6. DINING + NORTH BALCONY / LAUNDRY

[illegible] FCStd [illegible]+[illegible]/[illegible]

[illegible] table gap: 121.1 / target 150 / CONFLICT / shortfall 28.9 mm / HUMAN DECISION REQUIRED

[illegible]003 table gap: 121.1 / target 150 / CONFLICT / shortfall 28.9 mm / HUMAN DECISION REQUIRED

[illegible]004 table gap: 198.5 / target 150 / PASS / none / NO CHANGE REQUIRED

[illegible]+[illegible]: — / target — / TO_VERIFY / latest object present; generic/SKU envelope not measured here / HUMAN DECISION REQUIRED

Main laundry service: — / target — / TO_VERIFY / drainage/power/SKU not verified / HUMAN DECISION REQUIRED

R2.2 Critical Issues



R2.2 Critical Issues — current latest-FCStd positions only