

Searle Chemistry Laboratory D09



[If you have comments, send additional information](#)

Address: 5715-35 South Ellis Avenue
Year Construction: 1968
Year Acquired: 1968
Architect: Smith Haines Lundberg & Waehler
Gross Square Feet: 85,570
Primary Use: Laboratory
Design Zone: Main Quadrangle
Last Major Renovation:
 2009 gut/rebuild by William Wilson Assoc.
Comments:

LEED Gold certification. The 5-story renovation of the Searle Chemistry Building includes state-of-the-art dedicated research space for 5 principal investigators and approximately 60 graduate students, and administrative offices for the Department of Chemistry.

REGULATORY STATUS

National Register: Not individually listed
NR Historic District:
 Hyde Park-Kenwood Historic District
Chicago HRS Color Code: None

1 - Site

Land Ownership Status: Owned
Location - Physical:
 No comment
Location - Program Adjacency:
 Connected to Jones Laboratory.
Location Comment:
 Connected to Snell Hall via exit stair and to Jones Laboratory on all levels.

2 - Adaptability

Construction Type:

Reinforced concrete construction

Accessibility:

ADA Accessible

Floor-to-Floor Height:

1st: 13'-9", 2nd, 3rd, 4th: 14'-0"

Structural Capability:

Highly adaptable subject to structural analysis.

Adaptability Exterior:

Highly adaptable.

Adaptability Interior:

Current laboratory and office use - highly adaptable within construction type constraints.

Adaptability Physical Features:

No comment

Adaptability Structure:

Highly adaptable within construction type constraints.

3 - Building Envelope

Roof Type: No Data

Exterior Facade:

Limestone

Exterior Base: Limestone

Exterior Trim: Limestone

4 - Heritage and Historic

Landmark Status:

no

National Register: Not individually listed

NR Historic District:

Hyde Park-Kenwood Historic District

NR Comments:

Not listed on district nomination form

CHRS Comments:

None

Heritage - Exterior:

Building completely renovated in 2009.

Heritage - Interior:

Interior completely renovated to provide new laboratory and offices.

Significant Spaces Identified:

No Comment

Heritage Culture Elements:

Original building designed as additional space for chemistry department. Building was completely

Searle Chemistry Laboratory

D09

renovated in 2009 with no significant original interior building features retained.

Architectural Awards Certification:

LEED Gold certification.

Heritage and History - General Comments:

Building exhibits 1960's modern style rendered in limestone to blend in with adjacent academic buildings.

5 - Sustainability

Certifications:

LEED Gold

Window Last Replacement:

2009

Weather Stripping:

not identified

R Value Roof/Wall:

not identified

Systems:**Deficiencies:**