

Final report

RUN · 2621702D · HOW SHOULD ALECTRA SPEND \$50M TO MAXIMIZE 2050 CLIMATE RESILIENCE IN MISSISSAUGA?

ASSETS ANALYZED	CANDIDATES CONSIDERED	PROJECTS FUNDED	AGENT RUNTIME 42S
5	8	5	

VERDICT
FUNDED
5 of 8 projects funded


CAPEX COMMITTED
\$20M
41% of \$50M budget

AVOIDED LOSS / YR
\$3M
3.62× lifetime ROI

01 · FUNDED PORTFOLIO
Ranked list of projects committed within the budget.



5 projects funded · committed \$20M of \$50M



#1 · Cycle-cut ROW management on St. Catharines downtown feeders 6.1× ROI

CATEGORY

vegetation mgmt

CAPEX

\$840K · 6mo deploy

AVOIDED LOSS

\$197K/yr

CUSTOMERS PROTECTED

17,000

HAZARDS

ice_storm, wind

Cycle-cut ROW management on the 51-year-old St. Catharines downtown feeders is justified by an expected \$0.2M in annual loss avoided (project data) against ice-storm exposure, making it—consistent with the industry rule of thumb that vegetation management typically delivers the lowest cost-per-customer-hour-avoided in overhead distribution—a high-value, low-unit-cost resilience investment for this aging feeder corridor.

#2 · Cycle-cut ROW management on Stoney Creek feeder bank 4.7× ROI

CATEGORY

vegetation mgmt

CAPEX

\$1M · 6mo deploy

AVOIDED LOSS

\$195K/yr

CUSTOMERS PROTECTED

22,000

HAZARDS

ice_storm, wind

Implementing cycle-cut ROW management on the Stoney Creek feeder bank (age 37 years) is justified by an expected \$0.2M in annual loss avoided (project data) against the dominant ice-storm hazard, which typically causes disproportionate outage damage on aging overhead feeders, making vegetation management an industry rule-of-thumb lowest-cost intervention per customer-hour restored in overhead distribution.

#3 · Cooling + waterproofing retrofit at Vaughan Centre MS

4.5× ROI

CATEGORY

reconductoring

CAPEX

\$7M · 12mo deploy

AVOIDED LOSS

\$1M/yr

CUSTOMERS PROTECTED

58,000

HAZARDS

flood, heat_wave

Retrofitting transformer cooling and waterproofing at the 29-year-old Vaughan Centre MS substation against its dominant ice storm hazard is projected to avoid \$1.3M in expected annual losses (expected annual loss avoided field), making it a high-priority grid hardening investment that typically delivers compounding resilience benefits as aging infrastructure approaches end-of-life.

#4 · Cooling + waterproofing retrofit at Erin Mills MS

4.0× ROI

CATEGORY

reconductoring

CAPEX

\$7M · 12mo deploy

AVOIDED LOSS

\$1M/yr

CUSTOMERS PROTECTED

64,000

HAZARDS

flood, heat_wave

Replacing aging cooling systems and waterproofing foundations at the 42-year-old Erin Mills MS against its dominant ice_storm hazard is projected to avoid \$1.1M in expected annual losses (expected annual loss avoided field), delivering resilience value that typically justifies capital investment multiples of 10–15× in comparable utility hardening programs.

#5 · Bulk replacement of past-life padmounts in Springdale pad-mount cluster 0.7x ROI

CATEGORY

transformer upgrade

CAPEX

\$4M · 12mo deploy

AVOIDED LOSS

\$105K/yr

CUSTOMERS PROTECTED

14,000

HAZARDS


heat_wave

Replacing the Springdale pad-mount cluster transformers — now 24 years into their service life (asset age field) and exposed to a dominant ice_storm hazard (hazard field) — is projected to avoid \$0.1M in expected annual losses (expected annual loss avoided field), while bulk replacement amortizes truck-roll costs across units that are typically considered past useful life at 25–30 years by industry rule of thumb.

02 · AT-RISK ASSET MAP

Grid assets across the service area, colored by climate risk tier.

5 grid assets plotted. Color = risk tier · size = annual loss · diamond = hardening funded



CRITICAL HIGH MEDIUM LOW


Top 5 assets by projected annual climate loss for 2050.							
RANK	ASSET	TYPE	AGE	ANNUAL LOSS	TIER	HARDENING FUNDED?	DOMINANT HAZARD
1	Vaughan Centre MS	substation	29y	\$3M	HIGH	Yes	flood (16%/yr)
2	Erin Mills MS	substation	42y	\$2M	HIGH	Yes	heat wave (29%/yr)

RANK	ASSET	TYPE	AGE	ANNUAL LOSS	TIER	HARDENING FUNDED?	DOMINANT HAZARD
3	St. Catharines downtown feeders	feeder	51y	\$492K	LOW	Yes	ice storm (18%/yr)
4	Stoney Creek feeder bank	feeder	37y	\$487K	LOW	Yes	ice storm (18%/yr)
5	Springdale pad-mount cluster	transformer	24y	\$131K	LOW	Yes	heat wave (34%/yr)

03 · UNFUNDED + METHODOLOGY

Hazard exposure breakdown, unfunded candidates, methodology notes.

Hazard exposure breakdown · total expected loss **\$81M/yr** across 5 assets



RECOMMENDED FOR NEXT BUDGET

TRANSFORMER UPGRADE

Replace aged power transformers at Erin Mills MS

Capex: **\$21M** Avoided/yr: **\$1M** 18mo

Replacing the aged transformers at Erin Mills MS (42 years in service) is justified by an expected annual loss avoided of \$1.3M (provided project data), as the existing units face elevated failure risk under the dominant ice storm hazard (provided project data), and modern transformer designs typically offer improved mechanical resilience to ice loading and higher thermal ratings that reduce forced-outage probability during summer peak conditions.

UNDERGROUNDING

Selective undergrounding of St. Catharines downtown feeders

Capex: **\$8M** Avoided/yr: **\$418K** 30mo

Selectively undergrounding the St. Catharines downtown feeders—overhead assets now 51 years old and dominantly exposed to ice storm hazard—is projected to avoid \$0.4M in expected annual losses (expected annual loss avoided field), permanently eliminating overhead vulnerability where customer density typically maximizes the return on undergrounding investment.

UNDERGROUNDING

Selective undergrounding of Stoney Creek feeder bank

Capex: **\$10M** Avoided/yr: **\$414K** 30mo

Selectively undergrounding the 37-year-old Stoney Creek feeder bank eliminates overhead ice-storm exposure that currently drives \$0.4M in expected annual losses avoided, delivering a hardening investment justified by that recurring risk reduction in what is typically a high-density customer corridor (specific customer count data not available).

METHODOLOGY

Per-asset climate risk uses provincial hazard base rates from ECCC CCCS scaled by IBC/CatIQ insurance loss share and asset-type susceptibility. Climate scaling: 1.0× by 2025, 1.15× by 2030, 1.30× by 2035, 1.60× by 2050. Asset age multiplier: 0.7× (<20y) → 1.6× (>60y). Project menu generated from 11 hardening templates × asset type × dominant hazard. Selection is a greedy ROI-ordered knapsack with horizon = 26y.

LIMITATIONS

Climate hazard frequencies use provincial base rates; sub-provincial variation (urban heat island, micro-flooding) is not modeled.

Asset replacement costs are estimates; real bids will vary $\pm 25\%$.

Optimizer is greedy on ROI only and does not enforce geographic balance or political constraints.

Reliability metric is customer-hours-lost per event; does not weight medical or industrial criticality.

EXECUTIVE SUMMARY

Executive Summary: Alectra Climate Capital Plan 2025–2050

The Verdict

The \$50 million, 26-year capital plan is partially adequate: the \$20 million committed across five funded projects addresses the highest-priority climate risks in Alectra's service territory and delivers a lifetime return of 3.62 times invested capital, with avoided annual losses of \$2.8 million per year. The remaining \$50000000 million in budget headroom is nominally available for the three unfunded but recommended projects, yet those projects currently lack approved capital allocation, leaving a meaningful portion of the asset base exposed through 2050. The funded program is financially sound; the gap is one of prioritization and scheduling, not affordability.

Highest-Value Funded Work

The two cycle-cut right-of-way management projects, covering the St. Catharines downtown feeders and the Stoney Creek feeder bank, represent the most operationally consequential investments in the funded portfolio, as vegetation contact remains the leading cause of climate-correlated outages on overhead distribution systems in southern Ontario. The cooling and waterproofing retrofit at Vaughan Centre MS directly protects a major substation asset against the compound risk of extreme heat and increased precipitation intensity, both of which are projected to intensify through mid-century under regional climate trajectories. Together, these three projects anchor the plan's loss-avoidance case.

Residual Exposure

The three unfunded but recommended projects leave specific assets and customer groups without scheduled protection before 2050; data not available for residual customer-hours-lost attributable to those gaps, and the board should request that figure before the next capital cycle closes. Without it, the utility cannot quantify its regulatory exposure under Ontario's evolving reliability reporting requirements, nor can it defend deferral decisions to the OEB with confidence.

Analytical Limitations

The loss-avoidance figure of \$2.8 million per year and the 3.62 times lifetime ROI are derived from the project-level data provided; independent validation against Alectra's outage management system and asset condition records has not been confirmed in this summary. Climate hazard projections used to size these investments typically carry a range of uncertainty across emissions scenarios, and actual avoided losses could be higher or lower depending on how quickly extreme-weather frequency accelerates relative to the planning assumptions embedded in the model.

One Move for the Next Budget Cycle

The board should formally approve capital allocation for the three unfunded recommended projects in the next budget cycle, drawing on the \$50000000 million of uncommitted plan capacity, and should require staff to attach a quantified residual-risk figure (in customer-hours and dollar terms) to each deferral decision going forward. Locking in that commitment now, while the ROW and substation work is still in early execution, allows Alectra to sequence contractor capacity efficiently and avoids the cost premium that typically accompanies reactive post-event remediation.

DATA PROVENANCE

● CLIMATE HAZARDS

● CITY DEMOGRAPHICS

● ASSET CATALOG

● ASSET LOCATIONS

● UTILITY LOAD BASELINE

● PORTFOLIO

● SUMMARY

● LIVE API

● FROZEN SNAPSHOT

● MODELED

● LLM NARRATIVE

SOURCES

● LIVE

NRCan Historical Flood Events (Esri Living Atlas): empirical flood probability applied to 5 of 5 asset(s)

● LIVE

NRCan CWFIS National Fire Database (Esri Living Atlas): empirical wildfire probability applied to 5 of 5 asset(s)

● LIVE ArcGIS GeoEnrichment (Esri Canada): Mississauga, ON (CY): 192,532 households, population 768,433

● FROZEN Utility asset filings (Hydro One, Toronto Hydro, EPCOR, Hydro-Québec)

● FROZEN CCCS (Canadian Centre for Climate Services) hazard scenarios

● FROZEN Insurance Bureau of Canada loss data

● FROZEN ECCC historical weather extremes

