

Test Verification of Conformity

Verification Number: 2405B1550SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Schneider Merlin Gerin Low Voltage (Tianjin) Co., Ltd. No.66 Muning Road, TEDA, Tianjin, P.R.China
Manufacturing site Name & Address:	Same as applicant
Product Description: Ratings & Principle Characteristics:	Low Voltage Circuit-breakers Ue= 12-60V~, 100-133V~, 220-240V~(1P), 12-133V~, 220-240V~, 380-415V~, 440V~ (2P, 3P, 4P), Uimp=6kV, Ui=500V, Cat. A, 50/60Hz, iC65N, C-Type, Ie= 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63, 80A iC65H, C-Type(1-80A), D-Type(1-63A) Ie= 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63, 80A iC65L, C and D-Type Ie= 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A iC65*** (see page 2 for details)
Models/Type References: Brand Name(s):	
Standard(s)/Directive(s):	EN 60947-2:2017+A1:2020 Low Voltage Directive 2014/35/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2024-05-24 to 2024-07-05
Test Report Number(s):	2405B1550SHA-001



Signature

Name: Oliver Wei

Position: Manager

Date: 22 July 2024

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2405B1550SHA-V1.

iC65N					
Ph/Ph (2P, 3P, 4P)	12-133V~	220-240V~	380-415V~	440V~	Ics/Icu
Ph/N (1P)	12-60V~	100-133V~	220-240V~	-	
In	Icu				
1-4A	50kA	50kA	50kA	25kA	100%
6-40A	20kA	20kA	10kA	6kA	75%(≤415V~) 50%(440V~)
50-63A	15kA	15kA	10kA	6kA	50%
80A	/	/	6kA (230V~ for 1P, 400V~ for 2P, 3P, 4P)	/	100%
iC65H					
Ph/Ph (2P, 3P, 4P)	12-133V~	220-240V~	380-415V~	440V~	Ics/Icu
Ph/N (1P)	12-60V~	100-133V~	220-240V~	-	
In	Icu				
1-4A	70kA	70kA	70kA	50kA	100%
6-40A	30kA	30kA	15kA	10kA	50%
50-63A	20kA	20kA	15kA	10kA	50%
80A	/	/	10kA (230V~ for 1P, 400V~ for 2P, 3P, 4P)	/	75%
iC65L					
Ph/Ph (2P, 3P, 4P)	12-133V~	220-240V~	380-415V~	440V~	Ics/Icu
Ph/N (1P)	12-60V~	100-133V~	220-240V~	-	
In	Icu				
1-4A	100kA	100kA	100kA	70kA	100%
6-25A	50kA	50kA	25kA	20kA	50%
32-40A	50kA	50kA	25kA	15kA	50%
50-63A	30kA	30kA	20kA	10kA	37,5%(≤415V~) 50%(440V~)

Explanation of type designation iC65***:

1st * denotes the type of rated ultimate short-circuit breaking capacity Icu: N for 6kA, H for 10kA, L for 15kA

2nd * denotes the type of instantaneous tripping current: C for C- type, D for D- type

3rd * denotes the rated operational current Ie: 1A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A.



Signature

Name: Oliver Wei

Position: Manager

Date: 22 July 2024

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.