

Client Name	Energy Transfer
Project Name	This Meter Station
Revision	2013-06-06 - 08:24:07 AM
HMM Contact	Olin Valby - 281-598-9539

LEGEND



Changes made to this
revision

Current Quantities Per Site								Quantities Requested						
Mark No.	Unit	Description	Parker	Birdland	TEST	Total Qty.	Quantity Left to Acquire	Current Client Invetory	Existing Material Supply	BRDLND	TST1234	RFRP1234	123258	123236
										6/6/2013	5/8/2013	5/1/2013	4/22/2013	4/21/2013
1	FT	PIPE - 24", 0.500" WT, ERW/DSAW, BE, API 5L PSL-2, X60, BARE	17			17	0	17	0		17			
88	FT	PIPE - 20", 0.500" WT, ERW/DSAW, BE, API 5L PSL-2, X60, BARE		17		17	0	17	0	17				
2	FT	PIPE - 16", 0.500" WT, ERW/DSAW, BE, API 5L PSL-2, X52, BARE	19	19		38	-21	59	0	19	19	21		
3	FT	PIPE - 12", 0.375" WT, ERW/SMLS, BE, API 5L PSL-2, X52, BARE	17	17		34	-25	59	0	17	17	25		
4	FT	PIPE - 12", 0.375" WT, ERW/SMLS, BE, API 5L PSL-2, X52, COATED	113	113		226	0	226	0	111	115			
90	FT	PIPE - 10", 0.365" WT, ERW/SMLS, BE, API 5L PSL-2, X52, BARE TESTING	29	29		0	0	0	0					
80	FT	PIPE - 10", 0.322" WT, ERW/SMLS, BE, API 5L PSL-2, X42, COATED				0	-60	60	0				60	
6	FT	PIPE - 8", 0.322" WT, ERW/SMLS, BE, API 5L PSL-2, X42, BARE	1	1		2	-42	44	0			5	39	
5	FT	PIPE - 8", 0.322" WT, ERW/SMLS, BE, API 5L PSL-2, X42, COATED	6	6		12	6	6	0	6				
8	FT	PIPE - 6", 0.280" WT, ERW/SMLS, BE, API 5L PSL-2, GRB, BARE	3	3		6	0	6	0	3	3			
9	FT	PIPE - 6", 0.280" WT, ERW/SMLS, BE, API 5L PSL-2, GRB, COATED	29	29		58	0	58	0	29	29			
10	FT	PIPE - 4", 0.237" WT, ERW/SMLS, BE, API 5L PSL-2, GRB, BARE	13	13		26	-84	110	0	13	13	84		
79	FT	PIPE - 4", 0.237" WT, ERW/SMLS, BE, API 5L PSL-2, GRB, COATED				0	-34	34	0			17	17	
11	FT	PIPE - 2", 0.218" WT, ERW/SMLS, BE, API 5L PSL-1, GRB, BARE	4	4		8	-51	59	0	4	4	51		
12	FT	PIPE - 1 1/2", 0.200" WT, SMLS, BE, ASTM A106, GRB, BARE	14	14		28	0	28	0	14	14			
13	FT	PIPE - 1", 0.179" WT, SMLS, BE, ASTM A106, GRB, BARE	1	1		2	0	2	0	1	1			
14	FT	PIPE - 3/4", 0.154" WT, SMLS, BE, ASTM A106, GRB, BARE	1	1		2	0	2	0	1	1			
15	FT	PIPE - 1/2", 0.147" WT, SMLS, BE, ASTM A106, GRB, BARE	1	1		2	0	2	0	1	1			
30	EA	TEE, STRAIGHT - 12", 0.375" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	1	1		2	0	2	0	1	1			
31	EA	TEE, STRAIGHT - 10", 0.365" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	1	1		2	0	2	0	1	1			
32	EA	TEE, REDUCING - 16", 0.500" WT x 12", 0.375" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	1	1		2	0	2	0	1	1			
33	EA	TEE, REDUCING - 12", 0.375" WT x 6", 0.280" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	1	1		2	-33	35	0	1	1			33
34	EA	TEE, REDUCING - 12", 0.375" WT x 4", 0.237" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	1	1		2	0	2	0	1	1			
35	EA	TEE, REDUCING - 8", 0.322" WT x 6", 0.280" WT, BW, MSS-SP-75, Y42, PER ASME B16.9	1	1		2	-1	3	0	1	1	1		
45	EA	ELL, 90 DEG - LR, 12", 0.375" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	2	2		4	-2	6	0	2	2	2		
46	EA	ELL, 90 DEG - LR, 10", 0.365" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	2	2		4	-2	6	0	2	2	2		
47	EA	ELL, 90 DEG - LR, 8", 0.322" WT, BW, MSS-SP-75, Y42, PER ASME B16.9	2	2		4	-2	6	0	2	2	2		
48	EA	ELL, 90 DEG - LR, 6", 0.28" WT, BW, ASTM A234, WPB, PER ASME B16.9	4	4		8	-4	12	0	4	4	4		
49	EA	ELL, 90 DEG - LR, 4", 0.237" WT, BW, ASTM A234, WPB, PER ASME B16.9	2	2		4	-2	6	0	2	2	2		

50	EA	ELL, 90 DEG - LR, 2", 0.218" WT, BW, ASTM A234, WPB, PER ASME B16.9	3	3		6	-3	9	0	3	3	3		
51	EA	ELL, 90 DEG - LR, 1 1/2", 0.200" WT, BW, ASTM A234, WPB, PER ASME B16.9	6	6		12	-6	18	0	6	6	6		
52	EA	ELL, 45 DEG - 3R, 10", 0.365" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	2	2		4	-2	6	0	2	2	2		
53	EA	REDUCER, CONC. - 20", 0.500" WT x 16", 0.375" WT, BW, MSS-SP-75, Y60, PER ASME B16.9	2	2		4	-2	6	0	2	2	2		
54	EA	REDUCER, CONC. - 12", 0.375" WT x 10", 0.365" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	1	1		2	-1	3	0	1	1	1		
55	EA	REDUCER, CONC. - 12", 0.375" WT x 8", 0.322" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	1	1		2	-1	3	0	1	1	1		
85	EA	REDUCER, CONC. - 6", 0.280" WT x 4", 0.237" WT, BW, ASTM A234, WPB, PER ASME B16.9				0	-3	3	0		3			
56	EA	REDUCER, ECC. - 12", 0.375" WT x 10", 0.365" WT, BW, MSS-SP-75, Y52, PER ASME B16.9	1	1		2	-1	3	0	1	1	1		
36	EA	FLANGE - 16", ANSI 600, RFWN, ASTM A694, F52, TWT 0.500" WT, X52 PIPE, PER MSS-SP-44	4	4		8	-4	12	0	4	4	4		
37	EA	FLANGE - 12", ANSI 600, RFWN, ASTM A694, F52, TWT 0.375" WT, X52 PIPE, PER MSS-SP-44	2	2		4	-2	6	0	2	2	2		
38	EA	FLANGE - 10", ANSI 600, RFWN, ASTM A694, F52, TWT 0.365" WT, X52 PIPE, PER MSS-SP-44	4	4		8	-4	12	0	4	4	4		
39	EA	FLANGE - 8", ANSI 600, RFWN, ASTM A694, F42, TWT 0.322" WT, X42 PIPE, PER MSS-SP-44	1	1		2	-1	3	0	1	1	1		
40	EA	FLANGE - 6", ANSI 600, RFWN, ASTM A105, GR B, TWT 0.280" WT, GR B PIPE, PER ASME B16.5	4	4		8	-4	12	0	4	4	4		
41	EA	FLANGE - 4", ANSI 600, RFWN, ASTM A105, GR B, TWT 0.237" WT, GR B PIPE, PER ASME B16.5	3	3		6	-3	9	0	3	3	3		
42	EA	FLANGE - 2", ANSI 600, RFWN, ASTM A105, GR B, TWT 0.218" WT, GR B PIPE, PER ASME B16.5	7	7		14	-49	63	0	7	7	7		42
43	EA	FLANGE - 1 1/2", ANSI 600, RFWN, ASTM A105, GR B, TWT 0.200" WT, GR B PIPE, PER ASME B16.5	6	6		12	-6	18	0	6	6	6		
44	EA	FLANGE, BLIND - 2", ANSI 600, RF, ASTM A105, GR B, PER ASME B16.5, CD&T FOR 1/2" NPT	3	3		6	-3	9	0	3	3	3		
20	EA	WELDOLET - 2" ON 20", BW, MSS-SP-75, F60, BONNEY FORGE OR EQUAL, PER MSS SP-97, -20°F TO 250°F	2	2		4	0	4	0	2	2			
21	EA	WELDOLET - 2" ON 12", BW, MSS-SP-75, F52, BONNEY FORGE OR EQUAL, PER MSS SP-97, -20°F TO 250°F	1	1		2	0	2	0	1	1			
22	EA	WELDOLET - 1 1/2" ON 20", BW, MSS-SP-75, F60, BONNEY FORGE OR EQUAL, PER MSS SP-97, -20°F TO 250°F	2	2		4	0	4	0	2	2			
23	EA	WELDOLET - 1 1/2" ON 16", BW, MSS-SP-75, F52, BONNEY FORGE OR EQUAL, PER MSS SP-97, -20°F TO 250°F	2	2		4	0	4	0	2	2			
24	EA	THREDOLET - 24" - 14" x 1-1/2", CLASS 3000, FNPT ASTM A105, BONNEY FORGE OR EQUAL, PER MSS SP-97, -20°F TO 250°F	2	2		4	0	4	0	2	2			
25	EA	THREDOLET - 12" - 8" x 1-1/2", CLASS 3000, FNPT ASTM A105, BONNEY FORGE OR EQUAL, PER MSS SP-97, -20°F TO 250°F	4	4		8	0	8	0	4	4			
16	EA	CLOSURE, HORIZONTAL - 20.000" OD, ANSI 600, TWT 0.500" WT, X60 PIPE, YALE OR EQUIV.	2	2		4	0	4	0	2	2			
17	EA	CLOSURE, HORIZONTAL - 12.750" OD, ANSI 600, TWT 0.375" WT, X52 PIPE, YALE OR EQUIV.	1	1		2	0	2	0	1	1			
18	EA	CLOSURE, HORIZONTAL - 4.500" OD, ANSI 600, TWT 0.237" WT, GR B PIPE, YALE OR EQUIV.	1	1		2	0	2	0	1	1			
19	EA	CLOSURE, HORIZONTAL - 2.375" OD, ANSI 600, TWT 0.218" WT, GR B PIPE, YALE OR EQUIV.	2	2		4	0	4	0	2	2			
26	EA	SADDLE, WELD 6" ON 20", 5/8" THK, HDR EDGE TAPERED TO 0.280", W/VENT HOLE, MSS-SP-75, Y65, PER FLEETLINE CATALOG SFI-105 & ASME B31.8	2	2		4	0	4	0	2	2			
27	EA	SADDLE, WELD 4" ON 12", 5/8" THK, HDR EDGE TAPERED TO 0.237", W/VENT HOLE, MSS-SP-75, Y52, PER FLEETLINE CATALOG SFI-105 & ASME B31.8	1	1		2	0	2	0	1	1			

28	EA	SADDLE, WELD 4" ON 10", 5/8" THK, HDR EDGE TAPERED TO 0.237", W/VENT HOLE, MSS-SP-75, Y52, PER FLEETLINE CATALOG SFI-105 & ASME B31.8	1	1		2	0	2	0	1	1			
29	EA	SADDLE, WELD 2" ON 20", 5/8" THK, HDR EDGE TAPERED TO 0.218", W/VENT HOLE, MSS-SP-75, Y65, PER FLEETLINE CATALOG SFI-105 & ASME B31.8	2	2		4	0	4	0	2	2			
65	EA	PLUG, HEXHEAD, 1", 3000#, MNPT, ASTM A105, PER ASME B16.11	2	2		4	-2	6	0	2	2	2		
66	EA	PLUG, HEXHEAD, 3/4", 3000#, MNPT, ASTM A105, PER ASME B16.11	2	2		4	-2	6	0	2	2	2		
67	EA	PLUG, HEXHEAD, 1/2", 3000#, MNPT, ASTM A105, PER ASME B16.11	3	3		6	-3	9	0	3	3	3		
68	EA	VALVE, PLUG - 1 1/2", ANSI 600, RF, API 6D, ASTM A216 WCB, REGULAR PATTERN, FOR SWEET NATURAL GAS SERVICE, -20°F TO 120°F, LEVER OPERATED C/W LOCKING DEVICE, CLEANED AND PAINTED W/ SHOP PRIMER	3	3		6	-3	9	0	3	3	3		
69	EA	VALVE, BALL - 16", ANSI 600, RF, API 6D, FULL PORT, DOUBLE BLOCK & BLEED, FOR SWEET NATURAL GAS SERVICE, -20°F TO 120°F, LESS LEVER FOR MOUNTING VALVE OPERATOR, CLEANED AND PAINTED W/ SHOP PRIMER	1	1		2	-1	3	0	1	1	1		
70	EA	VALVE, BALL - 12", ANSI 600, RF, API 6D, FULL PORT, DOUBLE BLOCK & BLEED, FOR SWEET NATURAL GAS SERVICE, -20°F TO 120°F, LESS LEVER FOR MOUNTING VALVE OPERATOR, CLEANED AND PAINTED W/ SHOP PRIMER	1	1		2	-1	3	0	1	1	1		
71	EA	VALVE, BALL - 10", ANSI 600, RF, API 6D, FULL PORT, DOUBLE BLOCK & BLEED, FOR SWEET NATURAL GAS SERVICE, -20°F TO 120°F, LESS LEVER FOR MOUNTING VALVE OPERATOR, CLEANED AND PAINTED W/ SHOP PRIMER	2	2		4	-2	6	0	2	2	2		
72	EA	VALVE, BALL - 6", ANSI 600, RF, API 6D, FULL PORT, DOUBLE BLOCK & BLEED, FOR SWEET NATURAL GAS SERVICE, -20°F TO 120°F, LEVER OPERATED, C/W LOCKING DEVICE, CLEANED AND PAINTED W/ SHOP PRIMER	2	2		4	-2	6	0	2	2	2		
73	EA	VALVE, BALL - 4", ANSI 600, RF x WE, FULL PATTERN, API 6D, FULL PORT, LEVER OPERATED, C/W LOCKING DEVICE, TWT 4" OD, 0.237" WT, GRB PIPE	1	1		2	-1	3	0	1	1	1		
74	EA	VALVE, BALL - 4", ANSI 600, RF, API 6D, FULL PORT, DOUBLE BLOCK & BLEED, FOR SWEET NATURAL GAS SERVICE, -20°F TO 120°F, LEVER OPERATED, C/W LOCKING DEVICE, CLEANED AND PAINTED W/ SHOP PRIMER	1	1		2	-1	3	0	1	1	1		
75	EA	VALVE, BALL - 2", ANSI 600, RF, API 6D, FULL PORT, DOUBLE BLOCK & BLEED, FOR SWEET NATURAL GAS SERVICE, -20°F TO 120°F, LEVER OPERATED, C/W LOCKING DEVICE, CLEANED AND PAINTED W/ SHOP PRIMER	5	5		10	-5	15	0	5	5	5		
76	EA	VALVE, BALL - 1", CLASS 3000, W.O.G., THRD, FNPT, C.S, SS TRIM, FULL PORT, NATURAL GAS SERVICE, C/W LEVER OPERATOR & LOCKING DEVICE	2	2		4	-2	6	0	2	2	2		
77	EA	VALVE, BALL - 3/4", CLASS 3000, W.O.G., THRD, FNPT, C.S, SS TRIM, FULL PORT, NATURAL GAS SERVICE, C/W LEVER OPERATOR & LOCKING DEVICE	2	2		4	-2	6	0	2	2	2		
78	EA	VALVE, BALL - 1/2", CLASS 3000, W.O.G., THRD, FNPT, C.S, SS TRIM, FULL PORT, NATURAL GAS SERVICE, C/W LEVER OPERATOR & LOCKING DEVICE	3	3		6	-3	9	0	3	3	3		
57	EA	GASKET, SPIRAL WOUND - 16", ANSI 600, RF, FLEXITALLIC, STYLE CGI OR EQUAL, 304 SS WINDING WITH GRAPHITE FILLER, 304 SS OUTER & INNER RING, 1/8" THK. FOR MSS-SP-44 FLANGE	4	4		8	-4	12	0	4	4	4		
58	EA	GASKET, SPIRAL WOUND - 12", ANSI 600, RF, FLEXITALLIC, STYLE CGI OR EQUAL, 304 SS WINDING WITH GRAPHITE FILLER, 304 SS OUTER & INNER RING, 1/8" THK. FOR MSS-SP-44 FLANGE	2	2		4	-2	6	0	2	2	2		
59	EA	GASKET, SPIRAL WOUND - 10", ANSI 600, RF, FLEXITALLIC, STYLE CGI OR EQUAL, 304 SS WINDING WITH GRAPHITE FILLER, 304 SS OUTER & INNER RING, 1/8" THK. FOR MSS-SP-44 FLANGE	4	4		8	-4	12	0	4	4	4		

60	EA	GASKET, SPIRAL WOUND - 8", ANSI 600, RF, FLEXITALLIC, STYLE CGI OR EQUAL, 304 SS WINDING WITH GRAPHITE FILLER, 304 SS OUTER & INNER RING, 1/8" THK. FOR MSS-SP-44 FLANGE	1	1		2	-1	3	0	1	1	1		
61	EA	GASKET, SPIRAL WOUND - 6", ANSI 600, RF, FLEXITALLIC, STYLE CGI OR EQUAL, 304 SS WINDING WITH GRAPHITE FILLER, 304 SS OUTER & INNER RING, 1/8" THK. FOR ASME B16.5 FLANGE	4	4		8	-4	12	0	4	4	4		
62	EA	GASKET, SPIRAL WOUND - 4", ANSI 600, RF, FLEXITALLIC, STYLE CGI OR EQUAL, 304 SS WINDING WITH GRAPHITE FILLER, 304 SS OUTER & INNER RING, 1/8" THK. FOR ASME B16.5 FLANGE	3	3		6	-3	9	0	3	3	3		
63	EA	GASKET, SPIRAL WOUND - 2", ANSI 600, RF, FLEXITALLIC, STYLE CGI OR EQUAL, 304 SS WINDING WITH GRAPHITE FILLER, 304 SS OUTER & INNER RING, 1/8" THK. FOR ASME B16.5 FLANGE	10	10		20	-10	30	0	10	10	10		
64	EA	GASKET, SPIRAL WOUND - 1 1/2", ANSI 600, RF, FLEXITALLIC, STYLE CGI OR EQUAL, 304 SS WINDING WITH GRAPHITE FILLER, 304 SS OUTER & INNER RING, 1/8" THK. FOR ASME B16.5 FLANGE	6	6		12	-6	18	0	6	6	6		