



ADA Curb Ramp New Construction Inspection Form (Parallel)

North-South Road Name

Project No.

Sheet No.

Intersection No.

East-West Road Name

See https://www.oregon.gov/odot/Engineering/Documents_RoadwayEng/ADA_ExhibitA.pdf for more corner styles.
Use Washington County corner numbering system.

Calibration Date

(mm/dd/yy)

Ramp Style

*The passing value for Gutter Flow Slope (GFS) depends on the Intersection Control Type. At a Midblock (MB), GFS must be \leq Slope of the Road, at Signalized or Uncontrolled (SU), GFS must be $\leq 5.0\%$, and at Stop or Yield (SY), GFS must be $\leq 2.0\%$.

*1 If Back of Ramp Obstruction is Yes, turn space length Y must be minimum 5.0 ft.

*2 Clear Space area is the width of Ramp Run 1 and extends 4.0 ft into the roadway.

See also Standard Drawings to assess provisions not shown: (inlets, alignment, etc.)




PARALLEL RAMP (PL)

PARALLEL RAMP (PL)

- Pedestrian Access Route (to measure Clear Width)
- Detectable Warning Surface
- Cross Slope (2.0% max.)
- Running Slope (8.3% max.)
- Counter Slope (5.0% max.)
- Turning Space (X & Y) (2.0% max. / 4' x 4' min.)*
* If constrained at back of walk, min. Y length is 5'.
- Gutter Flow Slope (as directed)

	Pass	Fail
RAMP RUN 1		
Running Slope 1	$\leq 2.0\%$	$> 2.0\%$
Cross Slope 1	$\leq 2.0\%$	$> 2.0\%$
Detectable Warning	Y	N
Lip Height	$\leq 1/4"$	$> 1/4"$
Gutter Flow Slope	$\leq *$	$> *$
Curb Running Slope ^(avg)	$\leq 8.3\%$	$> 8.3\%$
Counter Slope (+/-)* ²	$\leq 5.0\% $	$> 5.0\% $
Det. warning full width of ramp	Y	N
RAMP RUN 2		
Running Slope 2	$\leq 8.3\%$	$> 8.3\%$
Length 2		
Cross Slope 2	$\leq 2.0\%$	$> 2.0\%$
RAMP RUN 3		
Running Slope 3	$\leq 8.3\%$	$> 8.3\%$
Length 3		
Cross Slope 3	$\leq 2.0\%$	$> 2.0\%$
TURN SPACE		
Width X	$\geq 4.0'$	$< 4.0'$
Length Y	$\geq 4.0'^{*1}$	$< 4.0'^{*1}$
Back of Ramp Obstruction (Y/N)	$\geq 5.0'^{*1}$	$< 5.0'^{*1}$
Slope X (Cross Slope 1)	$\leq 2.0\%$	$> 2.0\%$
Slope Y (Running Slope 1)	$\leq 2.0\%$	$> 2.0\%$
MISCELLANEOUS		
Clear Width (feet)	$\geq 4.0'$	$< 4.0'$
Intersection Control Type	Slope of Rd.	
Horizontal Gaps	$\leq 1/2"$	$> 1/2"$



	PE Stamp (required for private development)
--	---

Comments:

Inspector's Signature	Date (mm/dd/yy)
Print name clearly	Certification No.
Company/Agency	

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed