



ADA Curb Ramp New Construction Inspection Form (Parallel)

North-South Road Name

Project No.

Sheet No.

Intersection No.

East-West Road Name

See https://www.oregon.gov/odot/Engineering/Documents_RoadwayEng/ADA_ExhibitA.pdf for more corner styles.
Use Washington County corner numbering system.

Calibration Date

(mm/dd/yy)


Ramp Style

*The passing value for Gutter Flow Slope (GFS) depends on the Intersection Control Type. At a Midblock (MB), GFS must be \leq Slope of the Road, at Signalized or Uncontrolled (SU), GFS must be $\leq 5.0\%$, and at Stop or Yield (SY), GFS must be $\leq 2.0\%$.

*¹ If Back of Ramp Obstruction is Yes, turn space length Y must be minimum 5.0 ft.

*² Clear Space area is the width of Ramp Run 1 and extends 4.0 ft into the roadway.

See also Standard Drawings to assess provisions not shown:
(inlets, alignment, etc.)




PARALLEL RAMP (PL)

PARALLEL RAMP (PL)

- Pedestrian Access Route (to measure Clear Width)
- Detectable Warning Surface
- Cross Slope (2.0% max.)
- Running Slope (8.3% max.)
- Counter Slope (5.0% max.)
- Turning Space (X & Y) (2.0% max. / 4' x 4' min.)*
* If constrained at back of walk, min. Y length is 5'.
- Gutter Flow Slope (as directed)

RAMP RUN 1		Pass	Fail
Running Slope 1	$\leq 2.0\%$	$> 2.0\%$	
Cross Slope 1	$\leq 2.0\%$	$> 2.0\%$	
Detectable Warning	Y	N	
Lip Height	$\leq 1/4"$	$> 1/4"$	
Gutter Flow Slope	$\leq *$	$> *$	
Curb Running Slope ^(avg)	$\leq 8.3\%$	$> 8.3\%$	
Counter Slope (+/-) ^{*2}	$\leq 5.0\% $	$> 5.0\% $	
Det. warning full width of ramp	Y	N	
RAMP RUN 2		Pass	Fail
Running Slope 2	$\leq 8.3\%$	$> 8.3\%$	
Length 2	$\leq 2.0\%$	$> 2.0\%$	
RAMP RUN 3		Pass	Fail
Running Slope 3	$\leq 8.3\%$	$> 8.3\%$	
Length 3	$\leq 2.0\%$	$> 2.0\%$	
TURN SPACE		Pass	Fail
Width X	$\geq 4.0'$	$< 4.0'$	
Length Y	$\geq 4.0'*^1$	$< 4.0'*^1$	
Back of Ramp Obstruction (Y/N)	$\geq 5.0'*^1$	$< 5.0'*^1$	
Slope X (Cross Slope 1)	$\leq 2.0\%$	$> 2.0\%$	
Slope Y (Running Slope 1)	$\leq 2.0\%$	$> 2.0\%$	
MISCELLANEOUS		Pass	Fail
Clear Width (feet)	$\geq 4.0'$	$< 4.0'$	
Intersection Control Type	Slope of Rd.		
Horizontal Gaps	$\leq 1/2"$	$> 1/2"$	



PE Stamp (required for private development)
Comments:

Inspector's Signature

Date (mm/dd/yy)

Print name clearly

Certification No.

Company/Agency



ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed