
START
INPUT equipment_id
INPUT temperature (deg C)
INPUT vibration (mm/s)
temperature < 80?
True
OUTPUT: NORMAL: Equipment operating within defined monitoring limits.
False
temperature <= 100?
True
OUTPUT: WARNING: Equipment temperature approaching predefined threshold.
False
OUTPUT: CRITICAL: Equipment temperature exceeds predefined threshold.
OUTPUT: Inspection required
vibration < 5?
True
OUTPUT: NORMAL: Equipment operating within defined monitoring limits.
False
vibration <= 8?
True
OUTPUT: WARNING: Equipment vibration approaching predefined threshold.
False
OUTPUT: CRITICAL: Equipment vibration exceeds predefined threshold.
OUTPUT: Inspection required
OUTPUT Equipment ID
END