CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT

CPRI

Test Report Number : **CPRIBPLSTNBMISC22T0128** **Date: 23 May 2022**

Name and Address of the Customer	:	APEX Marketing 3/5 Tower, L. Road, Bistupur, Jamshedpur, East Singhbhum, Jharkhand, 831006
Name and Address of the Manufacturer	:	APEX Marketing 3/5 Tower, L. Road, Bistupur, Jamshedpur, East Singhbhum, Jharkhand, 831006
Particulars of sample tested	:	LT Panel (Non-Extendable) 415 V, 6000A
Type	:	Power Cum Motor Control Centre
Description of test sample	:	Refer sheet 2 of 6
Serial Number	:	APEX/70k
Number of samples tested	:	One
Date(s) of Test(s)	:	29 April 2022
CPRI Sample code Number(s)	:	STNBMISC22S0130
Particulars of tests conducted	:	Verification of the short circuit withstand strength
Test in accordance with Standard/Specification	:	As per customer's requirement and procedure generally followed as per cl.10.11.5.3.3 & 10.11.5.3.5 of IS/IEC:61439-1,2011 & IS/IEC:61439-2, 2011
Sampling Plan	:	Nil
Customer's Requirement	:	SCWS test to be conducted only on busbars.
Deviations if any	:	SCWS test was conducted only on busbars.
Name of the witnessing persons		
Customers representative	:	Mr. Aman Thakur
Other than customer's representatives	:	None
Test subcontracted with address of the laboratory	:	Nil

Documents constituting this report (in words)

Number of Sheets	:	Six
Number of Oscillogram(s)	:	Two
Number of Graph(s)	:	Nil
Number of Photograph(s)	:	One
Number of Test Circuit Diagram(s)	:	Two
Number of Drawing(s)	:	Three

(Saumitra Pathak)
Test Engineer

(Himangshu Roy)
Head of Division
Reviewed and Authorized by