CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT

CPRI

Test Report Number	:	**CPRINOAHV22T0171** **Date: 27 April 2022**
Name and Address of the Customer	:	M/s Apex Marketing 3/5, Tower, L. Road, Bistupur, Jemshedpur, East Singhbhum, Jharkhand-831001.
Name and Address of the Manufacturer	:	M/s Apex Marketing 3/5, Tower, L. Road, Bistupur, Jemshedpur, East Singhbhum, Jharkhand-831001.
Particulars of sample tested	:	415V, 4000Amps, LT Panel
Type	:	Main Distribution Panel
Description of test sample	:	Refer sheet 2 of 6
Serial Number	:	APEX/40TR
Number of samples tested	:	One
Date(s) of Test(s)	:	26 April 2022
CPRI Sample code Number(s).	:	NOAHV22S0158
Particulars of tests conducted	:	Refer sheet 3 of 6
Test in accordance with Standard/Specification	:	IS/IEC 61439-1: 2011 & IS/IEC 61439-2: 2011
Sampling Plan	:	None
Customer's Requirement	:	Temp. rise limit on busbar & busbar joints is to be 70K
Deviations if any	:	Nil
Name of the witnessing persons		
Customers representative	:	Nil
Other than customer's representatives	:	Nil
Test subcontracted with address of the laboratory	:	

Documents constituting this report (in words)

Number of Sheets	:	Five
Number of Oscillogram(s)	:	Nil
Number of Graph(s)	:	Nil
Number of Photograph(s)	:	One
Number of Test Circuit Diagram(s)	:	Nil
Number of Drawing(s)	:	Three

(Sandeep Singh)
Test Engineer

(M.K.Jaiswal)
Head of Division
Reviewed and Authorized by