CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT

CPRI

Test Report Number	: **CPRIBPLSTNC25T0368**	**Date: 22 October 2025**
Name and Address of the Customer	: M/s Apex Marketing, Bistupur , 3/5, H.S. Tower, Jamshedpur, East Singhbhum, Jharkhand - 831 001	
Name and Address of the Manufacturer	: M/s Apex Marketing, Bistupur , 3/5, H.S. Tower, Jamshedpur, East Singhbhum, Jharkhand - 831 001	
Particulars of Sample tested	: 415V, 1600A, LT Distribution Panel	
Type	: Outdoor	
Description of test sample	: 415V, 1600A, LT Distribution Panel	
Serial Number	: AM/LT/2502/2024-25	
Number of Sample tested	: One	
Date(s) of Test(s)	: 13 August 2025	
CPRI sample code number(s)	: STNBMISC25S0221	
Particulars of test(s) conducted	: 1) Dielectric Properties 1.1) Impulse Withstand voltage Test. 1.2) Power Frequency Voltage Withstand Test. 1.3) External operation handles of insulating materials.	
Test in accordance with Standard/specification	: IEC 61439-1: 2020 & IEC 61439-2: 2020	
Sampling Plan	: Nil	
Customer's Requirement	: Nil	
Deviations, if any	: Nil	
Name of the witnessing persons		
Customer's Representatives	: Mr. Sumit Kumar Ghosh & Mr. Jitendra Singh	
Other than Customer's Representatives	: Nil	
Test subcontracted with address of the laboratory	: None	
Documents constituting this report (in words)		
No. of Sheet(s)	: Seven	
No. of Oscillogram(s)	: Four	
No. of Graph(s)	: Nil	
No. of Photograph(s)	: Two	
No. of Test Circuit Diagram(s)	: Nil	
No. of Drawing(s)	: Five	

Manish Keshari

(Manish Kumar Keshari)
Test Engineer

(Sarita Dongre)
Head of Division
Reviewed and Authorized By

CENTRAL POWER RESEARCH INSTITUTE

CPRI

TEST REPORT

Test Report Number	:	**CPRIBPLSTNC25T0251** **Date: 02 July 2025**
Name and Address of the Customer	:	M/s Apex Marketing, Bistupur, 3/5, H.S. Tower, Jamshedpur East Singhbhum, Jharkhand, - 831 001
Name and Address of the Manufacturer	:	M/s Apex Marketing, Bistupur, 3/5, H.S. Tower, Jamshedpur East Singhbhum, Jharkhand, - 831 001
Particulars of Sample tested	:	415V, 1600A, LT Distribution Panel
Type	:	1600A LT PDB
Description of test sample	:	415V, 1600A, LT Panel
Serial Number	:	AM/LT/2502/2024-25
Number of Sample tested	:	One
Date(s) of Test(s)	:	17 June 2025 To 19 June 2025
CPRI sample code number(s)	:	STNBMISC25S0221
Particulars of test(s) conducted	:	1) Mechanical operation. 2) Marking. 3) Lifting. 4) Clearances and Creepage Distances
Test in accordance with Standard/specification	:	IEC 61439-1: 2020 & IEC 61439-2: 2020.
Sampling Plan	:	Nil
Customer's Requirement	:	Nil
Deviations, if any	:	Nil
Name of the witnessing persons		
Customer's Representatives	:	Mr. Sumit Kumar Ghosh & Mr. Jitendra Singh Rajput
Other than Customer's Representatives	:	Nil
Test subcontracted with address of the laboratory	:	None
Documents constituting this report (in words)		
No. of Sheet(s)	:	Eight
No. of Oscillogram(s)	:	Nil
No. of Graph(s)	:	Nil
No. of Photograph(s)	:	Two
No. of Test Circuit Diagram(s)	:	Nil
No. of Drawing(s)	:	Five

manish keshari

(Manish Kumar Keshari)
Test Engineer

(Sarita Dongre)
Head of Division
Reviewed and Authorized By

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT

CPRI

Test Report Number	:	CPRIBPLSTNC25T0176 Date: 26 May 2025
Name and Address of the Customer	:	M/s. Apex Marketing, Bistupur, 3/5 H.S. Tower, L-Road Bistupur-831 001, Jamshedpur, East Singhbhum, Jharkhand.
Name and Address of the Manufacturer	:	M/s. Apex Marketing, Bistupur, 3/5 H.S. Tower, L-Road Bistupur-831 001, Jamshedpur, East Singhbhum, Jharkhand.
Particulars of Sample tested	:	415V, 1600A LT Distribution Panel
Type	:	1600A, LT PDB
Description of test sample	:	415V, 1600A LT Distribution Panel
Serial Number	:	AM/LT/2502/2024-25
Number of Sample tested	:	One
Date(s) of Test(s)	:	29 April 2025
CPRI sample code number(s)	:	STNBMISC25S0221
Particulars of test(s) conducted	:	Verification of protection against mechanical impact (IK 08).
Test in accordance with Standard/specification	:	IEC 61439-1: 2020 and IEC 61439-2: 2020
Sampling Plan	:	Nil
Customer's Requirement	:	Nil
Deviations, if any	:	Nil
Name of the witnessing persons		
Customer's Representatives	:	Mr. Sumit Kumar Ghosh, Mr. Jitendra Singh.
Other than Customer's Representatives	:	Nil
Test subcontracted with address of the laboratory	:	None
Documents constituting this report (in words)		
No. of Sheet(s)	:	Six
No. of Oscillogram(s)	:	Nil
No. of Graph(s)	:	Nil
No. of Photograph(s)	:	Two
No .of Test Circuit Diagram(s)	:	Nil
No. of drawing(s)	:	Five

Manish Keshari

(Manish Kumar Keshari)
Test Engineer

(Sarita Dongre)
Head of Division
Reviewed and Authorized By

TEST REPORT

CPRI

Test Report Number	:	CPRIBPLSTNC25T0252 — Date: 26 June 2025
Name and Address of the Customer	:	M/s Apex Marketing, 3/5, H.S. Tower, L. Road, Bistupur, Jamshedpur - 831 001
Name and Address of the Manufacturer	:	M/s Apex Marketing, 3/5, H.S. Tower, L. Road, Bistupur, Jamshedpur - 831 001
Particulars of Sample tested	:	Insulating Materials of 415V, 1600A, LT Distribution Panel i) FRP sheet for busbar support (Thickness 10mm) ii) Polyamide hexagonal insulator(M16)
Type	:	Nil
Description of test sample	:	Insulating Materials of 415V, 1600A, LT Distribution Panel i) FRP sheet for busbar support (Thickness 10mm) ii) Polyamide hexagonal insulator(M16)
Serial Number	:	Nil
Number of Sample tested	:	02 Nos. (1 No. Sample Each)
Date(s) of Test(s)	:	17 th & 18th June 2025
CPRI sample code number(s)	:	STNC25S0446 & STNC25S0447.
Particulars of test(s) conducted	:	Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects
Test in accordance with Standard/specification	:	IEC 61439 Part-1 & 2:2020
Sampling Plan	:	Nil
Customer's Requirement	:	Nil
Deviations, if any	:	Nil
Name of the witnessing persons Customer's Representatives	:	Mr. Sumit Kumar Ghosh
Other than Customer's Representatives	:	Nil
Test subcontracted with address of the laboratory	:	None

Documents constituting this report (in words)

No. of Sheet(s)	:	Six
No. of Oscillogram(s)	:	Nil
No. of Graph(s)	:	Nil
No. of Photograph(s)	:	One
No. of Test Circuit Diagram(s)	:	Nil
No. of Drawing(s)	:	One

Manish Keshari

(Manish Kumar Keshari)
Test Engineer

(Sarita Dongre)
Head of Division
Reviewed and Authorized By