



NOTES

- 1. Customer: Maria Delgado.
- 2. Inverter quantity: 1. Inverter: SolarEdge SE7600H-US, grid-support utility-interactive, UL 1741 SA listed.
- 3. Main service panel 200 A. 120% rule: 200 A main + 40 A PV breaker = 240 A <= 1.2 x 200 A busbar.
- 4. PV breaker sized at 125% of 32 A inverter max continuous output current = 40 A.
- 5. System exports to grid under Net Billing Tariff (NBT-1). No energy storage.
- 6. Rapid shutdown per NEC 690.12 via SolarEdge optimizers. All work per 2022 CEC and PG&E Greenbook.

SINGLE LINE DIAGRAM SLD-1 rev A

Customer: Maria Delgado

2147 Brookwood Avenue, Santa Rosa, CA 95404

Redwood Valley Solar & Electric (fictional)

PV system: 8.0 kW DC / 7.6 kW AC

Drawn: D. Whitfield Date: 09/03/2026

Scale: NTS