

NRC REFINERY COMPLEX — MONTHLY INSPECTION DOSSIER (FEBRUARY 2026)

Asset: Distillation Unit 7 | Operating Pressure: 42.1 PSI | Feed: 51,200 BPD

Ultrasonic Thickness: Shell Course 3 measured at 10.45 mm. Rapid thickness degradation of 0.75 mm detected in 30 days.

Safety Review: PRV-701A exhibited premature leakage. Urgent inspection recommended.