

LT-CT METERS TEST REPORT

ORIGINAL

Sl. No. **5637**

Date 18/10/2024

Sc. No. 2921-1721

Name of the Consumer Smt. Arimilli Sita

Cat/Load II / 26KW

Distribution : Praddutur

Section Mokila

Sub Division : Mokila

Type of Load Non-Domestic Division : Pbrazhimbagh

Service inspected for the purpose of periodical test / Releasing of new service / Meter charge /

Challenge Test Service Released as per E-2024-65-01-13-01-019

CTs Make Continental Ratio 200/5A SI.Nos. R 8433 Y 966E B 8536 N 8539

OLD			PARTICULARS	NEW		
			Meter Make	Genius, IPDA		
			Meter Sl. No.	7195133, 6/24		
			Meter Type / Class / Const	03C-682/0.5S/500		
			Initial Reading : KWH	00		
			KVAH	00.		
			MD	-		
			Final Reading : KWH	28		
			KVAH	28		
			MD	0.24, 17/10/24, 15:00		
			MF			
			MD Button Seal	A 0310367		
			MRI Seal	-		
			Meter Cover Seal	368		
			Meter Terminal Cover Seal	369, 370		
			Test Terminal Box Seal	371, 372		
			Meter Board Seal	373, 374		
			CTs Chamber Seal	Ax283		
			Meter Box Seal			
R	Y	B	Meter Test Results	R	Y	B
			Voltage with Neutral (Volts)	245	248	247
			Current in Meter (Amps)	9.1	9.4	9.1
			Current with Tong Tester (Amps)	9.1	9.4	9.1

Remarks : The Meter is Tested with ERS Meter with Consumer / 2 KW Heater Load and found an error of +0.04 %