Distributed-solar inverter inspection: Cedar Quay Solar Field

Revision v1. Record EV-SOL-02.

Site: Cedar Quay Solar Field; asset: grid-tied inverter B.

EV-SOL-02 Cedar Quay: grid-alarm voltage 228 V; review within 10 min.

during the storm watch, save the waveform and isolate the branch when the threshold is crossed; log readings in SOLAR-LOG-052.

LINK-013 control-room backup switch limit: 5 minutes.