Regional archive-room inspection: Cedar Quay Archive Room

Revision v1. Record EV-ARC-02.

Site: Cedar Quay Archive Room; asset: paper-records room B.

EV-ARC-02 Cedar Quay: relative humidity for paper storage 45 %; review within 10 min.

during the storm watch, start dehumidification and recheck the sensor when outside the range; log readings in ARCHIVE-LOG-072.

LINK-016 control-room backup switch limit: 8 minutes.