



Hydrogen Leak Detection: Atmospheric Dispersion and Sensor Placement

Mr Rakesh Paleja: Shell Research Limited
Ms Aarti Nagarajan: Shell India Markets Private Limited
Dr Matthew Jones: Shell Research B.V
Dr Philip Jonathan: Shell Research Limited


Agenda

- ❑ Motivation
- ❑ Gaussian plume dispersion
- ❑ Sensor types
- ❑ Dispersion of hydrogen and sensor placement
- ❑ Conclusions and future work

Motivation

- ❑ Growing attention to Hydrogen (H_2) as an energy carrier and low carbon solution in energy transition to net zero
- ❑ Projected H_2 aspirations for some major economies*:
 - EU: 10 million tonnes of production and imports by 2030
 - UK: 5GW of production by 2030
 - China: 35 million tonnes by 2025¹
 - India : 5 million tonnes by 20230²
- ❑ Due to small size H_2 may be more prone to leak
- ❑ Motivation:
 - a)How does H_2 gas cloud disperse in the atmosphere?
 - b)What are the sensor technologies and what is their suitability for H_2 ?
 - c)How to spatially place sensors given the limitations of current technologies?
 - d)What are the emerging R&D topics?

* **Indicative aspirations in public domain**
Copyright of Shell Research Ltd



EU Hydrogen accelerator programme

https://energy.ec.europa.eu/topics/energy-systems-integration/hydrogen_en



<https://assets.publishing.service.gov.uk/government>

[t/uploads/system/uploads/attachment_data/file/1175494/UK-Hydrogen-Strategy_web.pdf](https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/1175494/UK-Hydrogen-Strategy_web.pdf) September 2023

175494/UK-Hydrogen-Strategy_web.pdf

Gaussian Plume Dispersion

- Advection diffusion equation⁴:

$$\frac{\partial C}{\partial t} = -\nabla \cdot (C\vec{u}) + \nabla \cdot (K\nabla C) + S \text{ (Equation 1)}$$

- Under steady state condition, concentration profile given by⁴:

$$C(x, y, z) = \frac{1e^6 Q}{2\pi\sigma_y\sigma_z\rho u 3600} \exp\left(-\frac{y^2}{2\sigma_y^2}\right) \left[\exp\left(-\frac{(z-H)^2}{2\sigma_z^2}\right) + \exp\left(-\frac{(z+H)^2}{2\sigma_z^2}\right) \right] \text{ (Equation 2)}$$

C : Concentration, ppm,

Q : Leak rate, kg/h

x, y, z : Distance in downwind, across wind and vertical direction, m

σ_y, σ_z : Horizontal and vertical standard deviations of emission distribution, m

u : Wind speed, m/s

ρ : Density, kg/m³

h : Release height, m

Δh : Plume elevation from release height, m

H : Plume centre line distance from ground level

Gaussian plume dispersion




Image from

https://www.researchgate.net/figure/Gaussian-plume-for-air-dispersion-model_fig1_267209805?vm=r

σ_y, σ_z and wind stability classes

- ❑ σ_y, σ_z linear function of downwind distance x and random shift in wind direction⁴
- ❑ Random shift expressed as standard deviation of wind angle θ_y, θ_z
- ❑ σ_y, σ_z specified as a function of x and θ_y, θ_z

$$\sigma_y(x) = x * \tan(\theta_y) + w \text{ (Equation 3)}$$

$$\sigma_z(x) = x * \tan(\theta_z) \text{ (Equation 4)}$$
- ❑ Generally for European locations, stability classes D and E are prevalent. Realistic u and θ_y, θ_z :

u : 3- 9 m/s

θ_y, θ_z : 3- 11°

Pasquill Class ⁷	θ , degrees ⁵
A-Extremely unstable	25
B-Moderately unstable	20
C-Slightly unstable	15
D-Neutral	10
E-Slightly stable	5
F-Moderately stable	2.5
G-Extremely stable	1.7

Wind speed	Daytime incoming solar radiation			Night time cloud cover	
	Strong	Moderate	Slight	>50%	<50%
m/s					
<2	A	A-B	B	E	F
2-3	A-B	B	C	E	F
3-5	B	B-C	C	D	E
5-6	C	C-D	D	D	D
>6	C	D	D	D	D

Class D applies with overcast skies at any windspeed during day or night⁷


Hydrogen Leak Detection : Sensor Types

Spot Sensors (e.g. Smoke detector)

- ❑ H_2 has to come in contact with the sensor
- ❑ Commercially available
- ❑ Sensor will detect if
 - Concentration of H_2 is above the lower measuring range also called low detection limit (LDL)
 - H_2 comes in contact with the sensor

Wide Area Sensors (e.g. Human eye, IR camera)

- ❑ H_2 does not come in contact with the sensor
- ❑ Not commercially available



Measuring range of spot sensors⁶



Most commercial spot sensors have $LDL \geq 1000$ ppm.

Few have $LDL = 10-100$ ppm

No commercial sensor with $LDL = 1$ ppm




Combining sensor property with Gaussian Plume Dispersion in 1-D

- ❑ Sensor selection function intrinsic property of the sensor and depends on its the lower detection limit (LDL)
- ❑ Pollutant concentration profile ($C_{(x,0,0)}$ or simply C_x) in downwind direction given by Equation 2 (Gaussian Plume dispersion)
- ❑ Combining the two provides useful information on sensor placement to detect a potential leak
- ❑ Distance at which the concentration is equal to LDL is the Maximum Distance from source at which the sensor can be placed
- ❑ Sensor place beyond Maximum Distance will lead to false negative alarm




Impact of Q , u and θ on Maximum Distance in 1-D

- Realistic Q and u and θ for most prevalent wind stability class assumed in simulation
- $H = 4\text{m}$, open space. Potential leak sources are known
- C_x can be derived analytically but not the Max Distance
- Adverse wind conditions (high u and θ_y, θ_z) reduce Max Distance



Sensor placement in 1-D: Threshold leak rate




- ❑ All possible cases of Q considered for most adverse wind conditions ($u = 10 \text{ m/s}$, $\theta_y, \theta_z = 11^\circ$) to determine conservative Maximum Distance
- ❑ Not all leaks can be detected by current technology
- ❑ A “threshold” leak rate can be used to understand sensor placement in downwind direction
- ❑ Sensor placement at Maximum Distance in downwind direction is a function of sensor’s LDL, threshold leak rate and wind properties





Dispersion in 2-D plane

- ❑ Dispersion in 2-D plane for threshold rate coupled with sensor LDL determine co-ordinates in a plane
- ❑ Wind direction also changes over time
- ❑ A single sensor can lead to false negative (no alarm when there is a leak) with unfavourable wind direction
- ❑ Multiple sensors required to cover change in wind direction

Typical wind direction profile Manchester⁸



Colours show concentration (on log scale) above sensor's LDL.




Colours show concentration (on log scale) above sensor's LDL.



Sensor placement in 2-D (x-y) plane

- ❑ Historic wind direction data and sensor LDL useful for sensor placement in x-y plane and maximize probability of leak detection
- ❑ With three sensors limit, for prevalent wind directions, maximum distance is 30 m (1 ppm LDL) or 1.5 m (100 ppm)
- ❑ Sensor with 1000 ppm LDL not suitable to cover variation in wind direction
- ❑ Other factors such as permissible time between commencement of leak and detection play a role in number of sensors required

Typical wind direction profile Manchester⁸



Copyright of Shell Research




Δh and approximate adjustment for 3-D sensor placement

- ❑ $H = h + \Delta h$ (H = Centre line, h = release height, Δh = rise in centre line from release height)
- ❑ Buoyancy (F) and Advection (governed by u) counter each other to determine Δh , rise of plume from release height to h . Other factors* play a role
- ❑ Derivation of Δh ⁹ useful in determining lift in centre line and height , H at which sensors should be placed to maximise leak detection probability

$$F = Qg \text{ (Equation 5)}$$

$$\Delta h = \frac{1.6F^{0.33}x^{0.66}}{u} \text{ (Equation 6)}$$

- ❑ Units of measurement:
 F : m⁴/s³, Q :m³/s, g : m/s²
- ❑ Effective 3-D placement thus covered using dispersion properties and sensor LDL



* Other factors that determine Δh are release pressure & temperature, ambient temperature gradient in vertical direction, size of leak etc

Conclusions and future research areas

- ❑ It is possible to understand spot sensor placement in 3-D using Gaussian Plume dispersion and Sensor's Low Detection Limit (LDL) for open space application with potential leak sources known
- ❑ For wind conditions prevalent in Europe, sensors with lower LDL provide flexibility and additional degree of freedom in placement strategy
- ❑ Buoyancy is complex, needs to be fully understood
- ❑ R&D efforts to develop spot sensors with LDL ~1ppm will help to develop sustainable pathway for green hydrogen economy
- ❑ Development of appropriate wide area sensing technology can lead to significant reduction false negatives

References

- 1: Center for Strategic and International Studies. (2022). *China Unveils Its First Long Term Hydrogen Plan*. Retrieved from CSIS: <https://www.csis.org/analysis/china-unveils-its-first-long-term-hydrogen-plan>
- 2: Reuters. (2022). *India plans to produce 5 mln tonnes of green hydrogen by 2030*. Retrieved from <https://www.reuters.com/business/energy/india-plans-produce-5-mln-tonnes-green-hydrogen-by-2030-2022-02-17/#:~:text=India%20will%20set%20up%20separate%20manufacturing%20zones%2C%20waive,to%20incentivise%20production%2C%20the%20federal%20power%20ministry%2>
- 3: ARUP. (2023). *Five minutes guide to Hydrogen*. Retrieved from ARUP: <https://www.arup.com/perspectives/publications/promotional-materials/section/five-minute-guide-to-hydrogen>
- 4: Stockie, J. M. (2011). The Mathematics of Atmospheric Dispersion Modelling. *Society Of International Applied Mathematics*, 349-372. doi:10.1137/10080991X
- 5: NOAA Air Resource Laboratory (2023). *PG classes for fluctuations in wind direction and vertical temperature gradient*. Retrieved from <https://www.ready.noaa.gov/READYpgclass.php>
- 6: Brett, L. B. (2010). Identifying performance gaps in hydrogen safety sensor technology for automotive and stationary applications. *International Journal Of Hydrogen Energy*, 373-384.
- 7: Kahl, J. (2018). Atmospheric stability of characterisation using the Pasquill method. A critical evaluation. *Atmospheric Environment*, 196-209. doi:<https://doi.org/10.1016/j.atmosenv.2018.05.058>
- 8: Weather Archive (2023) *Weather archive in Manchester*. Retrieved from World Weather: https://world-weather.info/archive/united_kingdom/manchester_1/