New York ISO
Independent System Operator

NYISO Winter 2023 Operating Study Report

Raj Dontireddy

Manager, Operations Engineering (NYISO)

Operating Committee(OC):
November 16, 2023

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED

Topics

- Changes in Generation
- Changes in Transmission
- Changes in Operating Capabilities
- Anticipated Interface Limit Changes

New York ISO

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED

Generation Deactivations Since Winter 2022-23

Astoria GT Groups 2, 3, & 4	-558 MW
Ravenswood 10	-25 MW
Ravenswood 01	-19 MW
74th St. GT 1 & 2 (Local Reliability Only)	-37 MW
TOTAL	**-639 MW**

New York ISO

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED

Generation Additions Since Winter 2022-23

South Fork Wind I & II	136 MW
East Point Solar	50 MW
Homer Solar Energy Center	90 MW
Puckett Solar	20 MW
Regan Solar	20 MW
Grissom Solar	20 MW
Total	**336 MW**

New York ISO

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED

Changes in Transmission Since Winter 2022-23

- **Modeled out-of-service**
  - East 13th Street (BK17) 345/69 kV transformer modeled out of service
  - East 13th Street (TR4) 138/69 kV transformer modeled out of service
  - Pleasant Valley – Wood Street (F31) 345 kV line modeled out of service
  - Wood Street – Millwood (W81) 345 kV line modeled out of service
  - West 49th Street (TR4) 345/138/ kV Transformer modeled out of service
  - Fraser SVC modeled out of service
  - Adirondack – Porter (12) 230kV line modeled out of service
  - Willis – Patnode (WPN-1) 230 kV line modeled out of service
  - Moses– Willis (MW1) 230 kV line modeled out of service
- **Modeled in-service**
  - Sprainbrook – East Garden City (Y49) 345 kV modeled in service
  - Eastview – Grassland (38W52) 138 kV line returned in service
  - Eastview – Elmsford (38W34) 138 kV line returned in service
  - Moses (AT2) 230/115 kV transformer returned in service
  - Moses – Adirondack (MA1) 230 kV line returned in service

New York ISO

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED

Additions in Transmission Since Winter 2022-23

- **Addition**
  - Segment A Project
    - Princetown Station
  - Segment B
    - Knickerbocker Station
    - Van Wagner Station
  - Corona – Rainey (R5W) 138 kV PAR
  - Corona – Rainey (36188) 138kV line
  - Rainey (5W) 345/138 kV Transformer

New York ISO

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED

Changes in Internal Thermal Transfer Limits

Winter 2023-24 /Winter 2022-23

(1) Dysinger East
(2) West Central Reverse
(3) Total East
(4) Central East
(5) UPNY-ConEd
(6) Sprn / Dun – South
(7) ConEd – LIPA
(8) Moses South



New York ISO

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED

Changes in Internal Thermal Transfer Limits

- **Dysinger East** interface thermal transfer limit decreased by 400 MW. This is mainly due to the change in schedule of the Dysinger PAR from 100 MW in Winter 2022-23 period to 400 MW in Winter 2023-24.
- **Total East** interface thermal transfer limit increased by 1525 MW. This is mainly due to the modeling of Segment A & B project.
- **Central East** interface thermal transfer limit increased by 1825 MW. This is mainly due to the modeling of Segment A & B project.
- **UPNY-ConEd** interface thermal transfer limit decreased by 525 MW This is mainly due to the modeling of Pleasant Valley – Wood Street (F31) 345 kV and Wood Street – Millwood (W81) 345 kV lines out-of-service.
- **ConEd-LIPA** interface thermal transfer limit increased by 675 MW. This is mainly due to the return of Sprainbrook – East Garden City (Y49) 345 kV line to in-service.
- **Moses South** interface thermal transfer limit decreased by 850 MW. This is mainly due to the modeling of Adirondack – Porter (12) 230 kV, Moses – Willis (MW1) 230 kV, and Willis – Patnode (WPN-1) 230 kV lines out-of-service.

New York ISO

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED

Changes in External Thermal Transfer Limits



New York ISO

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED

Changes in External Thermal Transfer Limits

- **ISO-NE – NYISO** interface thermal transfer limit decreased by 225 MW. This is mainly due to the return of Sprainbrook – East Garden City (Y49) 345 kV line to in-service.
- **NYISO – PJM** interface thermal transfer limit increased by 250 MW. This is mainly due to the change in dispatch assumption of PJM.
- **PJM – NYISO** interface thermal transfer limit increased 75 MW. This is mainly due to the redistribution of flows due to the Segment A & B project.
- **IESO – NYISO** thermal transfer limit increased by 75 MW. This is mainly due to the change in schedule of the Dysinger PAR.
- **NYISO – IESO** thermal transfer limit decreased by 100 MW. This is mainly due to the change in schedule of the Dysinger PAR.

New York ISO

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED

Questions?

© COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED.

New York ISO

Our Mission & Vision

Mission

Ensure power system reliability and competitive markets for New York in a clean energy future

Vision

Working together with stakeholders to build the cleanest, most reliable electric system in the nation

New York ISO

©COPYRIGHT NYISO 2023. ALL RIGHTS RESERVED