Memo: Dairy plant ammonia refrigeration (new ice cream line, floating head pressure)

2026-10-29 11:15 +03 · DRAFT, not approved

Decision asked for: Can the ammonia plant take a new ice cream line (+700 kW refrigeration, 2,400 to 3,100 kW) with N+1 on compressors, what limits first, and how much electricity a year would floating head pressure save?

Recommendation: no change to the plant is needed. Plant handles new load; floating saves yearly. At 129 % throughput every stated limit is within 100 % in the simulation.

Cost class: not stated.

Risk: the open-weights second opinion disagreed on: annual energy saving: 1,716 vs 1,330 MWh; units.C-101A.P_out_bar: only the open model changes it; units.C-101B.P_out_bar: only the open model changes it. Relief findings on changed equipment: 0.

Measure next: the first 24 h at the new throughput against the model's predicted values.

Full decision file and PSSR checklist (1 items) attached. Audit head `1655c5620726`.