中国认可
检测
TESTING
CNAS L18645

Test report

No：CIC-RJ-CC261436-02A

Product Name：CNT CONDUCTIVE TILE

Model：/

Size：600×600×2(mm)

Applicant：QingDao In Tech Trade Co.,Ltd.

Manufacturer：DOOHA CO.,LTD. (KOREA)

MII Anti-Static Products Quality Supervision &Testing Center

Saisheng Laboratory ,China Industrial Control Systems Cyber Emergency Response Team

扫描全能王 创建

Note：

1. This report is invalid without "anti-counterfeiting mark", "seal for sewing" and "special seal for testing".

2. This report is invalid without the signature (seal) of the testing, auditing and approving person.

3. This report is invalid if it is altered or copied at will, and cannot be copied without the written approval of the laboratory (except the full copy).

4. The data results in this report are only valid for the tested samples.

5. The sample information of this test report is provided for customers, and our center is not responsible for the authenticity.

6. The report is valid for one year for Scan cover QR code inquiry 10 days after the date of issue.

Testing unit：MII Anti-Static Products Quality Supervision &Testing Center

Saisheng Laboratory ,China Industrial Control Systems Cyber Emergency Response Team

Address：No.35 Lugu Road, Shijingshan District Beijing ,China

Postal Code：100040

Tel：+86-10-68869773/68865301

Website：www.cics-cert.org.cn

Email：cicesd@163.com

扫描全能王 创建

Product Name	CNT CONDUCTIVE TILE		
Address	No. 808, Haiyun Dongfang, 15 Qinling Road, Laoshan District, Qingdao City, Shandong Province, China		
Submitter	Huang Donglong	**Tel**	13953291817
Test category	Commission test	**Quantity of Samples**	7 pcs
Date of sample arrival	Aug.21,2026	**Date of testing**	Aug.24,2026、Aug.28,2026
Structure characteristics	Material: PVC+CNT(Carbon Nanotube) Structure: CNT(Carbon Nanotube) Homogeneous Transparent Network Structure; Color: White carbon grid		
Test Items	Point-to-point resistance, Point to groundable point resistance		
Test Standard	ANSI/ESD STM7.1-2020		
Determination Standard	ANSI/ESD S20.20-2021		
Apparatus	625 temperature and humidity sensor (FJ-69), 152-1 surface resistance tester (FJ-72)		
Testing Environment	（1）Temperature: 23.0℃ Relative Humidity: 12.0%RH （2）Temperature: 23.0℃ Relative Humidity: 50.0%RH		
Test Conclusion	The test results show that the inspection items meet the requirements of ANSI/ESD S20.20-2021. Issue Date: Sep.01,2026		
Remarks	/		

Authorized by: Zhao Guanghui **Approved by:** Fan Zengjie **Tested by:** Lu Ling

扫描全能王 创建

Summary of Test Results

（1）**Testing Environment：** Temperature: 23.0℃ Relative Humidity: 12.0%RH

Sample state adjustment: The sample has been conditioned for 72 hours under environmental conditions of temperature 23.0 ℃ and humidity 12.0% RH.

S/N	Test Item(s)	Unit	Specification	Test Result(s)		Conclusion
1	Point-to-point resistance	Ω	ANSI/ESD S20.20-2021 $<1.0\times10^{9}\Omega$	A	B	Pass
				7.01×10^{5}	6.22×10^{5}	
				8.91×10^{5}	7.41×10^{5}	
				9.01×10^{5}	6.91×10^{5}	
				6.21×10^{5}	7.22×10^{5}	
				5.44×10^{5}	6.49×10^{5}	
				5.71×10^{5}	8.01×10^{5}	
				Maximum :9.01×10^{5} Minimum :5.44×10^{5}		
2	Point to groundable point resistance	Ω	ANSI/ESD S20.20-2021 $<1.0\times10^{9}\Omega$	A	B	Pass
				6.04×10^{5}	5.41×10^{5}	
				7.33×10^{5}	5.99×10^{5}	
				8.10×10^{5}	6.22×10^{5}	
				4.21×10^{5}	6.10×10^{5}	
				4.22×10^{5}	5.21×10^{5}	
				5.22×10^{5}	5.01×10^{5}	
				Maximum :8.10×10^{5} Minimum :4.21×10^{5}		

CNAS

扫描全能王 创建

Summary of Test Results

（2）Testing Environment： Temperature: 23.0℃ Relative Humidity: 50.0%RH

Sample state adjustment: The sample has been conditioned for 72 hours under environmental conditions of temperature 23.0 ℃ and humidity 50.0% RH.

S/N	Test Item(s)	Unit	Specification	Test Result(s)		Conclusion
3	Point-to-point resistance	Ω	ANSI/ESD S20.20-2021 ＜$1.0\times10^9\Omega$	A	B	Pass
				5.61×10^5	6.01×10^5	
				4.11×10^5	5.71×10^5	
				4.26×10^5	5.20×10^5	
				3.77×10^5	4.90×10^5	
				3.92×10^5	4.91×10^5	
				5.99×10^5	6.44×10^5	
				Maximum :6.44×10^5 Minimum :3.77×10^5		
4	Point to groundable point resistance	Ω	ANSI/ESD S20.20-2021 ＜$1.0\times10^9\Omega$	A	B	Pass
				5.15×10^5	6.07×10^5	
				5.26×10^5	6.22×10^5	
				5.79×10^5	6.31×10^5	
				5.01×10^5	5.22×10^5	
				4.20×10^5	5.42×10^5	
				4.01×10^5	5.10×10^5	
				Maximum :6.31×10^5 Minimum :4.01×10^5		

Note: The test voltage is DC10V.

(The following blanks)

CNASTC

扫描全能王 创建