

Design-day facility power: 43.7 kW against a 150 kW IT load $\Rightarrow$ PUE = 1.291



■ Compressor bank 32.12 kW (73%) ■ Dry cooler fans 7.91 kW (18%) ■ Glycol loop pump 2.57 kW (6%) ■ CHW/CRAH pump 1.11 kW (3%)