

Design-day facility power: 46.0 kW against a 150 kW IT load $\Rightarrow$ PUE = 1.307



■ Compressor bank 31.72 kW (69%) ■ Dry cooler fans 10.60 kW (23%) ■ Glycol loop pump 2.56 kW (6%) ■ CHW/CRAH pump 1.11 kW (2%)