[SYNTHETIC REGULATION - NOT FOR COMPLIANCE USE] Doc: SYNTH-BATT-2022-RevA

CHAPTER 1 GENERAL SCOPE

Clause 1.1 (Purpose) This synthetic regulation specifies safety requirements for industrial lithium battery packs.

CHAPTER 2 ELECTRICAL AND THERMAL REQUIREMENTS

Clause 2.1 (Overcharge Cutoff) Under normal load, overcharge cutoff response time shall not exceed 500 ms.

Clause 3.1 (Enclosure Clearance) In Chapter 2 cabinets, minimum clearance distance under rated load shall be at least 12 mm

Clause 4.1 (Small Module Exemption) Battery modules under 100 Wh shall be exempted from thermal runaway propagation te

Clause 5.1 (Legacy NiCd Venting) Legacy vented nickel-cadmium cells shall include alkaline mist traps.

ANNEX A ENVIRONMENTAL AND VIBRATION TESTS

Clause 3.1 (Vibration Sweep Test) In Annex A testing, packs shall pass vibration per IEC 62619:2017 without leakage.

Clause 6.1 (Effective Date) This regulation enters into force on 2023-05-01.