

Enclosure '4A'
(Refer Para 3(f) of SOC)

TECHNICAL SPECIFICATION OF 8.5 TON PACKAGE AC UNIT

S No	Description	Specification
(i)	Rating	8.5 Ton Package AC Unit
(ii)	Operating Voltage	380-420 V AC
(iii)	Nominal Frequency	50 Hz
(iv)	No. of Phases	Three Phase
(v)	Cooling	Forced Air Cooled
(vi)	No of Compressors	02
(vii)	Display Parameters	Suction Pressure, Discharge Pressure, fault alarms and Data logger
(viii)	Safety	High pressure Cutout (HP), Low pressure Cutout (LP), Over Current
(ix)	Copper Tubing	Copper tubing for suction and discharge lines from indoor unit to outdoor unit.
(x)	Electrical Control Panel	Electrical control panel for switching On/Off of ACs with in-built Digital Ammeter and Voltmeter
(xi)	Auto Changeover	Auto Changeover Panel required for auto changeover of ACs

Date: 12 Mar 25


(Rashmi Rawat)
Wg Cdr
CO 725 SU, AF

ADDITIONAL TERMS AND CONDITIONSPROCUREMENT, INSTALLATION AND COMMISSIONING OF 8.5 TON PACKAGE AIR CONDITIONER UNIT QTY-04 AT AIR FORCE STATION JAMMU

1. GeM platform provides option under "Additional Terms and Conditions" after finalizing the technical specifications. The following documents are essential to be uploaded by seller on GeM for consideration of the firm in TEC: -

(a) **GST Registration Certificate**. The Firm should have valid GST Registration number and Assessed Copy of the same should be uploaded.

(b) **PAN Card**. Firm should have valid PAN card in the name of Firm or in the name of proprietor of the Firm in case of proprietary Firm (Copy is to be enclosed).

(c) **OEM Certificate**. In case the seller is not the OEM, the authorization certificate with the OEM for sourcing the spares shall be mandatory uploaded.

2. **Schedule of Requirement**. List of items/ services required for procurement, installation and commissioning of 8.5 ton Package Air Conditioner unit Qty-04 at Air Force Station Jammu: -

S No	Description	Specification
1.	Rating	8.5 Ton Package AC Unit
2.	Operating Voltage	380-420 V AC
3.	Nominal Frequency	50 Hz
4.	No. of Phases	Three Phase
5.	Cooling	Forced Air Cooled
6.	No of Compressors	02
7.	Display Parameters	Suction Pressure, Discharge Pressure, fault alarms and Data logger
8.	Safety	High pressure Cutout (HP), Low pressure Cutout (LP), Over Current
9.	Copper Tubing	Copper tubing for suction and discharge lines from indoor unit to outdoor unit.
10.	Electrical Control Panel	Electrical control panel for switching On/Off of ACs with in-built Digital Ammeter and Voltmeter
11.	Auto Changeover	Auto Changeover Panel required for auto changeover of ACs

3. **Scope of Work**. procurement, installation and commissioning of 8.5 ton Package Air Conditioner unit Qty-04 at Air Force Station Jammu as per technical specification and parameters as under mentioned.

TECHNICAL SPECIFICATIONS

S No	Description	Specification
1.	Rating	8.5 Ton Package AC Unit
2.	Operating Voltage	380-420 V AC
3.	Nominal Frequency	50 Hz
4.	No. of Phases	Three Phase
5.	Cooling	Forced Air Cooled
6.	No of Compressors	02
7.	Display Parameters	Suction Pressure, Discharge Pressure, fault alarms and Data logger
8.	Safety	High pressure Cutout (HP), Low pressure Cutout (LP), Over Current
9.	Copper Tubing	Copper tubing for suction and discharge lines from indoor unit to outdoor unit.
10.	Electrical Control Panel	Electrical control panel for switching On/Off of ACs with in-built Digital Ammeter and Voltmeter
11.	Auto Changeover	Auto Changeover Panel required for auto changeover of ACs

- (i) Requirement of training/on-job training: **Yes**
- (ii) Requirement of installation/commissioning: **Yes**
- (iii) Requirement of Factory Acceptance Trials (FAT): **Test Report after complete installation needs to be handed over to user.**
- (iv) Requirement of Technical documentation: **Equipment Manual to handed over to user.**
- (v) Nature of assistance required after completion of warranty: **Yes**

4. **Compliance to Specification in Two-Bid System.** Bidders are required to furnish clause-by-clause compliance of specifications bringing out clearly the deviations from specification, if any. The bidders are advised to submit the compliance statement in the following form along with Technical Bid.

TEC FORMAT: CLEAR CUT PARAMETERS/ QRS

Sl. No.	Indor/ sample	Essential QRs (serially Listed)	Brand/ Make & Model	Comp liance (Yes/ No)	Remarks
(a)	PACKAGE AIR CONDITIONING UNITS				
	Rating	8.5 Ton Package AC Unit			
	Operating Voltage	380-420 V AC			
	Nominal Frequency	50 Hz			
	No.of Phases	Three Phase			
	Cooling	Forced Air Cooled			
	No of Compressors	02			
	Display Parameters	Suction Pressure, Discharge Pressure, fault alarms and Data logger			
	Safety	High pressure Cutout (HP), Low pressure Cutout (LP), Over Current			
	Copper Tubing	Copper tubing for suction and discharge lines from indoor unit to outdoor unit.			
	Cables And Connectors				
	Air Ducts Supply Air		(3'x1.5')x100'		
	Air Ducts Return Air		(2'x1')x110'		
	Electrical cables as per required Rating suggested by OEM				
(b)	Air Ducts Grills		08		
	Air Dampers		04		
	Electrical control panel for switching On/Off of ACs with MCCBs of rating suggested by OEM and in-built Digital Ammeter and Voltmeter		03		
	Auto Changeover Panel required for auto changeover of ACs		02		
(c)	Installation, Commissioning and Training				
	Installation of Ducts required breaking of walls at several places followed by cement work after installation of ducts.				
(d)	Pre-Bid Visit at Site				
	Bidder to visit site before participating in Bid for assessment of the task to be undertaken.				

(Note: Clear Cut Parameters / QRs to be filled in as per para 3 & 4 of this custom bid (terms & condition) proposed by Bidder. TEC format to form a part of the tender documents to provide for transparent technical criterion.)

5. **Technical documentation.** All technical literature needs to be attached in respect of items supplied by the seller.

6. **Delivery period.** The stores are considered to have been delivered only when, these are handed over to the consignee after due inspection by the designated inspecting agency. Delivery period for supply would be **30 days** from the effective date of contract and the project should be completed within **60 days** of the signing of contract. Please note the Buyer can cancel that contract unilaterally in case items are not received within the contracted delivery period. **Extension of contracted delivery period will be at the sole discretion of the Buyer, with applicability of LD clause.**

7. **Effective Date of the Contract.** Normally the contract shall come into effect on the date of signatures of both the parties on the contract except when some other effective date is mutually agreed to and specifically indicated / provided in the contract. The deliveries, supplies, and performance of the services shall commence from the effective date of the contract.

8. **Liquidated Damages.** In the event of the Seller's failure to submit the bonds, guarantees and documents, supply the stores/goods and conduct trials, installation of equipment, training etc. as specified in this contract, the Buyer may, at his discretion, withhold any payment until the completion of the contract. The Buyer may also deduct from the Seller as agreed, liquidated damages to the sum of **0.5%** of the contract price of the delayed/undelivered stores/services mentioned above for every week of delay or part of a week, subject to the maximum value of the liquidated damages being not higher than **10%** of the value of delayed stores/services.

9. **Termination of Contract.** The Buyer shall have the right to terminate this Contract in part or in full in any of the following cases: -

(a) The delivery of the material is delayed for causes not attributable to Force Majeure for more than three months after the scheduled date of delivery.

(b) The Seller is declared bankrupt or becomes insolvent.

(c) The delivery of material is delayed due to causes of Force Majeure by more than (six months).

(d) The Buyer has noticed that the Seller has utilised the services of any Indian/Foreign agent in getting this contract and paid any commission to such individual/company etc.

(e) As per decision of the Arbitration Tribunal.

10. **Performance Bank Guarantee (PBG).** The Bidder will be required to furnish a Performance Guarantee by way of Bank Guarantee through any of commercial bank authorized to conduct government business, for a sum equal to **3% of the contract value** in favour of **Air Force Public Fund accounts, Jammu** within 30 days of receipt of the confirmed order. Performance Bank Guarantee should be valid up to 60 days beyond the date of warranty. This obviates the need to obtain a fresh Warranty Bank Guarantee from the supplier on commencement of the warranty period, with corresponding return of the Performance Guarantee.

11. **Tolerance Clause.** To take care of any change in the requirement during the starting from issue of ATC till placement of the contract, Buyer reserves the right to **20% plus/minus** increase or decrease the quantity of the required goods up to that limit without any change in the terms & conditions and prices quoted by the Seller. While awarding the contract, the quantity ordered can be increased or decreased by the Buyer within this tolerance limit. Period.

12. **Payment Terms.** It will be mandatory for the Bidders to indicate their bank account numbers and other relevant payment details so that payments could be made through ECS/NEFT mechanism instead of payment through cheques, wherever feasible. A copy of the model mandate form prescribed by RBI to be submitted by bidders for receiving payments through ECS is at Form DPM-11 (Available in MoD website and can be given on request). The payment will be made as per the following terms, on production of the requisite documents: -

TEC FORMAT: CLEAR CUT PARAMETERS/ QRS

Sl. No.	Vendor/ sample	Essential QRs (serially Listed)	Brand/ Make & Model	Compliance (Yes/ No)	Remarks
(a)	PACKAGE AIR CONDITIONING UNITS				
	Rating	8.5 Ton Package AC Unit			
	Operating Voltage	380-420 V AC			
	Nominal Frequency	50 Hz			
	No. of Phases	Three Phase			
	Cooling	Forced Air Cooled			
	No of Compressors	02			
	Display Parameters	Suction Pressure, Discharge Pressure, fault alarms and Data logger			
	Safety	High pressure Cutout (HP), Low pressure Cutout (LP), Over Current			
	Copper Tubing	Copper tubing for suction and discharge lines from indoor unit to outdoor unit.			
	Cables And Connectors				
	Air Ducts		736 Cu Ft		
	Electrical cables as per required Rating suggested by OEM				
	Air Ducts Grills		08		
(b)	Air Dampers		04		
	Electrical control panel for switching On/Off of ACs with MCCBs of rating suggested by OEM and in-built Digital Ammeter and Voltmeter		03		
	Auto Changeover Panel required for auto changeover of ACs		02		
(c)	Installation, Commissioning and Training				
	Installation of Ducts required breaking of walls at several places followed by cement work after installation of ducts.				
(d)	Pre-Bid Visit at Site				
	Bidder to visit site before participating in Bid for assessment of the task to be undertaken.				

(Note: Clear Cut Parameters / QRs to be filled in as per para 3 & 4 of this custom bid (terms & condition) proposed by Bidder. TEC format to form a part of the tender documents to provide for transparent technical criterion.)

5. **Technical documentation.** All technical literature needs to be attached in respect of items supplied by the seller.

6. **Delivery period.** The stores are considered to have been delivered only when, these are handed over to the consignee after due inspection by the designated inspecting agency. Delivery period for supply would be **30 days** from the effective date of contract and the project should be completed within **60 days** of the signing of contract. Please note the Buyer can cancel that contract unilaterally in case items are not received within the contracted delivery period. **Extension of contracted delivery period will be at the sole discretion of the Buyer, with applicability of LD clause.**

7. **Effective Date of the Contract.** Normally the contract shall come into effect on the date of signatures of both the parties on the contract except when some other effective date is mutually agreed to and specifically indicated / provided in the contract. The deliveries, supplies, and performance of the services shall commence from the effective date of the contract.
8. **Liquidated Damages.** In the event of the Seller's failure to submit the bonds, guarantees and documents, supply the stores/goods and conduct trials, installation of equipment, training etc. as specified in this contract, the Buyer may, at his discretion, withhold any payment until the completion of the contract. The Buyer may also deduct from the Seller as agreed, liquidated damages to the sum of **0.5%** of the contract price of the delayed/undelivered stores/services mentioned above for every week of delay or part of a week, subject to the maximum value of the liquidated damages being not higher than **10%** of the value of delayed stores/services.
9. **Termination of Contract.** The Buyer shall have the right to terminate this Contract in part or in full in any of the following cases: -
- (a) The delivery of the material is delayed for causes not attributable to Force Majeure for more than three months after the scheduled date of delivery.
 - (b) The Seller is declared bankrupt or becomes insolvent.
 - (c) The delivery of material is delayed due to causes of Force Majeure by more than (six months).
 - (d) The Buyer has noticed that the Seller has utilised the services of any Indian/Foreign agent in getting this contract and paid any commission to such individual/company etc.
 - (e) As per decision of the Arbitration Tribunal.
10. **Performance Bank Guarantee (PBG)** The Bidder will be required to furnish a Performance Guarantee by way of Bank Guarantee through any of commercial bank authorized to conduct government business, for a sum equal to **3% of the contract value** in favour of **Air Force Public Fund accounts, Jammu** within 30 days of receipt of the confirmed order. Performance Bank Guarantee should be valid up to 60 days beyond the date of warranty. This obviates the need to obtain a fresh Warranty Bank Guarantee from the supplier on commencement of the warranty period, with corresponding return of the Performance Guarantee.
11. **Tolerance Clause.** To take care of any change in the requirement during the starting from issue of ATC till placement of the contract, Buyer reserves the right to **20% plus/minus** increase or decrease the quantity of the required goods up to that limit without any change in the terms & conditions and prices quoted by the Seller. While awarding the contract, the quantity ordered can be increased or decreased by the Buyer within this tolerance limit. Period.
12. **Payment Terms.** It will be mandatory for the Bidders to indicate their bank account numbers and other relevant payment details so that payments could be made through ECS/NEFT mechanism instead of payment through cheques, wherever feasible. A copy of the model mandate form prescribed by RBI to be submitted by bidders for receiving payments through ECS is at Form DPM-11 (Available in MoD website and can be given on request). The payment will be made as per the following terms, on production of the requisite documents: -

(Available in MoD website and can be given on request). The payment will be made as per the following terms, on production of the requisite documents: -

(a) **90%** on receipt and acceptance/inspection of all stores by means of JRI (Joint Receipt Inspection) and satisfactory installation and testing of the complete project.

(b) Balance **10%** will be paid on rendering satisfactory performance report by user.

13. **Advance Payments.** No advance payment will be made.

14. **Earliest Acceptable Year of Manufacture.** **2025(Year)**, quality/life certificate need to be enclosed with the bill.

15. **Quality.** The quality of the stores delivered according to the present contract shall correspond to the technical conditions and standards valid for the deliveries of the same stores for in Seller's country or specifications enumerated as per term and backward integrated and interchangeable with same equipment supplied by the Seller in the past if any. The Seller shall supply an interchangeability certificate along with the changed part numbers wherein it should be mentioned that item would provide as much life as the original item condition for the proposal and shall also include therein modification to the stores suggested by the Buyer. Such modifications will be mutually agreed to. The Seller confirms that the stores to be supplied under this Contract shall be new i.e. not manufactured before (Year of contract), and shall incorporate all the latest improvements and modifications thereto and spares of improved and modified equipment are.

16. **Quality Assurance.** Seller would provide the standard acceptance test procedure (ATP) within **02 months** of this date of contract. Buyer reserves the right to modify the ATP. The item should be of the latest manufactured, confirming to the current production standard and having 100% defined life at the time of delivery.

17. **Warranty.** The following Warranty will form part of the contract placed on the successful Bidder:

(a) The Seller warrants that the goods supplied under the contract confirm to technical specifications prescribed and shall perform according to the said technical specifications.

(b) The Seller warrants for a period of **36 (Thirty-Six) months** from the date of installation and commissioning, that the goods/stores supplied under the contract and each component used in the manufacture thereof shall be free from all types of defects/failures.

(c) If within the period of warranty, the goods are reported by the Buyer to have failed to perform as per the specifications, the Seller shall either replace or rectify the same free of charge, within a maximum period of **30 (Thirty)** days of notification of such defect received by the Seller, provided that the goods are used and maintained by the Buyer as per instructions. Warranty of the UG cable would be extended by such duration of downtime. Record of the downtime would be maintained by the user in the Logbook. Spares required for warranty repairs shall be provided free of cost by the Seller. The Seller also undertakes to diagnose, test and repair/replace the cable for any fault

arising due to accidents by neglect or misuse or damage due to transportation of the cable during the warranty period, at the cost mutually agreed between the Buyer and Seller.

(d) The Seller shall associate technical personnel for maintenance during warranty and shall provide the details of complete defects, reasons and remedial action for defects.

(e) If particular equipment/goods fails frequently and/or, the cumulative downtime exceeds **5%** of the warranty period, the complete equipment shall replace free of cost by the Seller within a stipulated period of **60 days** of receipt of the notification from the date of acceptance after Joint Receipt Inspection by the Buyer/date of installation and commissioning.

(f) In case the complete delivery of Engineering Support Package is delayed beyond the period stipulated in this contract, the Seller undertakes that the warranty period for the goods/stores shall be extended to that extent.

18. **Product Support.** The following Product Support clause will form part of the contract placed on successful Bidder: -

(a) The Seller agrees to provide Product Support for the stores, assemblies/ subassemblies, fitment items and consumables, Special Maintenance Tools(SMT)/ Special Test Equipment (STE) subcontracted from other agencies/manufacturer by the Seller for a minimum period of **10 years** including **03 years** of warranty period after the delivery of item.

(b) The Seller agrees to undertake Maintenance Contract for a minimum period of **07 years**, extendable till the complete Engineering Support Package is provided by the Seller.

(c) In the event of any obsolescence during the above mentioned period of product support in respect of any component or sub-system, mutual consultation between the Seller and Buyer will be undertaken to arrive at an acceptable solution including additional cost, if any.

(d) Any improvement/modification/upgradation being undertaken by the Seller or their sub suppliers on the stores/equipment being purchased under the Contract will be communicated by the Seller to the Buyer and, if required by the Buyer, these will be carried out by the Seller at Buyer's cost.

19. **Annual Maintenance Contract (AMC) Clause.** The following AMC clause will form part of the contract placed on successful Bidder:

(a) The Seller would provide comprehensive AMC with spares per annum of the hardware cost of the project, for a period of **07 years** (Negotiable during PNC), which will be applicable after expiry of warranty period of **03 years**. The AMC services should cover the repair and maintenance of all the equipment and systems purchased under the present Contract. The Buyer Furnished Equipment which is not covered under the purview of the AMC should be separately listed by the Seller. The AMC services would be provided in two distinct ways:

(i) **Preventive Maintenance Service.** The Seller will provide a minimum of four Preventive Maintenance Service visits during a year to the operating base to carry out functional checkups and minor adjustments/ tuning as may be required.

(ii) **Breakdown maintenance Service.** In case of any breakdown of the equipment/system, on receiving a call from the Buyer, the Seller is to provide maintenance service to make the equipment/system serviceable.

(b) **Response Time.** The response time of the Seller should not exceed 24 hours from the time written breakdown intimation is provided by the Buyer.

(c) Serviceability of **95 %** per year is to be ensured. This amounts to total maximum downtime of **18 days** per year. Also un-serviceability should not exceed **07 days** at one time. Required spares to attain this serviceability may be stored at site by the Seller at his own cost. Total down time would be calculated at the end of the year. If downtime exceeds permitted downtime, LD would be applicable for the delayed period.

(d) Maximum repair turnaround time for repair of cable/accessories would be **02 days**. However, the spares should be maintained in a serviceable condition to avoid complete breakdown of communications.

(e) During the AMC period, the Seller shall carry out all necessary servicing/repairs to the cables under AMC **at the current location** of the cables. Prior permission of the Buyer would be required in case certain components/sub systems are to be shifted out of location. On such occasions, before taking over the goods or components, the Seller will give suitable bank guarantee to the Buyer to cover the estimated current value of Item being taken.

(f) The Buyer reserves its right to terminate the maintenance contract at any time without assigning any reason after giving a notice of **01 month**. The Seller will not be entitled to claim any compensation against such termination. However, while terminating the contract, if any payment is due to the Seller for maintenance services already performed in terms of the contract, the same would be paid to it as per the contract terms.

(g) The Buyer reserves its right to offer the maintenance contract (after warranty period) to any vendor and NOT compelled to offer the AMC to the seller.

20. **Maintenance Clause.** The following maintenance clause will form part of the contract placed on successful Bidder for the period of warranty:

(a) **Preventive Maintenance Service.** The Seller will provide a minimum of **two** Preventive Maintenance Service visits during a year to the operating base to carry out functional checkups and minor adjustments/ tuning as may be required.

(b) **Breakdown Maintenance Service.** In case of any breakdown of the equipment/ system, on receiving a call from the Buyer, the Seller is to provide maintenance service to make the equipment/system serviceable.

(c) **Response Time.** The response time of the Seller should not exceed **24 hours** from the time written breakdown intimation is provided by the buyer.

(d) Serviceability of **95%** per year is to be ensured. This amounts to total maximum downtime of **18 days** per year. Also unserviceability should not exceed **07 days** at one time.

21. **Evaluation Criteria.** The broad guidelines for evaluation of Bids will be:

(a) Only those Bids will be evaluated which are found to be fulfilling all the eligibility and qualifying requirements of the ATC, both technically and commercially.

(b) In respect of Two-Bid system, the technical Bids forwarded by the Bidders will be evaluated by the Buyer with reference to the technical characteristics of the equipment as mentioned in the ATC. The compliance of Technical Bids would be determined on the basis of the parameters specified in the ATC. The Price Bids of only those Bidders will be opened whose Technical Bids would clear the technical evaluation.

(c) The Lowest Bid will be decided upon the lowest price quoted by the particular Bidder. The consideration of taxes and duties in evaluation process will be as follows:

(i) L1 bidder will be determined by excluding levies, taxes and duties levied by Central/ State Govt such as GST etc on final product, as quoted by bidders.

(ii) **The Lowest vendor will be decided on the basis of total project cost excluding the cost of AMC.** The cost of AMC will be on the basis of cost of Hardware of the project.

(iii) The Buyer reserves its right to offer the maintenance contract (after warranty period) to any vendor and NOT compelled to offer the AMC to the Seller.

(d) If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price will prevail and the total price will be corrected. If there is a discrepancy between words and figures, the amount in words will prevail for calculation of price.

(e) The Lowest Acceptable Bid will be considered further for placement of contract/ Supply Order after complete clarification and price negotiations as decided by the Buyer. The Buyer also reserves the right to do Apportionment of Quantity, if it is convinced that Lowest Bidder is not in a position to supply full quantity in stipulated time.

(f) Any other criteria as applicable to suit a particular case.

22. **Modification and Withdrawal of Bids.** A bidder may modify or withdraw his bid after submission provided that the written notice of modification or withdrawal is received by the buyer prior to deadline prescribed for submission of bids. A withdrawal notice may be sent by fax but it should be followed by a signed confirmation copy to be sent by post and such signed confirmation should reach the purchaser not later than the deadline for submission of bids. No bid shall be modified after the deadline for submission of bids. No bid may be withdrawn in the interval between the deadline for submission of bids and expiration of the period of bid validity specified. Withdrawal of a bid during this period will result in Bidder's forfeiture of bid security.

23. **Clarification regarding contents of the Bids.** During evaluation and comparison of bids, the Buyer may, at its discretion, ask the bidder for clarification of his bid. The request for clarification will be given in writing and no change in prices or substance of the bid will be sought, offered or permitted. No post-bid clarification on the initiative of the bidder will be entertained.

24. **Rejection of Bids.** Canvassing by the Bidder in any form, unsolicited letter and post tender correction may invoke summary rejection with forfeiture of EMD. Conditional tenders will be rejected.

25. **Validity of Bids.** The Bids should remain valid till **180 days** from the last date of submission of the Bids by vendors. Bid life cycle may be extended on GeM Portal by user unit.

26. **Earnest Money Deposit.** Bidders are required to submit Earnest Money Deposit (EMD) for amount to **----N/A----** along with their bids in favor of **AIR FORCE PUBLIC FUND ACCOUNTS, JAMMU**. The EMD may be submitted in the form of a Fixed Deposit Receipt, Banker's Cheque or Bank Guarantee from any of commercial bank authorised to conduct government businesses per Form DPM-13 (Available in MoD website and can be provided on request). EMD is to remain valid for a period of 45 days beyond the final bid validity period. EMD of the unsuccessful bidders will be returned to them at the earliest after expiry of the final bid validity and latest on or before the 30th day after the award of the contract. The Bid Security of the successful bidder would be returned, without any interest whatsoever, after the receipt of Performance Security from them as called for in the contract. EMD is not required to be submitted by those Bidders who are registered with the Central Purchase Organization (e.g. DGS&D), National Small Industries Corporation (NSIC) or any Department of MoD or MoD itself for the same item/range of products, goods or services for which the tenders have been issued. The EMD will be forfeited if the bidder withdraws or amends impairs or derogates from the tender in any respect within the validity period of their tender. Bid securities of the unsuccessful bidders should be returned to them at the earliest after expiry of the final bid validity and latest on or before the 30th day after the award of the contract. As per Rule 170 of GFR 2017.

27. **Annual Turnover.** Intending vendors should be having an annual turnover more than **Rs 20,00,000/- (Rupees Twenty Lakhs only)**.

28. **Documents to be submitted by the Seller.** As mentioned in Gem portal, the following documents are to be submitted by the seller at the time of Bidding: -

- (a) Experience Certificate last three years.
- (b) Past Performance cert of vendor of last three years.
- (c) Annual turnover of OEM/ bidder of last three years.
- (d) Authorization letter for dealership/distribution ship by the OEM to the firm with validity.
- (e) Make in India cert from OEM.
- (f) Tech literature of offered ~~item~~ **item**.
- (h) ATC acceptance certificate.

(j) MSME certificate.

29. Reverse Auction. Yes.

30. Consignee Details. (Main Items and delivery / unit address).

<u>Main Items (Name of Project)</u>	<u>Items Delivery Address</u>
PROCUREMENT, INSTALLATION AND COMMISSIONING OF 8.5 TON PACKAGE AIR CONDITIONER UNIT QTY-04 AT AIR FORCE STATION JAMMU	Air Officer Commanding, Air Force Station, Jammu J&K PIN-180003

Date: 12 Mar 25



(Rashmi Rawat)
Wg Cdr
CO 725 SU, AF