

STC FOR SPLIT AIR CONDITIONER (Wall Mount Type)

1) Scope of standard installation and Commissioning for Wall Mount Split AC consist of follows:

a) The following are included in the scope of standard installation and Commissioning for Wall Mount Split AC

- I)** Mounting/Fitting of indoor and outdoor units at the respective locations. The site shall be easily accessible for installation for outdoor unit (ODU)/indoor unit (IDU) keeping in view safety of the installation personnel. Also, the supply unit with accessories if any as per the bid are only to be considered fixed during the installation.
- II)** Laying of refrigerant piping and connecting with indoor and outdoor units after drilling hole/holes in the brick wall (up to 10inch) of width, if required.
- III)** Checking / Charging Refrigerant gas in the unit.
- IV)** Suitable electric wiring between indoor units and switch up to 1 meter in length.
- V)** Testing for satisfactory working without any abnormal noise as well as leakage test of the entire system.

b) The following are not included in the scope of standard installation and Commissioning for Wall Mount Split AC

- I)** Chiselling / Ducting / grooving for concealing the Refrigerant piping/cabling/ core cutting of brick wall more than 10inch of width, beam, slab, stone wall etc.
- II)** Switches/ Sockets / Plug Tops / Voltage Stabilizer/ Stand for ODU/ Drainpipe/ refrigerant pipe etc. are not to be provided If not ordered/ not covered in the bid supply order.

2) Note to Buyers: -

- I)** Central Ministries/ Departments while procuring electrical appliances notified by the Department of Expenditure (DoE) shall ensure that they carry the notified threshold or higher Star Rating of the Bureau of Energy Efficiency (BEE). In this regard, DoE OM No.26/6/2012-PPD dated 21.01.2013 may also be referred to wherein appliances and threshold star ratings have been circulated.
- II)** Buyer shall apply all relevant filter against “Golden/Filterable” parameters to define their technical requirements.

- III) For Procurement through BID/RA:** - Any bid not having specific value i.e. one and only one value to be specified by the buyer against "Golden" parameters such as 'Classification by Function, Nominal Marketing Cooling Capacity, Star Rating (ISEER value range), Eco-friendly Refrigerant, Compliance to Green AC related environmental friendly features complied, Comprehensive Warranty on Air Conditioner/Machine (in years), Warranty on Compressor (in years), Installation/Commissioning, Number of free services during the comprehensive warranty on air conditioner/machine, Mandatory Compliance / conformity to relevant ISS shall be considered as vague and is liable to be cancel by competent authority. For any violation of the above if resulting into limited competition or higher cost to the ex-chequer, the Buyer shall be solely responsible.
- IV) For Procurement through DIRECT/L1:** Buyers are advised to apply filters/ selections allowing all the values which are considered meeting or are better than their technical requirements e.g. if the requirement is 5 years compressor warranty; Buyer should select other superior values, i.e. 10 years warranty as well. Such selection will act as 5 years or better (in L1 buying). For any violation of the above if resulting into limited competition or higher cost to the ex-chequer, the Buyer shall be solely responsible.
- V) (a):** Buyer intended for buying AC with optional accessories, optional extended warranty shall use BID/RA. (Hint: Against the optional accessories/work required, optional extended warranty kind of parameters which are multi-select for seller, buyer may stipulate/select only required accessories shall be verified before accepting the stores. This is to ensure strict compliance of supplied stores to the bid requirement including ATC if any. However, the contract generated may have mentioned of accessories other than the big requirement due to the fact that the contract gets generated based on the catalogue uploaded by the OEM/seller.) This type of optional parameters is to enable the seller without creating multiple catalogues for given base models having capabilities to be upgraded.
- (b):** Direct/L1 procurement with selection of optional accessories will not be covered in supply through various appearing in the contract but seller/supplier do not supply the same being optional and buyer has not exercised their right to choose specifying in bid.
- VI)** Buyer shall also refer to GTC Clause 4. xiii.(w). The ATC / additional specification if any added by the buyer shall not be contradictory to the GeM category specifications / technical particulars (TP).
- VII)** Buyer/ consignee shall verify all the parameters/ specification including the specification which are to be as per the BEE star label such as 'Appliance Type, Cooling Capacity (100%), Compressor Type, Heat Pump' before issuing of CRAC.
- VIII)** In case the sellers offered with information against "Other Equivalent/Better Alternate Models Offered against offered (bid) models", the buyer must ensure that the alternate model meets or exceeds all the bid requirements before accepting it. This parameter is applicable only procurement through bid only. Procurement through direct/L1 this parameter has no bearing on the contract as the direct purchase/L1 procurement happens on the stock available with seller.
- IX)** Buyer may consider for EPBG duration which cover machine warranty / warranty of compressor/ warranty on PCB whichever is higher to safeguard government interest and considering other factors to ensure no undue prices escalations may occur.

- X) The parameter “Nominal Marketing Cooling Capacity (in Ton) {Hint: 1 Ton= 3000 Kcal/Hr, Tolerance +/-10%}” is a golden parameter. Buyer is advised to ensure strict compliance in respect of “Nominal Cooling Capacity (in Watt)” required for corresponding “Nominal Marketing Cooling Capacity (in Ton)”. For example: 1 Ton = 3165-3870, 1.5 Ton = 4750-5800, 1.8 Ton = 5801-6330, 2.0 Ton = 6331-7736, 2.5 Ton = 7913-9670. Buyer is also advised to strictly ensure the above and any contract having contradictory range of “Nominal Cooling Capacity (in Watt)” corresponding to “Nominal Marketing Cooling Capacity) (in Ton)” shall be rejected with intimation to GeM by raising suitable incident.

3) **Note to Sellers: -**

- I) (a): Seller may refer to GTC and ensure strict compliance of the uploaded/ offered product which shall be in line with their model having the claimed specifications in the catalogue or better.
(b): In case the seller specified values are contradictory to the specifications provided elsewhere in the TP supersede.
- II) Also, same model shall not be uploaded across catalogues with unreasonable/ contradictory offerings.
- III) Sellers should note that while uploading the catalogue, all three images must be distinct:
(a): **Image 1:** Should have original product image.
(b): **Image 2:** Should have details like make, model etc.
(c): **Image 3:** Should have BEE star rating label image having offered model number of uploaded product.
- IV) Seller shall take care before offering higher warranty on PCB/compressor as the buyer may consider for EPBG duration which cover machine warranty /warranty of compressor/warranty of PCB whichever is higher to safeguard government interest.
- V) In case any discrepancy is observed in the offered/ uploaded products, OEM dashboard of the respective Brand may be removed, and account shall be suspended as per IM policy.
- VI) The parameter “Nominal Marketing Cooling Capacity (in Ton) {Hint: 1 Ton= 3000 Kcal/Hr, Tolerance +/-10%}” is a golden parameter. Seller/OEM shall ensure strict compliance by offering proper products/catalogues having “Nominal cooling capacity (in Watt)” required for corresponding “Nominal Marketing Cooling Capacity (in Ton)”. For example: 1 Ton = 3165-3870, 1.5 Ton = 4750-5800, 1.8 Ton = 5801-6330, 2.0 Ton = 6331-7736, 2.5 Ton = 7913-9670. In case such deviations/contradiction or similar deviation/contradiction are observed in the offered catalogue, GeM reserves the right to remove such catalogues by sidelining from the portal without further intimation and/or action as per clause 3(v) of the STC shall be taken.

4) Note to Buyers/ Sellers: -

- I) The buyer Specific requirement (Optional Accessories, optional warranty) are the requirements which is considered as having price implication above the basic model price.
- II) The buyer/seller shall ensure separate line item in the OEM/Seller's invoice to clearly account for the price implication and future reference to fulfil the OEM/sellers obligations (for example extended warranty offered by the OEM)
- III) Green AC being a nascent concept, buyers and sellers are expected to have gone through the draft document "Sustainable Public Procurement: Green Room Air Conditioner Specification (draft)" on the GeM portal. Further the sellers who is claiming to be offering green AC are expected to follow all the organizational specification for RAC manufacturers mentioned in the document "Sustainable Public Procurement: Green Room Air Conditioner Specification (draft)" and shall be able to provide all the compliances to the buyer including compliance to ISO 14001 etc. at the time of supply/bid. Buyer is also advised to verify the same in case green ac is procured.
- IV) In case the sellers offered with information against "Optional Parameters", the buyer must ensure that the alternate model meets or exceeds all the bid requirements before accepting it. This parameter is applicable only procurement through bid only. Procurement through direct/L1 this parameter has no bearing on the contract as the direct purchase/L1 procurement happens on the stock available with seller.

5) Standard Warranty Obligation: -

OEM/ Sellers are required to service of supplied AC's twice a year which includes:

- I) 2 Services per year/ 4 services per year as applicable shall be provided. Out of these services at least one will be wet service & remaining will be dry services through checking of filter, gas leak check etc. The interval/timing of service shall be on the call basis on brands, customer care number preferably every quarter/ one at starting of the summer season and one at end of the season. However, this do not absolve the seller/OEM from the warranty obligations.
- II) Any manufacturing defect and wear/ tear of AC of major components such as compressor, condenser coil, evaporator coil, fan motor, blower motor, capacitor, relay, filters, PCB and refilling of the refrigerant etc. to be taken care and repaired/replaced accordingly without any extra cost to Buyer.
- III) Any physical damage of machine (post installation) may not be included in warranty.
- IV) During the warranty after physical damage seller has to provide service as per charge of the components.

