



8D4 调峰工况 (S0, 560 A 恒流, 6400 s) : 去掉启停层前后对比


8D4f (带启停监督层, 极限环波浪) : 末 1000 s 均温 25.01 °C (偏差 +0.01 K) , 极值 24.74~25.34 °C, 带外 0 s



启停 18 次; 末 1000 s 指令均值 2014 rpm, 波动 1095~3106



8D4g (去掉启停层, 连续调制) : 末 1000 s 均温 25.01 °C (偏差 +0.01 K) , 极值 24.76~25.02 °C, 带外 0 s



启停 0 次; 末 1000 s 指令均值 2011 rpm, 波动 1512~3285

