

AAON, Inc.

TULSA, OKLAHOMA

ANSI Z21.47a-2005/CSA2.3-2006 CENTRAL FURNACE

MODEL NO. **RN-070-8-0-BA04-5E9** PART NO. **92887**
DESC. **RN-070-8-0-BA04-5E9:CEHFD0BGLM00CRACEBBL0000000000B**
SERIAL NUMBER **200810-BNGY04249**



51034

CONFORMS TO UL STANDARD 1995
CERTIFIED TO CAN/CSA STD C22.2 NO. 236

ELECTRICAL RATING

RATED VOLTS **208** VAC **60** HZ **3** PHASE
MINIMUM CIRCUIT AMPACITY **406** AMPS MAXIMUM FUSE
MAXIMUM CIRCUIT BREAKER (HACR TYPE) **450** AMP

MOTOR	QTY	HP	VAC	PH	RPM	FLA	RLA	LRA	DRIVE
Compressor	4		208	3	3500		55.8	340	D
Compressor									
Condenser	6	.75	208	1	1075	5.4			D
Evaporator	2	20	208	3	1760	59.4			D
Combustion Air	4	.25	208	1	3200	1.2			D
Power Echl.	1	5	208	3	1760	16.7			D
Addl Mtr.									

EQUIPPED FOR GAS **NAT** TEMPERATURE RISE RANGE **15-45** TEMPERATURE RISE **30**
MANIFOLD PRESS. **3.5** "WC MAX INLET PRESS. **10.5** "WC MIN. INLET PRESS. **6.0** "WC

DESIGN MAXIMUM OUTLET TEMPERATURE **200 °F**
MAXIMUM LIMIT SETTING **235 °F**

CAPACITY ALTITUDE	INPUT MBH	OUTPUT MBH	MIN. INPUT MBH (2 STAGE GAS VALVE)
0-2000 Ft.			
2000-4500 Ft.	932	746	

MINIMUM AMBIENT TEMPERATURE IN WHICH GAS HEAT UNIT MAY OPERATE (CGA) **-40 °F**

CLEARANCES

FLOOR - UNIT MUST BE INSTALLED ON MINIMUM 12" HIGH CURB WHICH MAY BE ON COMBUSTIBLE FLOOR
(CANADA & USA) OR CLASS A, B, OR C ROOF COVERING MATERIAL (USA ONLY).

TOP - NO OBSTRUCTION

FRONT- **48** LEFT SIDE- **48** RIGHT SIDE- **70** BACK- **48**

FACTORY CHARGE

FACTORY CHARGE PER SYSTEM (1) **464** oz. (2) **464** oz. (3) **464** oz. (4) **464** oz.
(OUNCES) REFRIGERANT **R-410A** (5) oz. (6) oz. (7) oz. (8) oz.
LOWSIDE TEST PRESS. **255** PSIG.
HIGHSIDE TEST PRESS. **475** PSIG.

CAUTION: USE TIME DELAY TYPE FUSES.

FOR NON-RESIDENTIAL USE ONLY. NOT SUITABLE FOR USE WITH CONVENTIONAL VENTING SYSTEM.

FORCED AIR FURNACE WITH OR WITHOUT COOLING UNIT. CATEGORY III

FOR OUTDOOR INSTALLATION ONLY. CERTIFIED FOR INSTALLATION DOWNSTREAM FROM REFRIGERATION SYSTEM.

WARNING

THIS UNIT MUST BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND LOCAL CODES. IN THE ABSENCE OF LOCAL CODES, FOLLOW THE NATIONAL FUEL GAS CODE, ANSI Z223.1-1992 (USA) OR CAN/CGA-B3142.1 OR 2 INSTALLATION CODES (CANADA). IMPROPER INSTALLATION, ADJUSTMENT, ALTERATION, SERVICE OR MAINTENANCE CAN CAUSE PROPERTY DAMAGE, PERSONAL INJURY OR LOSS OF LIFE. REFER TO THE USER'S INFORMATION MANUAL PROVIDED WITH THIS FURNACE. INSTALLATION AND SERVICE MUST BE PERFORMED BY A QUALIFIED INSTALLER, SERVICE AGENCY OR THE GAS SUPPLIER.

FOR YOUR SAFETY: DO NOT STORE OR USE GASOLINE OR OTHER FLAMMABLE VAPORS AND LIQUIDS IN THE VICINITY OF THIS OR ANY OTHER APPLIANCE.

RTU-1