

Carrier
Corporation
TYLER, TEXAS

48TFF006-A-511

SERIAL 0602G10138



FACTORY CHARGED

	QTY	VOLTS AC	PH	HZ	RLA	LRA	REF.	SYSTEM	R-22	TEST PRESSURE	GAGE
COMPR	1	208/230	3	60	16.0	114	7.9	LBS	3.6	kg HI	401 PSI 2761 kPa
COMPR								LBS		kg LO	175 PSI 1207 kPa
FAN MTR	QTY	VOLTS AC	PH	HZ	FLA						
OUTDOOR	1	208/230	1	60	1.4						
OUTDOOR											
INDOOR	1	208/230		60	5.2						
OTHER											
COMBUST	1	208/230	1	60	0.6						

CHARGE SYSTEM PER INSTALLATION INSTRUCTIONS
FOR OUTDOOR INSTALLATION ONLY

POWER SUPPLY 208/230 3 PH 60 HZ
PERMISSIBLE VOLTAGE AT UNIT 254 MAX 187 HZ

MINIMUM CLEARANCES TO COMBUSTIBLE MATERIALS

	TOP	BOTTOM	SIDES	FLUE SIDE
DOWN SUPPLY	0 IN 0MM	1.0 IN 25.4MM	0 IN 0MM	36 IN 914MM
SIDE SUPPLY				

* FOR INSTALLATION ON COMBUSTIBLE FLOORING OR CLASS A,B, OR C ROOFING MATERIAL

** 18 INCHES (457mm) WITH ACCESSORY FLUE DISCHARGE DEFLECTOR

MIN CKT 27 AMPS	MAX FUSE OR HACR BREAKER 35	MINIMUM UNIT DISCONNECT FLA LRA
	MAX OVERCURRENT PROTECTIVE DEVICE 26	148

COMBINATION COOLING AND HEATING UNIT

DEVICE CERTIFIED AS A FORCED AIR FURNACE WITH COOLING UNIT
CSA APPROVED FOR NON-RESIDENTIAL USE TO -40 F AMBIENT.

DESIGNED MAXIMUM OUTLET AIR TEMPERATURE 185F 85C

AIR TEMP RISE	MAX EXTERNAL STATIC PRESSURE
50-80F 27.8-44.4C	1.0WC 0.25KPA

	INPUT MIN	INPUT MAX	OUTPUT CAP	THERMAL EFFICIENCY	EQUIPED FOR USE WITH
BTU/HR	120000	150000	96000/120000		
KW	35.2	44.0	28.1-35.2	80	NATURAL GAS
GAS SUPPLY PRESSURE	13WC 3.23KPA	MAX	5WC 1.24KPA	MIN	
MANIFOLD PRESSURE	2.2-3.5WC	0.55-0.87KPA			

GAS HEATING PORTION CLASSIFIED BY
UNDERWRITERS LABORATORIES

AT APPROXIMATE FURNACE INPUT 20,000 BTU/HOUR



48TFF006-A-511



0602G10138



LISTED
COOLING PORTION OF
HEATING AND COOLING UNIT
35N2

