

Carrier
Corporation
TYLER TEXAS

MODEL 48TFF006-A-511--

SERIAL 0602G10146



FACTORY CHARGED

	QTY	VOLTS AC	PH	HZ	RLA	LRA	REF.	SYSTEM R-22	TEST PRESSURE GAGE
COMPR	1	208/230	3	60	16.0	114	7.9	LBS 3.6 kg	HI 401 PSI 2761 kPa
COMPR								LBS kg	LO 175 PSI 1207 kPa
FAN TR	QTY	VOLTS AC	PH	HZ	FLA				
OUTDOOR	1	208/230	1	60	1.4				
OUTDOOR									
INDOOR	1	208/230		60	5.2				
OTHER									
COMBUST	1	208/230	1	60	0.6				

CHARGE SYSTEM PER INSTALLATION INSTRUCTIONS
FOR OUTDOOR INSTALLATION ONLY

POWER SUPPLY 208/230 3 PH 60 HZ
PERMISSIBLE VOLTAGE AT UNIT 254 MAX 187 MIN

MINIMUM CLEARANCES TO COMBUSTIBLE MATERIALS

	TOP	BOTTOM *	SIDES	FLUE SIDE **
DOWN SUPPLY	0 IN 0MM	1.0 IN 25.4MM	0 IN 0MM	36 IN 914MM
SIDE SUPPLY				

* FOR INSTALLATION ON COMBUSTIBLE FLOORING OR CLASS A, B, OR C ROOFING MATERIAL

** 18 INCHES (457mm) WITH ACCESSORY FLUE DISCHARGE DEFLECTOR

MIN CKT AMPS 27	MAX FUSE OR HACR BREAKER 35	MINIMUM UNIT DISCONNECT FLA LRA	COMBINATION COOLING AND HEATING UNIT
	MAX OVERCURRENT PROTECTIVE DEVICE 26	148	

DEVICE CERTIFIED AS A FORCED AIR FURNACE WITH COOLING UNIT
CSA APPROVED FOR NON-RESIDENTIAL USE TO -40 F AMBIENT

DESIGNED MAXIMUM OUTLET AIR TEMPERATURE 185F 85C

AIR TEMP RISE	MAX EXTERNAL STATIC PRESSURE
50-80F 27.8-44.4C	1.0WC 0.25KPA

	INPUT MIN	INPUT MAX	OUTPUT CAP	THERMAL EFFICIENCY	EQUIPED FOR USE WITH
BTU/HR	120000	150000	96000/120000		
KH	35.2	44.0	28.1-35.2	80	NATURAL GAS
GAS SUPPLY PRESSURE	13WC 3.23KPA	MAX	5WC 1.24KPA	MIN.	
MANIFOLD PRESSURE	2.2-3.5WC	0.55-0.87KPA			

GAS HEATING PORTION CLASSIFIED BY
UNDERWRITERS LABORATORIES
IN ACCORDANCE WITH ANSI Z21.47 STANDARD-1993



48TFF006-A-511--



0602G10146



LISTED
COOLING PORTION OF
HEATING AND COOLING UNIT
36N2



99NA504574-A