

Accessory Heater Power Exhaust	Qty	check here	Volts	PH	Hz	FLA	HP	Min Over Current Amps	Max OverCurrent Protective Device Amps
CRPWREXH018B00	2		208/230	1	60	5.9	1	137/134	150/150

Installer Note:

- 1: Install accessory per installation instructions enclosed with heater and/or power exhaust and mark space "Check Here" for accessory model(s) used. Use MIN CKT AMPS and MAX OVERCURRENT DEVICE AMPS listed for accessory(s)
- 2: Mark "NONE" if no accessories are used
- 3: Heaters are manufactured by Tulco.
- 4: Heater references do not apply to gas models.



Model 4800C22



Serial 4600020001

**Carrier**

A United Technologies Company

MODEL 48PGEC28 - C - 50 - 2S**SERIAL 4608G20081**

Compressors (Factory Charged)							Refrigerant/System			Test Pressure Gage		
Qty	Volts AC	PH	Hz	RLA	LRA		lbs	kg	R-	Hi	Lo	
1	208/230	3	60	28.2	208		49.3	22.4	R-410A	670 PSI (4619 kPa)	236 PSI (1627 kPa)	
2	208/230	3	60	28.2	208							
3	208/230	3	60	28.2	208		24.3	11.0	R-410A			
Fan Motors							HP		KW		Cooling Capacity	
Qty	Volts AC	PH	Hz	FLA								
Indoor Fan	1	208/230	3	60	24.2/22		7.5		5.60		Gas Ratings	
Outdoor Fan	6	208/230	1	60	1.5		0.25		0.19		BTU / Hr.	
Combustion Fan	1	208/230	1	60	0.5		0.06		0.04		Input Min	280000
Power Exhaust	2	208/230	1	60	5.9		1		0.75		Input Max	365000
											Output Cap.	295650
											Thermal Efficiency	81 %
										Design Tested Under ANSI Z21.47B		
										- CSA 2.36 - 2000 UL 1995 Air		
										Conditioners and ANSI 15 Safety		
										Code for Mechanical		
										This equipment complies with		
										the 2004 requirements of		
										ASHRAE 90.1		
Power Supply							Max		Min		MCA *	
Volts AC	PH	Hz	Volts	Volts								
208/230	3	60	253	187		137/134					150/150	
* MCA = Min Circuit Amps												
* MOCP = Max Over Current Protective Device Amps												
										* Fuse or		
										HACR BKR		

MODEL**SERIAL**

For Outdoor Use ONLY

Equipped for use with

NATURAL GAS