

Carrier Corporation

7310 WEST MORRIS STREET
INDIANAPOLIS, IN 46231 U S A

MODEL
SERIAL

48FCEA06A2A5A0A0A0

4918C65434

FACTORY CHARGED



	QTY	VOLTS AC	PH	HZ	RLA	LRA	REF SYSTEM R-410A			TEST PRESSURE GAGE		
COMPR A	1	208/230	3	60	16.0	110	8.2	LBS	3.72	kg	HI 650 PSI	4481.5 kPa
COMPR B										LO	450 PSI	3102.6 kPa
FAN MTR	QTY	VOLTS AC	PH	HZ	FLA	CHARGE SYSTEM PER INSTALLATION INSTRUCTIONS FOR OUTDOOR INSTALLATION ONLY COMBINATION COOLING AND HEATING UNIT						
OUTDOOR	1	208/230	1	60	1.5							
INDOOR	1	208/230	1	60	8.6							
COMBUST	1	208/230	1	60	0.48							
OTHER												
ERV. SUPPLY						POWER SUPPLY			PERMISSIBLE VOLTAGE TO UNIT			
ERV. EXHAUST						208/230	3	50	253	187		
ERV. WHEEL						VOLTS	PH	HZ	MAX	MIN		

ACCESSORY POWER EXHAUST MODEL CRPWREXH	VOLTS	PH	HZ	ACCESSORY POWER EXHAUST FLA	MINIMUM CIRCUIT AMPS	MAX FUSE OR HACR BREAKER PER NEC	MAXIMUM OVERCURRENT PROTECTION DEVICE	MINIMUM UNIT DISCONNECT	
NONE					31	45	-	30	126
030A, 028A	208/230	1	60	1.9	32	45	-/-	32	128

CONTROL PANEL SCCR: 5kA RMS SYMMETRICAL VOLTAGE: 253 MAX

MINIMUM CLEARANCE TO COMBUSTIBLE MATERIALS

	TOP				BOTTON *				SIDES				FLUE SIDE **			
DOWN SUPPLY	0	IN.	0	MM.	1	IN.	25	MM.	0	IN.	0	MM.	36	IN.	914	MM.
SIDE SUPPLY	0	IN.	0	MM.	1	IN.	25	MM.	0	IN.	0	MM.	36	IN.	914	MM.

* FOR INSTALLATION ON COMBUSTIBLE FLOORING OR CLASS A,B, OR C ROOFING MATERIAL

** 18 INCHES (457mm) WITH ACCESSORY FLUE DISCHARGE DEFLECTOR

DEVICE CERTIFIED AS A FORCED AIR FURNACE WITH COOLING UNIT APPROVED FOR NON-RESIDENTIAL
USE TO -40° F AMBIENT PER ANS Z21.47-2016 CSA 2.3-2016 CENTRAL FURN. *FOR INSTALLATIONS ABOVE
2000 ft, SEE HIGH ALTITUDE RATING PLATE INSIDE FURNACE*

AIR TEMP RISE	MAX EXTERNAL STATIC PRESSURE	DESIGNED MAXIMUM OUTLET AIR TEMPERATURE
25 - 65 F	1 in W.C.	185 F
13.9 - 36.1 C	0.25 kPa.	85 C

	INPUT MIN	INPUT MAX	OUTPUT CAP	THermal EFFICIENCY	EQUIPED FOR USE WITH
BTU/HR		115000	93000		
KW		33.7	27.3	81.0 %	NATURAL GAS
GAS SUPPLY PRESSURE	13 in W.C.	3.24 kPa.	MAX 4 in W.C.	1 kPa.	MIN
MANIFOLD PRESSURE	3.5 in W.C.	0.87 kPa.			

GAS-FIRED

HEATING AND COOLING UNIT
ANSI Z21.47-2012 / CSA 2.3b-2008
CENTRAL FURNACE
36N2



	CAPACITY Btu/Hr	CAPACITY KW	SEER	COP
COOLING	58500	17.1	14	

THIS EQUIPMENT COMPLIES WITH THE
2016 REQUIREMENTS OF ASHRAE 90.1



#48FCEA06A2A5A0A0A0#



#4918C65434#



ENGINEERED IN USA
ASSEMBLED IN MEXICO
DATE OF MANUFACTURE Dec - 2018