

UNIT SIZE		12.5 - 15 TON		18 - 25 TON	
GAS INPUT (BTU/H)		HIGH HEAT 300,000	LOW HEAT 230,000	HIGH HEAT 360,000	LOW HEAT 275,000
ORIFICE FOR FULL RATE AT INJECTEUR A DEBIT MAXIMAL DE		MAIN ORIFICES INJECTEUR PRINCIPAL			
0-2000 FT (PDS)	-NAT. GAS/GAZ NAT. (IN/PO)	.136	.1285	.136	.1285
	-PROPANE/GAZ PROP. (IN/PO)	.1065	.1065	.1065	.1065
2000-3000 FT (PDS)	-NAT. GAS/GAZ NAT. (IN/PO)	.1285	.120	.1285	.120
	-PROPANE/GAZ PROP. (IN/PO)	.104	.104	.104	.104
3000-4500 FT (PDS)	-NAT. GAS/GAZ NAT. (IN/PO)	.1285	.120	.1285	.120
	-PROPANE/GAZ PROP. (IN/PO)	.1015	.1015	.1015	.1015
MANIFOLD PRESSURE PRESSION A LA TUBULERE-NAT. GAS/GAZ NAT. D'ALIMENTATION (IN/PO)		3.3	3.3	3.3	3.3
INLET PRESSURE RANGE GAMME DE PRESSION D'ENTREE		MIN 5.5 INS WC 1.37 KPA MAX 13.0 INS WC 3.24 KPA			

CERTIFIED FOR MINIMUM AMBIENT TEMPERATURE
CERTIFIE POUR UNE TEMPERATURE AMBIANTE MINIMALE DE

HIGH ALTITUDE RATING IS 90% OF SEA LEVEL RATING.
CARACTERISTIQUES NOMINALE A HAUTE ALTITUDE-90% DE CELLES AU NIVEAU DE LA MER.

-40°F
-40°F

"FOR USE WITH NATURAL GAS AND PROPANE. A CONVERSION KIT, AS SUPPLIED BY MANUFACTURER, SHALL BE USED TO CONVERT THIS FURNACE TO THE ALTERNATE FUEL."

"POUR UTILISATION AVEC LE GAZ NATUREL ET LE PROPANE. UNE TROUSSE DE CONVERSION FOURNIE PAR LE FABRICANT DOIT ETRE UTILISEE POUR PASSER D'UN COMBUSTIBLE A L'AUTRE."

⚠ CAUTION

CAUTION - THIS UNIT IS EQUIPPED WITH 0-2000 FEET (0-610 M) MAIN ORIFICES

ATTENTION - LES INJECTEURS PRINCIPAUX QUE COMPORTE CE GENERATEUR ONT ETE INSTALLES EN USINE ET CONVIENNENT POUR LES ALTITUDES DE 0-2000 PIEDS- (0-610M)



CONFORMS TO
UL STD 1995
ANSI STD Z21.47
CERTIFIED TO
CAN/CGA STD 2.3
CAN/CSA STD C22.2 NO. 237

Product has been safety tested by ETL Testing Laboratories Inc. The test procedure is in strict conformance with prevailing and applicable ANSI*/UL* standards as listed above.

Further information regarding the test procedure and compliance to existing industry standards may be obtained directly from ETL Testing Laboratories, Inc.

ETL Testing Laboratories, Inc.

Industrial Park Cortland, NY

Telephone: (607) 753-6711

13045

TWX: 510-2520792

*(ANSI) American National Standards Institute

*(UL) Underwriters Laboratory, Inc.



Carrier

A United Technologies Company

MODEL 48TJF016 — — — 581BA

SERIAL 0602F35459



CU000J23B

Compressor

QTY	Volts AC	PH	Hz	(Factory Charged)		Refrigerant/System			Test Pressure Gage	
				RLA	LRA	lbs	kg	R—	PSI	kPa
1	208/230	3	60	28.8	195	10.6	4.8	22	Hi 410	2827
2	208/230	3	60	28.8	195	10.6	4.8	22	Low 150	1034

Fan Motors

QTY	Volts AC	PH	Hz	FLA	HP	KW
Outdoor	208/230	1	60	1.7	0.5	0.37
Indoor	208/230	3	60	10.5/11	3.7	2.8
Combustion	208/230	1	60	0.57	0.06	0.04

Power Supply

Volts AC	PH	Hz	Max Volt	Min Volt
208/230	3	60	253	187

Min Circuit Amps 81/81 FUSE OR HACR BKR
Max Overcurrent Protective Device Amps 100/100

BTU/hr. kW 81% Thermal Efficiency

225,000	65.9	Input Min
300,000	87.9	Input Max
243,000	71.2	Output Cap

Outdoor Installation Only

Equipped for use with NATURAL Gas
Charge System Per Installation Instructions

Minimum circuit ampacity (MCA) and
maximum overcurrent protection (MOCP)
calculations per UL 1995, CAN/CSA No.
236, Sections 36.14, 15, 16.

Design Tested Under ANSI Z21.47 — CAN /
CGA — 2.3, — 1993 Central Furnaces UL
1995 Air Conditioners and ANSI 89.1
Mechanical Refrigeration

Made In U.S.A.

99NA506463-1