

Carrier
Corporation

7310 WEST MORRIS STREET
INDIANAPOLIS, IN 46231 U.S.A.

MODEL 48PGEC12-A-50-2S

SERIAL 4608G30033

FACTORY CHARGED

Carrier

QTY	VOLTS AC	PH	HZ	RLA	LRA	REF. SYSTEM	410A	TEST PRESSURE	GA
1	208/230	3	60	17.6	123	13.7 LBS	6.2 kg	596 PSI	4109 kPa
1	208/230	3	60	17.6	123	13.7 LBS	6.2 kg	236 PSI	1627 kPa
R C						LBS	kg		

TAN MTR	QTY	VOLTS AC	PH	HZ	FLA	CHARGE SYSTEM PER INSTALLATION INSTRUCTIONS FOR OUTDOOR INSTALLATION ONLY COMBINATION COOLING AND HEATING UNIT			
OUTDOOR	2	208/230	1	60	1.9				
INDOOR	1	208/230	3	60	7.5				
PWR EXH.	1	208/230	1	60	3.0	POWER SUPPLY		PERMISSIBLE VOLTAGE TO UNIT	
COMBUST	1	208/230	1	60	0.52	208/230	3	60	253 MAX 187 MIN
OTHER						VOLTS	PH	HZ	

ACCESSORY PWR. EXHAUST MODEL NUMBER	VOLTS	PH	HZ	ACCESSORY PWR. EXHAUST FLA	MINIMUM CIRCUIT AMPS	MAX FUSE OR HACR BREAKER PER NEC	MAXIMUM OVERCURRENT PROTECTION DEVICE	MINIMUM UNIT DISCONNECT	
NONE					53.9	60	-	57	314
						0			

MINIMUM CLEARANCES TO COMBUSTIBLE MATERIALS				
	TOP	BOTTOM *	SIDES	FLUE SIDE **
DOWN SUPPLY	0 IN. 0MM	1 IN. 25MM	0 IN. 0MM	48 IN. 1219MM
SIDE SUPPLY	0 IN. 0MM	1 IN. 25MM	0 IN. 0MM	48 IN. 1219MM

* FOR INSTALLATION ON COMBUSTIBLE FLOORING OR CLASS A,B, OR C ROOFING MATERIAL
** 18 INCHES(457mm) WITH ACCESSORY FLUE DISCHARGE DEFLECTOR

DEVICE CERTIFIED AS A FORCED AIR FURNACE WITH COOLING UNIT
CSA APPROVED FOR NON-RESIDENTIAL USE TO -40 F AMBIENT.

AIR TEMP RISE		MAX EXTERNAL STATIC PRESSURE		DESIGNED MAXIMUM OUTLET AIR TEMPERATURE					
35-70F		1.4 IN. W.C.		200F					
19.4-38.9C		0.35 KPA		93C					
INPUT MIN		INPUT MAX		OUTPUT CAP		THERMAL EFFICIENCY		EQUIPED FOR USE WITH	
BTU/HR 158200		226000		185300		82.0 %		NATURAL GAS	
KW 46.4		66.2		54.3		82.0 %		NATURAL GAS	
GAS SUPPLY PRESSURE		13WC 3.24KPA		MAX 5WC 3.24KPA		MIN			
MANIFOLD PRESSURE		1.7/3.5 WC - 0.42/0.87 KPA							

GAS-FIRED



ANSI Z21.47-CAN/CGA-2.3 -
(2003) CENTRAL FURNACE

LISTED



COOLING PORTION OF
HEATING AND COOLING UNIT
36N2

	CAPACITY Btu/Hr	CAPACITY kW	EER	COP
COOLING				
HP HEATING				

THIS EQUIPMENT COMPLIES WITH THE
2004 REQUIREMENTS OF ASHRAE 90.1



#48PGEC12-A-50-2S*



#4608G30033*



DATE OF MANUFACTURE: NOV 2008

ARI Standard 340/360
Commercial and Industrial Unitary
Air Conditioning Equipment