

Carrier
Corporation
TYLER, TEXAS

MODEL 48TFF006-A-511--
SERIAL 0602G10143
FACTORY CHARGED



	QTY	VOLTS	AC	PH	HZ	RLA	LRA	REF. SYSTEM R-22	TEST PRESSURE	GAGE
COMPR	1	208/230	3	60	16.0	114	7.9	LBS	3.6	kg HI 401 PSI 2761 kPa
COMPR								LBS		kg LO 175 PSI 1207 kPa
FAN MTR	QTY	VOLTS	AC	PH	HZ	FLA				
OUTDOOR	1	208/230	1	60	1.4					
OUTDOOR										
INDOOR	1	208/230		60	5.2					
OTHER										
COMBUST	1	208/230	1	60	0.6					

CHARGE SYSTEM PER INSTALLATION INSTRUCTIONS
FOR OUTDOOR INSTALLATION ONLY

POWER SUPPLY 208/230 3 PH 60 HZ
PERMISSIBLE VOLTAGE AT UNIT 254 MAX 187 MIN

MINIMUM CLEARANCES TO COMBUSTIBLE MATERIALS

	TOP	BOTTOM *	SIDES	FLUE SIDE **
DOWN SUPPLY	0 IN 0 MM	1.0 IN 25.4 MM	0 IN 0 MM	36 IN 914 MM
SIDE SUPPLY				

* FOR INSTALLATION ON COMBUSTIBLE FLOORING OR CLASS A, B, OR C ROOFING MATERIAL

** 18 INCHES (457mm) WITH ACCESSORY FLUE DISCHARGE DEFLECTOR

MIN CKT 27 AMPS	MAX FUSE OR HACR BREAKER 35	MINIMUM UNIT DISCONNECT FLA 26	LRA 148	COMBINATION COOLING AND HEATING UNIT
-----------------	-----------------------------	--------------------------------	---------	--------------------------------------

DEVICE CERTIFIED AS A FORCED AIR FURNACE WITH COOLING UNIT
CSA APPROVED FOR NON-RESIDENTIAL USE TO -40 F AMBIENT.

DESIGNED MAXIMUM OUTLET AIR TEMPERATURE

185F 85C

AIR TEMP RISE	MAX EXTERNAL STATIC PRESSURE
50-80F	1.0WC 0.25KPA
27.8-44.4C	

	INPUT MIN	INPUT MAX	OUTPUT CAP	THERMAL EFFICIENCY	EQUIPED FOR USE WITH
BTU/HR	120000	150000	96000/120000		
KH	35.2	44.0	28.1-35.2	80	NATURAL GAS
GAS SUPPLY PRESSURE	13WC 3.23KPA	MAX	5WC 1.24KPA	MIN	
MANIFOLD PRESSURE	2.2-3.5WC	0.55-0.87KPA			

GAS HEATING PORTION CLASSIFIED BY
UNDERWRITERS LABORATORIES
IN ACCORDANCE WITH ANSI Z21.47 STANDARD-1993




48TFF006-A-511--



0602G10143



LISTED
COOLING PORTION OF
HEATING AND COOLING UNIT
36N2



99NA504574-A