

PREVENTIVE MAINTENANCE CHECKLIST
[SITE NAME]

A Asset Details										
Asset Group :		Mechanical				Model :				
Asset Category :		Fire Protection				Capacity :				
Asset Type :		Fire Extinguisher				Location Code :				
Task No :		M003B				PM Start Date :				
Work Order No :										
B Safety Precaution / General Guidelines prior to maintenance activity										
1. Ensure extinguishers and cylinders are in their correct location 2. Isolate all isolation switches at panel and disconnect wiring 3. To weigh the cylinder, disconnect the system piping from the discharge actuator valve. Remove the cylinder with their actuator valves intact and weigh them. 4. Set value is the total weight for each extinguisher/cylinder including the gas/dry powder and intact accessories.										
C Qualitative Tasks										
	Description					Freq	Pass	Fail	N/A	Action
A.1	Portable Fire Extinguishers: Visual check on pressure indicator and ensure is marked at "Full" or green range					M				
A.2	Portable Fire Extinguishers: Safety pins are not removed					M				
A.3	Portable Fire Extinguishers: Examine and clean the nozzle, horn valve assembly and discharge control mechanism. Replace if necessary					Y				
A.4	Portable Fire Extinguishers: Authority BOMBA certificates to be renewed for every portable extinguisher					Y				
B.1	Carbon dioxide gas cylinders: Check condition of cylinder actuator (pyrocharge/solenoid)					Y				
B.2	Carbon dioxide gas cylinders: Check piping and cylinder brackets					Y				
B.3	Carbon dioxide gas cylinders: Visual inspection on manifold and flexible hose					Y				
D Quantitative Tasks										
	Description	Units	Set Value	Measured Values	Limit / Tolerance	Freq	Pass	Fail	N/A	Action
E Spare Parts / Material Used (if any)										
F Additional Report										
Yes		No		Refer to						
G Comments / Remarks										
Service By			Checked By				Verified By			
.....										
Name :			Name :				Name :			
Date :			Date :				Date :			