

# T-300 Modbus Registers

This is a best guess of registers and the setpoints they relate to. Adjustments and improvements welcome. See the project at <https://github.com/zathras777/t300> for more details.

Register	Access	Setpoint	Description	Additional Information
3	3	D01		
4	3	F27		
5	3	F28		
11	3	D07		
26	3	F03		
27	3	F04		
28	3	F05		
29	3	F06		
30	3	F07		
31	3	F08		
33	3	F09		
36	3	F14	Modbus Unit ID	
37	3	F15	Modbus Baud Rate	1: 9,600 / 1: 19,200
38	3	F16	Modbus Parity	0: None, 1: Even, 2: Odd
89	3	F23		
90	3	F24		
91	3	F25		
92	3	F26		

## Notes:

- The access code shown below relates to the Modbus method for retrieving the register.
- Temperature values have 100 added to their value to allow negative values to be easily stored.
- Values with decimal places are stored multiplied up to a whole integer, e.g. 7.0 is stored as 70.