

WARNING NAMEPLATE DETAIL

S-L CONTROLS, DWG D32384-30
VOLTAGE: 120VAC, 60HZ, SINGLE PHASE
AMPS: 28.75

SHORT CIRCUIT CURRENT: N/A

ENCLOSURE RATING: UL TYPE 4X

CAUTION: MULTIPLE POWER SOURCES ARE PROVIDED FROM FIELD
TERMINALS. EACH SOURCE SHOULD BE DISCONNECTED FOR
SERVICING.

WARNING: - RISK OF ELECTRIC SHOCK - UPS EQUIPMENT
OUTPUTS REMAIN LIVE WITH MAIN DISCONNECT IN THE OFF
POSITION

WARNING: TO MAINTAIN OVERCURRENT, SHORT CIRCUIT, AND
GROUND FAULT PROTECTION, THE MANUFACTURER'S INSTRUCTIONS
FOR SELECTING CURRENT ELEMENTS MUST BE FOLLOWED

NAMEPLATES SIZED AS REQUIRED



NAME PLATE LEGEND TABLE

ITEM	QTY	DESCRIPTION
1	1	UPS CONTROL PANEL
2	1	120VAC 15 AMP / FOR UPS ONLY

NOTES:
ALL PLATES SHALL BE ENGRAVED ON WHITE BACKGROUND WITH
BLACK CHARACTERS. LETTER HEIGHT SHOULD BE MINIMUM 1/4"

WIRING:


- 1) □ - INDICATES CABINET TERMINAL BLOCK
- 2) DASHED LINES INDICATE WIRING REMOTE TO CONTROL PANEL.
- 3) PROVIDE 20% SPARE TERMINALS
- 4) UL APPROVED NO. TO BE PROVIDED AT TIME OF MANUFACTURING
- 5) ELECTRICAL CONNECTION TORQUES:
TERMINAL: 12 INCH POUNDS
CIRCUIT BREAKER: 20 INCH POUNDS



PANEL WIRING


AREA	VOLTAGE	NOUN NAME	ID	GAGE	COLOR	TYPE
INTERNAL	120VAC	HOT	(1), (1A), (X1)	14	BLACK	MTW
INTERNAL	120VAC	NEUTRAL	(N)	14	WHITE	MTW
CONTROL	120VAC	HOT	VARIOUS	16	RED	MTW
CONTROL	120VAC	NEUTRAL	N	16	WHITE	MTW
CONTROL	24VDC	DC+	VARIOUS	16	BLUE	MTW
CONTROL	24VDC	DC-	VARIOUS	16	WHT/BLU	MTW

TOLERANCES		REVISIONS			POMONKEY PUMP STATION UPS PANEL EXT. ENCLOSURE LAYOUT		
DECIMAL	NO.	DATE	BY				
	1						
FRACTIONAL	2				DRAWN BY ZBB		
	3						
ANGULAR	4				SCALE	NONE	MATERIAL
	5				CHK'D	MN	DATE 04-16-2026
	6				TRACED	APP'D	DRAWING NUMBER D32384-30



TAGS	QTY	CATALOG	DESCRIPTION	MANUFACTURER
ENC	1	SCE-30H2416SSLP	WALL MOUNT ENCLOSURE – NEMA 4X	SCE
ENC	1	SCE-30P24	ENCLOSURE BACKPANEL	SCE
CB3203	1	7940102572	CIRCUIT BREAKER, 120VAC, 2A	WEIDMULLER
CB3203A	1	7940102584	CIRCUIT BREAKER, 120VAC, 20A	WEIDMULLER
CB3204, CB3211	2	7940102582	CIRCUIT BREAKER, 120VAC, 15A	WEIDMULLER
RECP3204	1	T5015-W	SINGLE RECEPTACLE, 15A	LEVITON
CR3213	1	RPM42F7	RELAY, SP4T, 120VAC, 15A	SCHNEIDER ELECTRIC
CR3213	1	RPZF4	RELAY SOCKET, 120VAC, 14 BLADE, DIN	SCHNEIDER ELECTRIC
UPS	1	SRT1000XLA	UNINTERRUPTIBLE POWER SUPPLY	APC
UPS	1	AP9614	DRY CONTACT I/O CARD	APC
BP	1	SRT48BP	UPS EXTERNAL BATTERY PACK	APC
THERMOSTAT	1	7T.81.0.000.2403	ENCLOSURE HEATER THERMOSTAT, NC	FINDER
HTR3203	1	SCE-TSH50	ENCLOSURE HEATER	SCE
TB-AC, TB-UPS	12	3044076	UNIVERSAL TERMINAL BLOCK – UT 2,5	PHOENIX CONTACT
TB-AC, TB-UPS	A/R	3047028	TERMINAL END BARRIER	PHOENIX CONTACT
TB-AC, TB-UPS	A/R	3044092	GROUNDING TERMINAL BLOCK	PHOENIX CONTACT
TB-AC, TB-UPS	A/R	0800886	TERMINAL ANCHOR	PHOENIX CONTACT

TOLERANCES		REVISIONS			POMONKEY PUMP STATION UPS PANEL INT. PANEL LAYOUT		
		NO.	DATE	BY			
DECIMAL	1						
	2						
FRACTIONAL	3				DRAWN BY ZBB	SCALE NONE	MATERIAL
	4				CHK'D MN	DATE 04-16-2026	DRAWING NUMBER
ANGULAR	5						
	6				TRACED	APP'D	D32384-31



TOLERANCES	REVISIONS			POMONKEY PUMP STATION UPS PANEL		
	NO.	DATE	BY	UPS WIRING DIAGRAM		
DECIMAL	1					
	2					
FRACTIONAL	3			DRAWN BY ZBB		
	4					
ANGULAR	5			SCALE NONE		MATERIAL
	6			DATE 04-16-2026		
				CHK'D MN		DRAWING NUMBER
				TRACED		D32384-32
				APP'D		