




1/2" = 1'-0"
REF: S-3

NOTES:

1. ALL CANOPY FRAMING MUST BE ALUMINUM.
2. FASTEN PLATES TO FRAMING WITH TYPE 316 STAINLESS STEEL SELF DRILLING SCREWS.
3. PROVIDE FULLY WELDED CONNECTIONS AT ALL CANOPY FRAMING CONNECTIONS WITH 3/16" MINIMUM ALL AROUND FILLET WELDS UNLESS NOTED OTHERWISE, COPE ANGLES AS NECESSARY FOR FIT UP.
4. SLOPE THE TOP OF THE CONCRETE SLAB AWAY FROM THE CANOPY CENTERLINE AT 1/4" PER 1'-0".

3/4" = 1'-0"
REF: S-3


0 1' 2' 3'

SCALE: $\frac{3}{4}" = 1'-0"$

0 1' 2' 4'

SCALE: $\frac{1}{2}" = 1'-0"$

- | | | | | | |
|---------------------|--|-----------------------|--|----------------------------|--|
| | | | | | |
| | | | | | |
| | | | | | |
| NO. | | CONSTRUCTION REVISION | | DATE | |
| PROJECT NO. UN-1219 | | | | | |
| SCALE
AS SHOWN | | SHEET
S-4 | | DRAWING
NO. 12
OF 26 | |
| | | | | WD:14475-006 | |
| | | | | | |
| | | | | MAY 2024 | |



WRA
Whitman, Requardt & Associates, LLP
801 South Caroline Street, Baltimore, Maryland 21231

PROFESSIONAL CERTIFICATION. I HEREBY CERTIFY THAT THESE DOCUMENTS
WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED
PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND.
LICENSE NO. 42863, EXPIRATION DATE: 12/2/2024.

OWNER:
CHARLES COUNTY GOVERNMENT, DPW
5310 HAWTHORNE ROAD
LA PLATA, MARYLAND 20646
301-609-7400 301-753-8270

PROJECT NO.
UN-1219

POMONKEY PUMP STATION IMPROVEMENTS

STRUCTURAL SECTIONS AND DETAILS

CHARLES COUNTY, MARYLAND
ELECTION DISTRICT NO. 6

SCALE	SHEET	DRAWING	WD:14475-006
AS SHOWN	S-4	NO. 12	
		OF 26	
			MAY 2024