

SHERWOOD-LOGAN & ASSOCIATES, INC.

WASH. (301) 970-2181

2140 RENARD COURT
ANNAPOLIS, MARYLAND 21401
FAX: (410) 841-6330

BALT: (410) 841-6810

CHARLES COUNTY POMONKEY PUMP STATION IMPROVEMENTS

SECONDARY FAN CONTROL PANEL RESUBMITTAL

SECTION 17441 - CONTROLS SYSTEM HARDWARE

March 02, 2026

ENGINEER: WRA

CONTRACTOR: JOHNSTON CONSTRUCTION

***MANUFACTURERS' REPRESENTATIVE FOR ENGINEERED INSTRUMENTATION,
PROCESS EQUIPMENT AND PUMPING SYSTEMS***

Branch Offices: RICHMOND, VA and LEOLA, PA

CHARLES COUNTY POMONKEY PUMP STATION IMPROVEMENTS

Table of Contents

Comments

Parts Index

Data Sheets

Drawing Index

Drawings

CHARLES COUNTY POMONKEY PUMP STATION IMPROVEMENTS

General Comments:

1. The wiring schematics assume a $\frac{1}{4}$ HP motor with an FLA of 5.8. Please verify and confirm the motor nameplate details for the secondary fan motor.

Resubmittal Comment Confirmations:

1. Fault Contact: Overload contact label is incorrect update as shown below.

Sherwood Logan Response:

The overload contact which turns on the fault light has been updated accordingly to trigger on fan motor overload.

2. Panel Size: Per Contract Drawing I-8, backplate width shall be 11 ft. Submitted panel widths are as follows:
 - SCP: 20.00 in.
 - SPMP-01: 31.38 in.
 - SPMP-02: 31.38 in.
 - SFAN-01: 16.00 in.

Based on Contract Drawings, UPS and PLC panels are estimated to be 20 and 30 inches wide, respectively. Total width of all panels currently comes to 149in. approximately, which will not suit the 11 ft backplate. Contractor shall minimize panel widths (to match Contract Drawings) as necessary to meet backplate width requirements.

Sherwood Logan Response:

The dimensions of the RVSS panels have been modified such that all submitted panel dimensions should fit on the 11 ft backplate.

3. SFAN-01 Horsepower Comment: In response to Contractor comment on submittal page 5/77: SFAN-01 is shown with 1/4HP motor in submittal 8-15700-01 FRP Utility Set Fan

Sherwood Logan Response:

Sherwood Logan has acknowledged that the submitted fan motor is $\frac{1}{4}$ HP.

Parts Index:

SHT	MANUFACTURER	MODEL	DESCRIPTION
1	SCE	SCE-16H1606SS6LP	Wall Mount Enclosure - NEMA 4X
1	SCE	SCE-16P16	Enclosure Back Panel
1	SCE	SCE-BVKD	NEMA 4X VENT/DRAIN
2	Schneider Electric	9001SKT38LGG31	PTT Light, 120VAC LED, Green
2	Schneider Electric	9001SKT38LRR31	PTT Light, 120VAC LED, Red
2	Schneider Electric	9001SKT38LYA31	PTT Light, 120VAC LED, Amber
3	Schneider Electric	XB4BA922	Manual Overload Reset Pushbutton
4	Schneider Electric	9001SKS43BH13	3 Position Switch, Black
5	Square D	BGL26015	Main Circuit Breaker, 15A
6	Weidmuller	7940102572	Circuit Breaker, 120VAC, 2A
7	Square D	8536-SAO11V02ES	NEMA Motor Starter / Overload
7	Square D	B9.10	Thermal Motor Overload
8	Square D	9050JCK70V20	Repeat Cycle Timer, 0.5 Sec to 999 Hours
8	Square D	8501NR61	RELAY SOCKET, 120VAC, 11 PIN, DIN
9	Phoenix Contact	3044076	Terminal Block
9	Phoenix Contact	3044092	Grounding Terminal Block
9	Phoenix Contact	3047028	Terminal End Barrier
9	Phoenix Contact	0800886	Terminal Anchor

CHARLES COUNTY POMONKEY PUMP STATION IMPROVEMENTS

Data Sheet 1

Customer:	Johnston Construction
Reference:	Charles County Pomonkey Pump Station Improvements
Date:	03/02/2026
<u>Qty</u>	<u>Description</u>
1	Mfg: SCE: Wall Mount Enclosure - NEMA 4X Model Number: SCE-16H1606SS6LP Tags/Service: ENC / Secondary Fan Control Panel Specifications: • 0.075" stainless steel type 316/316L • Flange trough collar around all sides of door opening • Pour in place oil and water resistant gasket • Hasp and staple for padlocking • Stainless steel continuous hinges • Welded mounting provision top and bottom of back • #4 brushed finish on all exterior surfaces
1	Mfg: SCE: Enclosure Back Panel Model Number: SCE-16P16 Tags/Service: ENC / Secondary Fan Control Panel Specifications: • 13"H x 13"W x 0.10"D flat subpanel • Powder coated white finish

1	Mfg: SCE: NEMA 4X VENT/DRAIN Model Number: SCE-BVKD Tags/Service: DRAIN / Secondary Fan Control Panel Specifications: • Drain and breather vent kit • Made of corrosion and UV resistant polycarbonate material • NEMA 4X rated • 10 in·lb installation torque
---	---

Data Sheet 2

Customer:	Johnston Construction
Reference:	Charles County Pomonkey Pump Station Improvements
Date:	03/02/2026
<u>Qty</u>	<u>Description</u>
1	Mfg: Schneider Electric: PTT Light, 120VAC LED, Green Model Number: 9001SKT38LGG31 Tags/Service: LT5208 / Secondary Fan Control Panel Specifications: • Plastic bezel material • 120VAC rated supply voltage • 1 C/O contact composition • 5000000 cycle mechanical durability • 0.55A rated operational current • Silver alloy contact material • 60kA, 7200VA rated short-circuit making capacity • 6kA, 720VA rated breaking capacity • Green fresnel polycarbonate lens • Green LED
1	Mfg: Schneider Electric: PTT Light, 120VAC LED, Red Model Number: 9001SKT38LRR31 Tags/Service: LT5209 / Secondary Fan Control Panel Specifications: • Plastic bezel material • 120VAC rated supply voltage • 1 C/O contact composition

	• 5000000 cycle mechanical durability • 0.55A rated operational current • Silver alloy contact material • 60kA, 7200VA rated short-circuit making capacity • 6kA, 720VA rated breaking capacity • Red fresnel polycarbonate lens • Red LED
1	Mfg: Schneider Electric: PTT Light, 120VAC LED, Amber Model Number: 9001SKT38LYA31 Tags/Service: LT5210 / Secondary Fan Control Panel Specifications: • Plastic bezel material • 120VAC rated supply voltage • 1 C/O contact composition • 5000000 cycle mechanical durability • 0.55A rated operational current • Silver alloy contact material • 60kA, 7200VA rated short-circuit making capacity • 6kA, 720VA rated breaking capacity • Amber fresnel polycarbonate lens • Yellow LED

Data Sheet 3

Customer:	Johnston Construction
Reference:	Charles County Pomonkey Pump Station Improvements
Date:	03/02/2026
<u>Qty</u>	<u>Description</u>
1	Mfg: Schneider Electric: Manual Overload Reset Pushbutton Model Number: XB4BA922 Tags/Service: RESET / Secondary Fan Control Panel Specifications: • Chromium plated metal bezel • Zamak fixing collar material • Black flush, unmarked operator profile • 5.1...10.1" activating distance • NEMA 4X degree of protection • TH protective treatment

Data Sheet 4

Customer:	Johnston Construction
Reference:	Charles County Pomonkey Pump Station Improvements
Date:	03/02/2026
<u>Qty</u>	<u>Description</u>
1	Mfg: Schneider Electric: 3 Position Switch, Black Model Number: 9001SKS43BH13 Tags/Service: SS5205 / Secondary Fan Control Panel Specifications: • Black standard knob operator profile • Stay put operator • 1 C/O contact composition • NEMA 4X degree of protection

Data Sheet 5

Customer:	Johnston Construction
Reference:	Charles County Pomonkey Pump Station Improvements
Date:	03/02/2026
<u>Qty</u>	<u>Description</u>
1	Mfg: Square D: Main Circuit Breaker, 15A Model Number: BGL26015 Tags/Service: CB5201 / Secondary Fan Control Panel Specifications: • 15A line rated current • 2 pole circuit breaker • Toggle control type • 65kA breaking capacity • 65kA rated service breaking capacity • Thermal-magnetic trip unit technology • 80% continuous current rating • 20000 cycle mechanical durability • 10000 cycle electrical durability

Data Sheet 6

Customer:	Johnston Construction
Reference:	Charles County Pomonkey Pump Station Improvements
Date:	03/02/2026
<u>Qty</u>	<u>Description</u>
1	Mfg: Weidmuller: Circuit Breaker, 120VAC, 2A Model Number: 7940102572 Tags/Service: CB5204 / Secondary Fan Control Panel Specifications: • 120VAC operating voltage • 2A current rating • 10kA interrupting capacity • 100MΩ insulation resistance • 10000 mechanical operations operating life • -40...65°C operating temperature range

Data Sheet 7

Customer:	Johnston Construction
Reference:	Charles County Pomonkey Pump Station Improvements
Date:	03/02/2026
<u>Qty</u>	<u>Description</u>
1	Mfg: Square D: NEMA Motor Starter / Overload Model Number: 8536-SAO11V02ES Tags/Service: M5205 / Secondary Fan Control Panel Specifications: • Non-reversing starter type • NEMA size 00 • 9A rated current • 0.33HP at 115VAC • 120VAC 60 Hz coil voltage • Open enclosure type
1	Mfg: Square D: Thermal Motor Overload Model Number: B9.10 Tags/Service: OL5201 / Secondary Fan Control Panel Specifications: • Class 20 motor tripping class • Melting alloy thermal overload type

Data Sheet 8

Customer:	Johnston Construction
Reference:	Charles County Pomonkey Pump Station Improvements
Date:	03/02/2026
<u>Qty</u>	<u>Description</u>
1	Mfg: Square D: Repeat Cycle Timer, 0.5 Sec to 999 Hours Model Number: 9050JCK70V20 Tags/Service: RCT / Secondary Fan Control Panel Specifications: • 120VAC operating voltage • 0.5 second to 999 hour programmable timing range • 3 VA power burden • 10 million mechanical operations operating life • 100,000 electrical operations operating life • Silver nickel contact material
1	Mfg: Square D: RELAY SOCKET, 120VAC, 11 PIN, DIN Model Number: 8501NR61 Tags/Service: RCT / Secondary Fan Control Panel Specifications: • DIN rail mounted relay socket • Single tiered screw clamp terminal electrical connection • 15A rated at 300VAC

Data Sheet 9

Customer:	Johnston Construction
Reference:	Charles County Pomonkey Pump Station Improvements
Date:	03/02/2026
<u>Qty</u>	<u>Description</u>
A/R	Mfg: Phoenix Contact: Terminal Block Model Number: 3044076
A/R	Mfg: Phoenix Contact: Grounding Terminal Block Model Number: 3044092
A/R	Mfg: Phoenix Contact: Terminal End Barrier Model Number: 3047028
A/R	Mfg: Phoenix Contact: Terminal Anchor Model Number: 0800886 Tags / Service: TB-AC / Secondary Fan Control Panel Specifications: • Feed through and grounding terminals • Screw clamps • End plates and anchors • DIN rail mount

CHARLES COUNTY POMONKEY PUMP STATION IMPROVEMENTS

Drawings Index:

Drawing Number	Drawing Description
D32384-50	POMONKEY PS SFAN CONTROL PANEL EXTERIOR PANEL LAYOUT
D32384-51	POMONKEY PS SFAN CONTROL PANEL INTERIOR PANEL LAYOUT
D32384-52	POMONKEY PS SFAN CONTROL PANEL 120VAC WIRING DIAGRAM

CHARLES COUNTY POMONKEY PUMP STATION IMPROVEMENTS

Drawings: