Toxicology and Environmental Health Sciences
https://doi.org/10.1007/s13530-025-00294-4

ORIGINAL ARTICLE

AI-driven portable smartphone-based sensor for microplastic detection: a comprehensive review

Perumalla Akhil[1] · B. Nagashubha[1] · Mallam Sree Lakshmi[1] · Vallabhi Sowmya[1] · Gujjala Sonu[1] · Shaik Yashmeen Banu[1] · Chakali Veeresh[1] · Charitha Bandlapalli[1] · Maccha Kiran Sai[1]

Received: 24 September 2025 / Accepted: 4 December 2025
© The Author(s), under exclusive licence to Korean Society of Environmental Risk Assessment and Health Science 2025

Abstract

Background Microplastic pollution is a major environmental concern, with millions of metric tons entering the oceans yearly, threatening marine ecosystems and human health. This underscores the urgency for accessible, real-time microplastic detection technologies.

Objectives This review examines the fusion of artificial intelligence (AI) with smartphone-based sensors, aiming to develop portable, cost-efficient microplastic detection systems, and ushering a transition from laboratory-centered to distributed environmental monitoring.

Methods The review covers traditional microplastic detection methods such as FTIR and Raman spectroscopy and introduces emerging AI-driven techniques. It discusses advances in optical sensing (plasmonic nanowhiskers, fluorescence staining, colorimetric assays) and AI models, such as CNNs, YOLOv8, and U-Net. Smartphone hardware and computational advancements are also evaluated.

Results AI-enhanced smartphone sensors show detection accuracies between 96% and 99.3%, outperforming conventional microscopy and approaching laboratory-level precision. These systems detect sub-micron microplastics efficiently, supported by economic analyses favoring wide deployment.

Conclusions AI-integrated smartphone sensors are transformative tools for environmental monitoring, offering portability, accuracy, and affordability. Continued innovation and regulatory support are essential for global adoption and effective microplastic pollution management.

Keywords Microplastic detection · Artificial intelligence · Smartphone sensors · Portable detection · Machine learning · CNN · Pollution management · Environmental health · Edge computing · Nanoplastics

Introduction

Microplastic pollution has emerged as a critical environmental issue in the twenty-first century. An estimated 11 million metric tons of plastic waste enter the oceans each year [1], posing serious risks to marine ecosystems and human health through bioaccumulation [2, 3]. Detection of microplastics, typically smaller than 5 mm, in drinking water, food, and human tissues [4] calls for accessible, accurate, and real-time detection technologies [5–7].

✉ B. Nagashubha
naga.shubha531@gmail.com

[1] Department of Pharmaceutics, Raghavendra Institute of Pharmaceutical Education and Research Campus, Ananthapuramu, Andhra Pradesh 515721, India

Traditional detection challenges

Traditional methods such as FTIR and Raman spectroscopy provide high accuracy but are costly, time-consuming, and unsuitable for field deployment [8–10]. Microscopy is labour-intensive and prone to error. These laboratory-centric approaches create significant barriers to comprehensive environmental monitoring, particularly in resource-limited regions and developing countries where microplastic pollution is increasingly prevalent (Figs. 1, 2, 3, 4, 5, 6, 7, 8).

Smartphone-based sensors: a paradigm shift

Recent advances integrating artificial intelligence with smartphone capabilities have fostered portable, cost-effective detection systems allowing real-time data collection



Fig. 1 Convolutional neural network method for detection of microplastic

even in resource-limited settings [11, 12]. Smartphones, now ubiquitous globally with over 6 billion devices in use, represent an unprecedented opportunity for democratizing environmental monitoring. Modern smartphones are equipped with:

- **Advanced imaging hardware**: High-resolution CMOS sensors (typically 12–108 megapixels) with computational photography capabilities
- **Powerful processors**: Equipped with Neural Processing Units (NPUs) and Graphics Processing Units (GPUs) enabling on-device AI inference
- **Sophisticated optics**: Multiple camera systems with macro-focusing capabilities, enabling visualization of particles as small as 10–20 µm
- **Integrated sensors**: Proximity sensors, light sensors, and environmental sensors providing contextual data
- **Connectivity infrastructure**: Wi-Fi, 4G/5G, Bluetooth Low Energy (BLE), and NFC for seamless data transmission and IoT integration

Smartphone sensors for microplastic detection

The integration of smartphone sensors with optical attachments creates powerful detection platforms. Key sensor components include:

Optical attachments

- **Macro lenses** (external or clip-on): Enable magnification up to 60–100x, facilitating visualization of particles in the 10–20 µm range



Fig. 2 YOLOv8 (you only look once—Version 8) rapid identification



Fig. 3 Microplastic detection using support vector machines (SVM)



Fig. 4 Microplastic detection using U-Net architectures

- **Fluorescence filter arrays**: Paired with LED excitation sources (365–480 nm wavelength), enabling detection of microplastics stained with fluorophores like Nile Red
- **Plasmonic nano-whisker arrays**: Integrated surface modifications that amplify optical signals via localized surface plasmon resonance (LSPR), achieving sub-micron sensitivity
- **SERS-active substrates**: Surface-enhanced Raman scattering (SERS) substrates integrated into microfluidic chambers enable spectral analysis directly on-device

Sensor integration features

- **High-speed imaging**: Frame rates up to 240 fps enabling dynamic particle tracking and motion analysis
- **Multispectral imaging**: Simultaneous capture across multiple wavelengths (visible, near-infrared) for comprehensive particle characterization
- **Thermal imaging**: Emerging smartphones with thermal cameras enable temperature-dependent detection and analysis of thermoplastics



Fig. 5 AI Model validation and performance in microplastic detection

AI-driven detection advantages

CNNs, YOLO, and U-Net models deliver high detection accuracy, rapid processing, and the ability to distinguish plastics from organic debris [13–15]. These AI architectures, when integrated into smartphone applications, provide:

- **Real-time analysis**: Processing speeds from 1.2 to 35 ms per image enable continuous monitoring
- **High accuracy**: Detection accuracies of 96–99.3% rival laboratory instruments
- **Automated classification**: Distinguish microplastics from morphologically similar contaminants (organic matter, minerals)



Fig. 6 Portable mini-lab for microplastic detection

- **On-device processing**: Edge computing capabilities reduce dependency on cloud infrastructure, enabling deployment in remote locations
- **User-friendly interfaces**: Mobile applications abstract complex AI models, making detection accessible to non-technical operators

Scope of this review

This comprehensive review covers state-of-the-art AI-enabled smartphone-based detection technologies, including:

- Sensing mechanisms and optical technologies
- Machine learning and deep learning architectures
- Hardware integration and computational platforms
- Real-world environmental and industrial applications
- Sample preparation protocols and field deployment strategies
- Challenges, standardization efforts, and future prospects

Materials and Methods

Comparison of detection methodologies

Traditional laboratory versus AI-smartphone detection

Table 1.

AI models, smartphone sensors, and detection limits: integrated comparison

Comprehensive performance matrix

Table 2.

Portable sensor technologies for microplastic detection

Emerging portable sensor platforms

Smartphone-integrated optical systems

Modern smartphone-based sensor platforms combine multiple optical technologies in portable, integrated form factors:

- **Clip-on macro lens modules**: Magnetic or screw-mount external lenses providing 60–100 × magnification without compromising smartphone optical design
- **Built-in spectrometers**: Miniaturized spectrometer modules (size: 5 × 5 cm) integrated into phone cases, enabling spectral analysis of captured images
- **Microfluidic cartridges**: Disposable, single-use cartridges containing sample preparation chambers with



Fig. 7 Working procedure for nano whiskers



Fig. 8 Microplastic detection using fluorescence

Table 1 Comprehensive comparison of detection methodologies

Attribute	Traditional lab	AI-smartphone	Advantage
Equipment cost	$50 k+	$0.5 k–2 k	25–100 × cost reduction
Detection accuracy (%)	95–99	96–99.3	Comparable/Superior
Particle size limit (μm)	1–20	0.5–20	Enhanced sub-micron capability
Sample prep time (h)	3–5	< 1	3–5 × faster preparation
Portability	Low	High	In-situ analysis capability
Throughput (particles/min)	10–50	100+	2–10 × higher throughput
Operator training	Extensive (months)	Minimal (hours)	Democratized access
Infrastructure Req	High	Low	Scalability to remote areas
Operational cost ($/sample)	$5–20	$0.10–0.50	10–100 × reduction
Real-time capability	Limited	Yes	Immediate decision-making

Table 2 Integrated comparison of AI models, sensors, and performance metrics for microplastic detection

AI Model/Sensor Type	Detection Accuracy (%)	Detection Limit (μm)	Processing Speed (ms)	Power Consumption (mW)	Best Application
CNN (Convolutional Neural Network)	95–97	1–10	15–25	250–400	Image classification, feature extraction
YOLOv8 (You Only Look Once v8)	98–99.3	0.5–20	1.2–3.5	150–250	Real-time object detection, multi-particle localization
U-Net Architecture	96–98	1–15	20–35	300–500	Precise pixel-level segmentation, fiber differentiation
Support Vector Machine (SVM)	92–96	5–20	8–12	50–100	Classification with limited data sets, feature-based analysis
Smartphone Camera + Macro Lens	90–94	10–20	30–50	200–300	Morphological imaging, visual inspection
Fluorescence Sensor (Nile Red Staining)	94–97	2–15	5–10	100–200	Polymer-specific detection, high-contrast visualization
Plasmonic Nano-whisker Arrays	96–99	0.5–5	2–6	80–150	Sub-micron sensitivity via LSPR enhancement
SERS-based Sensor	95–98	1–10	10–20	120–180	Chemical fingerprinting, polymer identification

LSPR localized surface plasmon resonance; *SERS* surface-enhanced raman scattering

integrated optical windows; compatible with smartphone cameras via simple clipping mechanisms

- **LED excitation arrays**: Compact multi-wavelength LED arrays (365 nm UV, 470 nm blue, 530 nm green, 625 nm red) mounted on phone cases for fluorescence-based detection

Wearable and portable mini-lab systems

Beyond smartphones, portable detection platforms include:

- **Wearable spectroscopy modules**: Smartwatch-sized FTIR or Raman spectrometers connected via Bluetooth to smartphones for real-time analysis
- **Portable mini-lab kits**: Briefcase-sized systems combining sample preparation, optical detection, and processing in field-deployable packages
- **Microfluidic-on-smartphone devices**: Lab-on-chip systems using paper or polymer microfluidic channels directly integrated onto smartphone surfaces

IoT-enabled sensor networks

Integration with Internet of Things (IoT) frameworks enables distributed monitoring:

- **Autonomous sampling stations**: Solar-powered robotic samplers equipped with smartphone-grade sensors for continuous, unattended monitoring
- **Drone-based aerial systems**: Unmanned aerial vehicles (UAVs) carrying smartphone-compatible sensors for surveying water bodies and coastal regions
- **Underwater remotely operated vehicles (ROVs)**: Waterproofed smartphone-grade sensors mounted on submersible platforms for deep water and sediment monitoring

Distinction between microplastics and nanoplastics: analytical challenges

Definition and size classification

Table 3.

Technical distinctions and analytical implications

Microplastics (1–5000 μm):

- **Optical properties**: Light scattering dominates; particles visible under optical microscopy
- **Detection methods**: FTIR, Raman, fluorescence microscopy, smartphone cameras with macro lenses
- **Smartphone detection capability**: **excellent** – standard smartphone imaging with macro lenses and AI models achieve 96–99% accuracy
- **Challenges**: Distinguishing from morphologically similar organic debris; staining protocols may cause artifacts
- **Field deployment**: Highly practical; numerous successful case studies documented

Nanoplastics (1–1000 nm)

- **Optical properties**: Primarily electronic absorption and Rayleigh scattering; optical diffraction limits (~200 nm with visible light) become problematic
- **Detection methods**: High-resolution TEM (transmission electron microscopy), atomic force microscopy (AFM),

Table 3 Size-based classification and detection capability matrix for plastic particles

Classification	Size range	Analytical challenge	Detection methods	Current smartphone capability
Macroplastics	> 25 mm	Visible to naked eye	Visual inspection, manual removal	Excellent (trivial)
Mesoplastics	5–25 mm	Visual inspection with magnification	Microscopy, visual sorting	Excellent (macro lens)
Microplastics	1–5 mm to 1 μm	Requires magnification and spectral analysis	FTIR, Raman, smartphone AI	Very good (0.5–20 μm range)
Nanoplastics	< 1 μm to 1 nm	Extreme technical challenge; optical diffraction limits	TEM, AFM, hyperspectral Raman	Challenging (below optical diffraction limit)
Sub-nanoplastics	< 1 nm	Single molecule scale; requires advanced techniques	Molecular dynamics simulation, mass spectrometry	Not feasible

hyperspectral Raman, single-particle inductively coupled plasma mass spectrometry (sp-ICP–MS)

- **Smartphone detection capability**: **Severely limited**—standard smartphone optics insufficient; requires advanced plasmonic or SERS enhancement techniques to approach nanoplastic regime
- **Challenges**:
  - Optical resolution fundamentally limited by wavelength of visible light (~ 400–700 nm).
  - Diffraction-limited imaging cannot directly resolve particles < 200 nm.
  - Nanoplastics require near-field optical techniques or chemical enhancement.
  - Sample aggregation and settling complicate quantification.
  - Charge-based interactions cause artifacts during sample preparation.
- **Field deployment**: Limited practical implementation; primarily research-grade instruments required.

Smartphone-based approaches for nanoplastic detection

To extend smartphone capabilities toward nanoplastic detection:

Plasmonic enhancement techniques

- **Localized surface plasmon resonance (LSPR)**: Gold or silver nano-whisker arrays on sensor surfaces create localized electromagnetic field enhancements (10–100 × improvement)
- **Achievement**: Can effectively reduce detection limit from ~ 10 μm to ~ 0.5–5 μm range, partially bridging the microplastic–nanoplastic gap
- **Limitation**: Still insufficient for true nanoplastics (< 1 μm); effective for ultra-small microplastics at the micron/sub-micron boundary

SERS-based approaches

- **Surface-enhanced Raman scattering**: Nanostructured surfaces amplify Raman signals by $10^{4-}10^{6}$ fold
- **Achievement**: Enables detection of nanoplastics via spectral fingerprinting rather than direct imaging
- **Limitation**: Requires sophisticated substrate preparation; not truly "smartphone-simple"; still challenging for most nanoplastics

Nanoparticle tracking analysis (NTA) integration

- **Dark-field imaging**: Smartphone cameras detect scattered light from gold-labeled nanoparticles bound to nanoplastics
- **Achievement**: Indirect detection of nanoplastics in the 50–500 nm range via optical scattering
- **Limitation**: Requires nanoparticle labeling; adds complexity; indirect measurement

Current limitations and research gaps

- **Fundamental optical limit**: Standard visible-light microscopy cannot resolve objects < 200 nm due to diffraction limit
- **Nanoplastic heterogeneity**: Nanoplastics exhibit diverse composition, size, and shape; no universal detection standard
- **Standardization absence**: ISO and ASTM standards for nanoplastics are under development; no consensus methodology exists
- **Environmental matrices**: Complex environmental samples contain high background noise interfering with nanoplastic detection
- **Regulatory framework**: Most current microplastic regulations focus on particles > 20 μm; nanoplastic regulation remains nascent

Future directions: Advances in super-resolution imaging techniques (STED, structured illumination microscopy) integrated with smartphone platforms may eventually enable

nanoplastic detection, but this remains a frontier challenge requiring interdisciplinary innovation combining optics, materials science, and computational methods.

Sample preparation challenges and contamination risks in field conditions

Critical bottlenecks in real-world application

Sample preparation represents one of the most significant bottlenecks limiting real-world deployment of microplastic detection systems, particularly in field conditions. These challenges are compounded by environmental heterogeneity, operator variability, and contamination risks inherent to distributed monitoring scenarios.

Sample preparation protocols and associated challenges

Water sample preparation

Table 4.

Soil and sediment sample preparation

- **Dry matter concentration**: High organic and mineral content complicates microplastic isolation
- **Matrix complexity**: Soil texture, moisture content, and mineral composition vary widely, affecting extraction efficiency
- **Density separation challenges**: Traditional heavy liquid separation (zinc chloride, sodium iodide) difficult to deploy in field; creates hazardous waste
- **Enzymatic pre-treatment**: Emerging protocols using cellulase and protease require controlled conditions (pH, temperature, incubation time)
- **Contamination from soil contact**: Handling procedures introduce microplastics from clothing fibers and environmental dust

Food and biological sample preparation

- **Organic matrix degradation**: Chemical digestion of protein, lipid, and carbohydrate components must be rigorous to avoid microplastic interference
- **Sample complexity**: Seafood, processed foods, and biological tissues contain diverse organic matrices requiring method optimization per sample type
- **Contamination risk**: Laboratory cross-contamination from airborne microfibers; use of plastic equipment introduces artifacts

Table 4 Water sample preparation challenges and field deployment considerations

Step	Standard protocol	Field challenges	Contamination risk	Mitigation strategies
Collection	Sterile glass bottles, no plastics	Plastic contamination from non-compliant containers	Airborne microplastics, cross-contamination	Use metal containers, pre-cleaned glassware; minimize air exposure
Storage	4 °C, dark conditions, <48 h	Temperature control unavailable; extended storage in field	Growth of biofilms; sample degradation	Portable coolers; chemical preservatives (sodium azide, formalin)
Filtration	Vacuum filtration through 0.5 µm filters	Rapid filter clogging in turbid samples; high organic load	Filter contamination; loss of fine particles	Pre-filtration (> 100 µm); sequential filtering approach
Acid Digestion	H_2SO_4 or HNO_3 digestion (24–72 h)	Extended time; requires controlled lab conditions; safety hazards	Incomplete digestion; filter degradation in acidic conditions	Field-compatible enzymatic digestion protocols (e.g., protease)
Oxidative Treatment	H_2O_2/KOH treatment (30% H_2O_2, 10 h @ 60 °C)	Heat control; reagent stability; disposal concerns	Microplastic degradation; incomplete organic removal; hydrogen evolution	Optimized low-temperature protocols; environmental pH adjustment
Staining	Nile Red (fluorescence labeling) or other dyes	Stain uniformity; aggregation; photobleaching	False positives from non-plastic particles; stain bleed-through	Multiplexed staining; standardized concentration and incubation protocols
Rinsing	DI water, multiple rinses	Water purity; microplastic recontamination	Introduction of contaminant microplastics from tap water	Use of ultra-pure water (18.2 MΩ.cm); filtered rinse water

- **Quantification challenge**: Microplastics in complex matrices difficult to isolate and quantify; standardization lacking

Field-specific contamination risks

Airborne microplastic contamination

- **Environmental microfiber shedding**: Operator clothing, laboratory coats, and equipment emit microplastics at rates of 0.02–0.5 fibers per minute
- **Air quality dependence**: Indoor laboratories typically contain 10–100 airborne microfibers per cubic meter
- **Mitigation**: Field protocols require specialized clothing (Tyvek suits, nitrile gloves), protective equipment, and air filtration systems
- **Cost and logistics**: Deployment of contamination-control measures adds complexity and expense to field operations

Reagent and supply chain contamination

- **Chemical purity**: Commercial reagents may contain microplastic contaminants from packaging and manufacturing
- **Filter contamination**: Filtration materials themselves may be sources of microplastics; pre-filtration screening required
- **Glassware and equipment**: Even "sterile" laboratory materials may contain contaminant microplastics
- **Mitigation**: Batch testing of all consumables; pre-screening reagents; dedicated, segregated equipment for microplastic work

Environmental and weather-related contamination

- **Dust and precipitation**: Outdoor sampling introduces airborne microplastics and moisture that complicates analysis
- **Temperature and humidity effects**: Field conditions cause sample degradation, evaporation, and microbial growth
- **Water quality variability**: Natural water bodies show high temporal and spatial variability; single-point samples may not represent conditions
- **Seasonal variations**: Winter conditions may freeze samples; summer heat accelerates degradation; operational windows may be limited

Practical field-deployable solutions

Simplified sampling and preparation kits

- **All-in-one cartridges**: Pre-assembled, single-use sample preparation cartridges eliminating transfer steps and contamination opportunities
- **Enzymatic digestion pads**: Cellulose-based pads impregnated with enzymatic cocktails (protease, cellulase, lipase) for rapid, field-compatible organic degradation
- **Integrated microfluidics**: Miniaturized microfluidic channels combining filtration, staining, and optical detection in single-device format
- **Passive sample concentration**: Gravity or capillary-driven concentration eliminating need for pumps or active power

Quality assurance protocols for field use

- **Blank sample replicates**: Processing of field blanks (sterile water, unused filters) alongside samples to quantify background contamination
- **Positive control standards**: Reference microplastic standards (known composition, size, quantity) processed through full protocol to validate methodology
- **Duplicate sampling**: Collection of field replicates to assess spatial and temporal variability; distinguish true environmental signal from procedural artifacts
- **Chain-of-custody documentation**: Rigorous tracking of samples from collection through analysis, with photography and geolocation data

Standard operating procedures (SOPs) for field deployment

Organizations deploying smartphone-based microplastic detection should establish field-specific SOPs addressing:

- **Pre-deployment equipment calibration**: Verification of sensor functionality, camera focus, and AI model performance using reference standards
- **Environmental monitoring**: Documentation of weather conditions, water temperature, turbidity, pH, and other parameters affecting sample quality
- **Operator training and certification**: Standardized training protocols ensuring consistent sample handling and analysis across operators
- **Data validation and quality control**: Statistical screening of results to identify anomalies, outliers, or instrument drift
- **Documentation and metadata**: Comprehensive recording of collection location, time, environmental conditions, operator identity, and analysis parameters

Computational constraints and edge computing optimization

Power and computational challenges in smartphone deployment

While smartphones provide unprecedented computational power, real-world field deployment reveals significant constraints:

Battery limitations

- **Typical smartphone battery**: 3000–5000 mAh; capable of supporting 8–12 h moderate use
- **AI inference demands**: Deep learning models consume 150–500 mW; continuous operation depletes battery in 6–8 h
- **Field scenarios**: Remote locations may lack charging infrastructure; multi-day monitoring campaigns are limited
- **Solution complexity**: Solar charging, power-efficient algorithms, and intelligent sampling strategies required

Memory and storage constraints

- **Model size limitations**: Full-resolution deep learning models (CNNs, YOLOv8) require 100–500 MB; storage constraints necessitate model compression
- **Image buffering**: High-resolution image processing creates temporary memory spikes; garbage collection pauses disrupt real-time analysis
- **Cloud synchronization**: Continuous upload of data and images requires high bandwidth; limited connectivity in remote locations
- **Local storage**: Limited device storage (64–256 GB typical) insufficient for long-term monitoring campaigns storing high-resolution images

Edge computing strategies for optimization

On-device AI inference (edge computing)

- **Model quantization**: Reducing neural network precision (32-bit → 8-bit integers) reduces model size by 4 × with minimal accuracy loss
- **Model distillation**: Training smaller "student" models to mimic larger “teacher” models; can achieve 50–70% size reduction
- **Pruning and sparsity**: Removing non-critical neurons and connections; achieves 10–50% size reduction with maintained accuracy
- **Neural architecture search (NAS)**: Automated optimization of network architectures specifically for mobile devices (e.g., MobileNet and EfficientNet)
- **Achievement**: Modern optimized models run on smartphones at 50–150 mW power consumption with minimal accuracy degradation

Hybrid cloud-edge processing

- **Tiered inference**: Fast, lightweight initial classification on-device; detailed analysis offloaded to cloud servers when connectivity available
- **Smart caching**: Results from previous analyses cached locally; similar samples bypass cloud processing
- **Asynchronous uploading**: Non-critical data (metadata, summary statistics) uploaded during periods of high connectivity; high-bandwidth image data queued
- **Advantage**: Balances real-time responsiveness with computational rigor; reduces network bandwidth requirements by 60–80%

Recent advances in edge computing for microplastic detection

Specialized AI accelerators

Modern smartphones increasingly incorporate specialized processors:

- **Neural processing units (NPUs)**: Dedicated hardware for AI inference; 5–10 × more efficient than general GPUs for neural networks
- **Tensor processing units (TPUs)**: Google's specialized processors offering 10–100 × speedup for tensor operations
- **Qualcomm hexagon**: Qualcomm's AI engine optimized for mobile devices; achieves 10 TOPS (tera operations per second) with minimal power consumption
- **Apple neural engine**: Integrated into Apple devices since A11 Bionic; provides hardware acceleration for Core ML models

Emerging optimization techniques

- **Federated learning**: Distributed model training across multiple devices without centralizing data; privacy-preserving approach for sensitive environmental monitoring
- **Transfer learning**: Pre-training on large data sets followed by fine-tuning on task-specific data; reduces computational requirements by 50–70%
- **Adaptive inference**: Model complexity adjusted dynamically based on available resources and data characteristics
- **Continual learning**: Models updated incrementally with new data collected in field, improving performance over deployment lifetime

Future innovations in computing infrastructure

Photonic and optical computing

- **Photonic neural networks**: Using optical photons instead of electrical signals; potentially 100 × more energy efficient

- **Optical diffraction**: Using diffracted light patterns for rapid computation without traditional silicon transistors
- **Status**: Emerging technology; smartphone integration likely within 3–5 years

Quantum computing integration

- **Quantum speedup**: Quantum algorithms for optimization and machine learning potentially exponentially faster for specific problems
- **Hybrid quantum–classical**: Near-term approach combining classical smartphones with cloud-based quantum accelerators
- **Status**: Experimental; practical implementation in microplastic detection likely 5–10 + years away

Neuromorphic computing

- **Brain-inspired architectures**: Computing systems mimicking biological neural organization; inherently energy-efficient
- **Event-based processing**: Only activate computation when data changes, avoiding unnecessary power consumption
- **Status**: Early stage development; some commercial neuromorphic chips available; smartphone integration emerging

Methodology for detection of microplastic

Current state of microplastic detection technologies

Traditional laboratory methods

Laboratory methods such as FTIR and Raman spectroscopy remain gold standards by providing chemical identification of plastics [16–18].

- **FTIR spectroscopy**: Analyzes infrared absorption signatures specific to polymer functional groups; provides definitive chemical identification
    - Detection limit: Struggles with particles below 20 µm
    - Accuracy: 95–99% when combined with morphology
    - Challenges: Time-consuming (20–40 min per sample); expensive equipment; requires sample preparation
- **Raman spectroscopy**: Detects vibrational modes of polymers; highly specific
    - Detection limit: Down to 1 µm in optimal conditions
    - Challenges: Fluorescence interference; sample degradation from laser heating; specialized expertise required
- **Microscopy techniques** (optical and electron-based): Provide morphology but lack automation
    - Accuracy: Approximately 65% without spectral confirmation
    - Limitations: Operator-dependent; time-intensive; limited to morphological differentiation

Emerging and portable detection techniques

Portable devices now leverage fluorescence staining (e.g., Nile Red) [19, 20], mini Raman and FTIR spectrometers, and smartphone-compatible optical systems [21, 22]. These portable instruments enable:

- Field-ready, rapid microplastic detection with improved accessibility and cost efficiency [23–25]
- Integration with AI (CNNs, YOLO, and U-Net) for automated image analysis achieving detection accuracy > 95%
- Citizen science participation and flexible monitoring networks
- Challenges: sample preparation for field conditions remains complex; nanoplastic detection limited

Limitations of CURRENT APPROACHES

- Laboratory dependency restricts monitoring scope and frequency
- High capital costs ($50 k–200 k for equipment) limit deployment in developing regions
- Sample preparation introduces contamination and time delays (3–5 h)
- Personnel expertise requirements restrict accessibility
- Result turnaround time (days to weeks) precludes real-time response

AI models and smartphone integration

AI algorithms and models

Convolutional neural networks (CNNs)

Convolutional neural networks are deep learning architectures designed for processing image data [26–28]. In

microplastic detection, CNNs automatically extract hierarchical features, such as:

- Geometric characteristics (shape, size, aspect ratio, perimeter)
- Texture features (surface roughness, pattern uniformity)
- Optical properties (color, brightness, translucency)
- Boundary definition (edge sharpness, morphological complexity)

Performance metrics

- Reported accuracies exceeding 95%[29–31]
- Well-known variants like ResNet improve training efficiency via skip connections
- Capability to distinguish microplastics from morphologically similar organic debris (diatoms, algae spores, mineral particles)

YOLOv8 (you only look once—Version 8)

YOLOv8 is an advanced real-time object detection framework processing entire images in single neural network pass, enabling:

- Rapid identification and localization of multiple particles simultaneously
- Grid-based approach predicting bounding boxes and classification probabilities
- Achieves high accuracy (approximately 99%) with low latency (inference times 1.2 ms per image)
- Incorporates modern improvements: anchor-free detection, enhanced data augmentation
- Particularly suited for resource-constrained smartphone deployment[32, 33]

U-Net architectures

U-Net excels at image segmentation tasks, providing:

- Precise boundary detection for irregularly shaped microplastic particles
- Encoder–decoder structure enabling accurate pixel-level classification
- Measurement of particle dimensions and morphological analysis [34]
- Differentiation of microplastic fibers from natural organic materials
- Validation accuracy above 96% with minimal loss

Support vector machines (SVMs)

Support vector machines are classical machine learning models effective for classification:

- Particularly useful with limited data sets
- Process features extracted from spectral data or images
- Differentiate between plastic and non-plastic particles
- High accuracy when combined with hyperspectral imaging
- Complementary strengths to deep learning models

Validation and model performance

Extensive validation studies employing these AI models demonstrate:

- Detection accuracies ranging from 95% to over 99%
- Robust generalization to diverse environmental samples[35]
- Employment of cross-validation, transfer learning, and data augmentation to enhance reliability
- Mitigation of overfitting and improved model robustness

Smartphone hardware and sensor integration

Imaging systems

Modern smartphones are equipped with:

- High-quality cameras featuring sophisticated optics and sensitive CMOS sensors with pixel sizes below 1 µm
- Detailed imaging of microplastic particles capturing morphological and optical features necessary for accurate identification
- Computational photography techniques (multi-frame processing, autofocus, noise reduction) enhancing image quality under challenging conditions

Optical attachments and sensor enhancements

Macro lenses: Enable close-up imaging at high magnifications, facilitating visualization of microplastics as small as 10–20 µm.

Fluorescence filters: Paired with LED excitation sources enhance detection of microplastics dyed with specific fluorophores like Nile Red[36]

Plasmonic nanostructures (nano whiskers): Integrated with sensor surfaces amplify optical signals via

localized surface plasmon resonance (LSPR)[37], boosting detection sensitivity by 10–100 fold when microplastics bind to sensor surfaces[38, 39]

SERS substrates: Surface-enhanced Raman scattering provides chemical fingerprinting with $10^{4-}10^{6}$ fold signal amplification.

Instrumentation and data processing

Smartphones now incorporate:

- Powerful processors equipped with Neural Processing Units (NPUs) and Graphics Processing Units (GPUs)
- Execution of complex deep learning and image processing algorithms locally
- Reduced dependency on external computational resources
- Real-time diagnostics in remote locations with limited or no internet connectivity

Edge computing architectures: Balance local and cloud processing.

- Fast initial inference on-device
- Leveraging cloud services for extensive analysis and long-term data aggregation
- Optimization of power consumption while maintaining high data accuracy and accessibility

Connectivity and collaborative monitoring

Integrated connectivity options include:

- Wi-Fi, 4G/5G cellular networks, Bluetooth Low Energy (BLE), Near Field Communication (NFC)
- Seamless data transfer between smartphones, cloud platforms, and other sensor devices
- Collaborative environmental monitoring, real-time reporting, and IoT framework integration
- Scalable, networked microplastic surveillance

Power and resource optimization

Power efficiency critical for field-deployable devices:

- Energy-efficient algorithms, adaptive sampling strategies, power management techniques prolong operational lifetime
- Support for continuous monitoring several hours on single charge
- Memory and storage optimization through model compression and progressive data loading

Results & Discussion

Optical detection mechanisms and technologies

Technologies such as plasmonic nano whisker arrays amplify nanoscale light-matter interaction [40, 41], while surface-enhanced Raman scattering (SERS) boosts polymer-specific chemical detection. Fluorescence using Nile Red dye improves visibility of microplastics [42]. Colorimetric methods leverage AI for effective detection in variable lighting through color calibration techniques.

Performance metrics and validation studies

Robust validation of AI-driven smartphone-based microplastic detection platforms is integral for regulatory acceptance, field deployment, and research credibility [43]. Multiple performance metrics—accuracy, sensitivity, throughput, and cost—are evaluated relative to laboratory standards.

Detection accuracy and sensitivity

Recent studies employing deep learning algorithms (e.g., YOLO, CNNs, and U-Net) with smartphone imaging platforms report validated detection accuracies ranging from 96% to 99.3% across diverse environmental matrices. For example, a YOLOv5 model trained on ~ 2500 images of microplastics captured with a $10 smartphone microscope achieved overall detection accuracy of 98% and mean average precision (mAP@0.5) of 93.5% [44]. U-Net, renowned for pixel-level segmentation, achieved validation accuracy above 96%, outperforming alternative deep learning architectures in precise boundary mapping.

Specificity: These models distinguish microplastics from visually similar materials with false positive rates typically below 5%

Detection limits: Improved to as low as 0.5 µm under ideal conditions suitable for most microplastic classes. Field-deployable smartphone kits routinely detect and quantify particles from 1 to 20 µm.

Validation: Results independently validated using FTIR, Raman, and electron microscopy, confirming both presence and morphology of microplastics.

Processing speed and throughput

AI-driven detection models running on smartphones demonstrate remarkable inference speeds:

- Typical processing times: 1.2–35 ms per image
- Enables real-time analysis and continuous, high-throughput monitoring
- Significant leap over manual microscopy requiring hours per sample
- Automated quality control algorithms (cross-validation, confusion matrix analysis, real-time feedback) ensure reliability and consistency

Throughput: Smartphone-based platforms process hundreds of images or particles per minute, making them compatible with:

- Large-scale screening campaigns
- Remote surveillance
- Time-sensitive case investigations in aquatic, industrial, or food settings [45]

Cost-effectiveness analysis

Cost advantages of smartphone-based AI solutions are substantial:

- **Equipment costs**: \$500–2,000 vs. \$50,000 + for conventional FTIR or Raman spectrometers
- **Per-sample operational costs**: < \$0.50 (elimination of expensive laboratory reagents, lower labour requirements, minimized sample transport logistics)
- **Return on investment**: Often achieved within less than a year for routine monitoring programs

Outcomes: Financial accessibility democratizes microplastic detection, extending surveillance to citizen scientists, resource-limited countries, and enabling regulatory agencies to increase monitoring frequency and effectiveness.

Environmental applications and case studies

Water quality monitoring

Microplastics are pervasive across marine, freshwater, and drinking water systems, making their detection and quantification a high priority [46].

Marine systems: Portable systems deployed for mapping microplastic concentrations in coastal zones, offshore regions, and estuaries [32, 44, 47]. Field studies utilizing smartphone-based microscopy and deep learning models (YOLO, CNNs) demonstrate rapid screening of water samples, delivering real-time geographic mapping and contamination hotspot identification [48]

Freshwater monitoring: Rivers, lakes, and groundwater increasingly surveyed using smartphone devices with dense spatial and temporal coverage [49]. Enhanced accessibility enables early detection of pollution events, supports regulatory compliance, and aids water resource management [50–52]

Drinking water networks: Smartphone platforms provide on-site, immediate readouts for microplastic contamination in municipal supplies, treatment plants, and bottled water. These systems meet growing regulatory requirements for frequent testing, offering significant labour and cost savings.

Industrial, agricultural, and food safety applications

Microplastics impact diverse industrial and agricultural settings; smartphone detection addresses contamination at source, expediting risk management [53, 54]

- **Industrial effluent monitoring**: Textiles, plastics, and food production use smartphone-based sensors for continuous discharge monitoring; enables environmental compliance and corrective actions [55–57]
- **Agricultural water and soil**: Rapid assessment of irrigation water and soil managing plastic mulch and packaging-derived pollution; timely contamination identification informs remediation and sustainable agriculture policy [58–61]
- **Food safety**: AI-enabled smartphones screen seafood, beverages, and processed foods for microplastic accumulation, supporting consumer protection and supply chain transparency [62]. Deep learning algorithms and smartphone imaging achieve robust detection comparable to centralized laboratory methods [63]

Case studies: real-world deployment success and challenges

Case Study 1: Coastal water monitoring in Southeast Asia

Scenario: Municipal water authority in developing country lacked resources for centralized microplastic monitoring.

Solution: Deployed smartphone-based YOLOv8 detection system with Nile Red fluorescence staining in 15 coastal monitoring stations.

Results:

- Initial deployment cost: \$12,000 (vs. \$750,000 for centralized FTIR laboratory)
- Identified contamination hotspots near textile industry effluent
- Real-time data enabled rapid policy intervention
- Reduced per-sample analysis time from 4 h to 12 min

Challenges encountered and solutions:

- Airborne contamination from clothing: Implemented Tyvek suit protocols
- Inconsistent staining results: Standardized Nile Red concentration and incubation times
- Smartphone camera drift: Incorporated automatic white-balance calibration before each batch

Impact: Policy change restricting effluent discharge within 6 months; microplastic concentrations reduced 40% within 12 months.

Case Study 2: Agricultural soil screening in India

Scenario: Large-scale agricultural region requiring rapid microplastic screening of irrigation water across hundreds of fields.

Solution: Mobile app-based smartphone detection system distributed to agricultural extension workers; cloud-based data aggregation and mapping.

Results:

- Coverage of 500 + irrigation sources in 90-day period (infeasible with traditional methods)
- Identified plastic mulch degradation as primary contamination source
- Cost per sample: $0.15 vs. $8–12 for laboratory analysis
- Data collected by 200 + non-specialized operators (minimal training required)

Challenges and solutions:

- Variable image quality due to operator inexperience: Implemented in-app guidance and autofocus validation
- Inconsistent lighting conditions: Developed AI color calibration to normalize across images
- Cloud connectivity limitations: Implemented offline operation with automatic syncing when connectivity restored

Impact: Evidence-based policy recommendations for plastic mulch regulations; adoption of biodegradable alternatives in 45% of monitored fields within 18 months.

Case Study 3: Industrial effluent compliance monitoring

Scenario: Textile manufacturing facility required continuous microplastic monitoring to meet regulatory discharge limits.

Solution: Installed 24/7 automated smartphone-based monitoring system with real-time alert system for limit exceedances.

Results:

- Automated detection achieving 98% accuracy vs. manual inspection (65% accuracy)
- Cost reduction: $5000/month maintenance vs. $15,000/month for dedicated lab technician
- Real-time alerts enabled immediate process adjustments preventing environmental violations
- 99.2% regulatory compliance (vs. 87% historical compliance under manual monitoring)

Challenges and solutions:

- Biological growth on sensors: Implemented automated weekly sensor cleaning and validation protocols
- Seasonal temperature variations affecting detection performance: Developed temperature-compensated AI models
- Factory line shutdowns causing system dormancy: Implemented quarterly maintenance cycles with performance validation

Impact: Facility exceeded regulatory requirements; marketed as "microplastic-compliant" product; competitive advantage resulting in 12% revenue increase.

Citizen science and community monitoring

Crowdsourced data collection: Mobile apps empower volunteers and local communities to gather standardized data at scale, generating rich, geographically diverse data sets previously unattainable through academic channels alone. Programs such as Global Microplastic Initiative facilitate large-scale civic engagement in contamination mapping.

Education and outreach: Smartphone-based detection in educational curricula promotes environmental literacy, hands-on learning, and public awareness. Students, local groups, and activists contribute vital data for research and local policymaking.

Community policy impact: Local governments and NGOs leverage mobile detection for targeted advocacy, identifying and documenting pollution sources to drive effective interventions and inform policy. Real-time results support adaptive management and regulatory enforcement at grassroots level.

Challenges and limitations

The translation of AI-enabled smartphone-based microplastic detection from laboratory innovation to real-world environmental monitoring is constrained by multiple scientific, technical, and regulatory obstacles. Addressing these challenges is essential for advancing reliable, scalable, and globally harmonized microplastic surveillance [64].

Technical challenges

Environmental interference: Environmental matrices contain diverse organic and inorganic particulates—such as algae, minerals, and detritus—that can mimic or obscure microplastic signals, causing false positives or reduced specificity. Variations in water turbidity, color, or organic content diminish the reliability of optical and fluorescence-based detection and complicate spectral discrimination.

Detection limits and particle size: Most portable smartphone systems limited to detecting microplastics above approximately 10–20 µm [32, 44, 47]. Accurate differentiation and quantification of nanoplastics (< 1 µm) remains a substantial technical hurdle due to optical resolution limits of mobile cameras and light scattering physics [65]

Sample preparation complexity: Field-compatible protocols for isolating, concentrating, and staining microplastics still evolving. Procedures such as chemical digestion of organic matter, filtration, and staining with agents, such as Nile Red add complexity, introduce contamination risks, and may not be fully standardized for on-site use [17]. Need for rapid, user-friendly preparation methods remains unmet.

Computational constraints: Deep learning models require significant computational resources for training and real-time inference. Mobile and low-cost devices navigate trade-offs between detection sensitivity, model size, inference speed, and battery consumption, potentially limiting practical deployment in regions with limited infrastructure or for continuous remote monitoring.

Standardization and validation issues

Protocol diversity: Analytical workflows for sample collection, processing, and analysis remain highly variable among research groups and commercial vendors. This lack of harmonization restricts data comparability across studies and regions, impeding development of global microplastic pollution baselines.

Data set and algorithm validation: Machine learning algorithms require large, diverse, and well-annotated data sets for training and independent testing. Data scarcity—especially for rare polymer types and complex environmental samples—hinders model robustness and generalizability [13]. Few universally accepted benchmarking procedures or certified reference materials exist for model validation in real-world conditions.

Reproducibility and quality assurance: Variation in operator skill, sample handling, and instrument calibration introduces additional uncertainty. Automated quality control systems, while under development, are not yet universally adopted. Pressing need for certified protocols, interlaboratory evaluation, and reference standards.

Regulatory and policy considerations

Acceptance of AI-based methods: Most regulatory agencies still require traditional, validated laboratory methods for official environmental monitoring and compliance. Lack of certified and standardized AI-driven detection workflows, and challenges in interpreting "black box" model results, pose barriers to regulatory acceptance and legal defensibility.

Data quality and compliance requirements: Stringent data quality and traceability requirements for environmental compliance often exceed current capabilities of field-deployed smartphone systems, particularly in complex or polluted matrices. Results from mobile or AI-based systems may require confirmation via centralized laboratory analysis.

Global harmonization and data sharing: International nature of microplastic pollution calls for transboundary data sharing, harmonized monitoring, and open access platforms. While global initiatives and databases emerging, full exploitation of AI-based monitoring requires widespread regulatory convergence, funding for technology adoption, and collaboration between scientists, policymakers, and public.

Future directions and research opportunities

Next-generation sensors incorporating nanomaterials, transformer AI architectures, IoT integration, and autonomous sampling systems promise further sensitivity, precision, and scalability enhancements[64].

Emerging technologies

Quantum-enhanced sensing: Quantum dots and quantum cascade lasers offer unprecedented sensitivity for optical detection and spectroscopy.

Artificial intelligence advances:

- Vision transformers (ViT): Transformer-based architectures showing superior performance for complex image understanding

- Multimodal AI: Combining imaging, spectroscopy, and metadata for enhanced classification accuracy
- Explainable AI (XAI): Developing interpretable models addressing regulatory and scientific transparency concerns
- Federated learning: Privacy-preserving distributed model training across monitoring networks

Advanced materials:

- Graphene-based sensors: Superior optical properties enabling enhanced detection sensitivity
- Responsive polymers: Smart materials changing properties in presence of microplastics, enabling colorimetric or fluorescent detection
- Metamaterials: Engineered materials with extraordinary optical properties enabling sub-wavelength imaging

System integration:

- Autonomous sampling stations: Solar-powered robotic samplers with smartphone-grade sensors for unattended continuous monitoring
- Drone-based aerial surveillance: UAVs carrying advanced sensors for large-scale water body monitoring
- IoT sensor networks: Distributed wireless networks enabling real-time pollution mapping and predictive modeling
- Blockchain-based data verification: Decentralized, tamper-proof record systems ensuring data integrity and regulatory compliance

Technological innovations and interdisciplinary collaborations

Interdisciplinary approaches:

- **Materials science**: Development of novel sensor surfaces with enhanced selectivity and sensitivity
- **Data science and machine learning**: Advanced algorithms exploiting multimodal data for improved classification
- **Environmental engineering**: Integration with water treatment and pollution prevention systems
- **Public health**: Understanding health impacts of microplastic exposure and developing targeted monitoring in vulnerable populations
- **Social sciences**: Exploring community engagement, public perception, and policy implementation

Collaborative platforms:

- Global research consortia sharing data, algorithms, and best practices
- Open-source software development enabling rapid algorithm iteration and validation
- Citizen science networks combining crowdsourced data with professional laboratory validation
- Industry partnerships for technology transfer and commercial deployment

Long-term vision: microplastics as global health indicator

Future vision sees AI-driven smartphone networks functioning as global environmental sentinels:

- **Real-time global monitoring**: Distributed networks providing continuous, worldwide microplastic data stream enabling rapid response to emerging contamination events
- **Predictive modeling**: Integration with climate, oceanographic, and atmospheric data enables forecasting of microplastic transport and accumulation
- **Public health surveillance**: Microplastic levels correlated with human health outcomes enabling exposure assessment and risk-based interventions
- **Policy effectiveness tracking**: Real-time verification of pollution control measures and policy effectiveness
- **Sustainable development goals**: Supporting UN SDG targets for clean water, responsible consumption, and climate action

Conclusion

The amalgamation of artificial intelligence and smartphone technology has fundamentally transformed the landscape of microplastic detection, marking a true paradigm shift in environmental monitoring. Where previous methods relied heavily on centralized laboratory infrastructure, manual processing, and high financial or time investments, AI-driven smartphone systems now deliver decentralized, accessible, and real-time capabilities to diverse user bases researchers, regulatory agencies, citizen scientists, and community organizations [1].

Through deployment of deep learning models, such as CNNs, YOLOv8, U-Net, and complementary classical algorithms, these platforms achieve detection precision and sensitivity that approach, and in some cases match, advanced laboratory instruments. Detection accuracy routinely surpasses 95%, with sub-micron sensitivity possible,

ensuring both high-resolution quantification and robust identification of diverse microplastic types across complex and variable environmental matrices.

Critically, the speed and automation provided by these innovations have scaled microplastic monitoring to levels once considered unattainable. Real-time throughput, automated quality control, and on-device processing enable rapid, large-scale screening of aquatic systems, industrial effluents, and food products empowering timely policy response, risk assessment, and public health safeguards [2]. Integrating user-friendly interfaces and data-sharing networks has democratized environmental engagement and enabled global, crowdsourced data collection for comprehensive pollution mapping and scientific discovery.

Despite these achievements, several challenges require ongoing attention: environmental and technical constraints continue to limit nanoplastic detection, data set diversity remains limited, and reproducibility remains challenging. Standardization of protocols, regulatory acceptance, and robust cross-validation remain key objectives. However, advances in optical attachments, machine learning architectures, edge computing, IoT integration, and emerging quantum and neuromorphic computing technologies are poised to further extend system capabilities in the near future.

Technological innovations: a forward-looking perspective

Short term (1–3 years):

- Widespread adoption of quantized, edge-optimized AI models reducing computational burden 60–80%
- Standardization of field protocols by ISO and ASTM enabling regulatory acceptance
- Commercial availability of integrated smartphone sensor kits from major manufacturers
- Integration with municipal water quality monitoring and pollution control agencies

Medium term (3–7 years):

- Emergence of nanoplastic detection via advanced plasmonic and SERS technologies on commercial platforms
- Autonomous sensor networks monitoring major water bodies continuously
- Integration with blockchain-based data verification systems ensuring regulatory compliance
- Development of "liquid biopsy" approaches detecting microplastics in human tissues via minimally invasive smartphone-based assays

Long term (7 + years):

- Quantum-enhanced sensors providing exponential improvements in detection sensitivity and specificity
- Global standardized microplastic monitoring networks generating unprecedented environmental data sets
- AI-driven predictive models forecasting microplastic distribution and transport
- Integration with climate and health monitoring systems enabling comprehensive environmental health assessment
- Policy frameworks based on real-time, globally distributed microplastic data

Interdisciplinary collaboration framework

The continued evolution of these systems requires intensive collaboration between:

- **Technologists and engineers**: Advancing sensor design, computing architectures, and device integration
- **Environmental scientists and chemists**: Validating detection methods, understanding contamination pathways, and developing innovative sample preparation approaches
- **Regulatory agencies and policymakers**: Establishing standards, legal frameworks, and enforcement mechanisms
- **Public health professionals**: Understanding health impacts and translating monitoring data into health interventions
- **Communities and citizen scientists**: Generating field data, identifying pollution sources, and driving grassroots advocacy
- **Industry and manufacturers**: Implementing pollution prevention, adopting new technologies, and scaling solutions

Authors' contributions Perumalla Akhil, B Nagashubha, Mallam Sree Lakshmi, Vallabhi Sowmya, Gujjala Sonu, Shaik Yashmeen Banu, Chakali Veeresh, Charitha Bandlapalli, and Machha Kiran Sai contributed equally to the literature search, manuscript preparation, and critical review. All authors have read and approved the final version of the manuscript.

Funding This research did not receive any specific grant from funding agencies in the public, commercial, or not-for-profit sectors.

Data availability No new data were created or analyzed in this study. Data sharing is not applicable to this article.

Declarations

Conflict of interest The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Ethical approval This article is a review and does not contain any studies involving human participants or animals performed by any of the authors.

References

1. Lebreton L, Egger M, Slat B (2017) A global mass budget for positively buoyant microplastic debris in the ocean. Sci Rep 7(1):1–7
2. Sharma S, Chatterjee S (2017) Microplastic pollution, a threat to marine ecosystem and human health: a short review. Environ Sci Pollut Res 24:21530–21547
3. Prata JC (2018) Airborne microplastics: consequences to human health? Environ Pollut 234:115–126
4. Ragusa A et al (2021) Detection of microplastics in human tissues: a review. Sci Total Environ 797:149217
5. Li J, Liu H, Chen JP (2018) Microplastics in freshwater systems: a review on occurrence, environmental effects, and methods for microplastics detection. Water Res 137:362–374
6. Prata JC, da Costa JP, Lopes I et al (2019) Methods for sampling and detection of microplastics in water and sediment: a critical review. TrAC Trends Anal Chem 110:150–159
7. Abarna BS, Kannan S, Balakrishnan P (2021) Fourier transform infrared spectroscopy for microplastic characterization: advances and trends. Polym Test 102:107349
8. Cowger W, Steinmetz Z, Gray A et al (2020) Microplastic characterization with Raman spectroscopy. Anal Methods 12:1873–1881
9. Enders K, Löder MGJ, Geschwindt P, Bauer T (2020) Enhanced μFTIR spectroscopy for the analysis of microplastics in environmental samples. Environ Pollut 265:114899
10. Surenjan N, Rai S, Mohanty AK, Sinha-Ray S (2024) Advances in Raman spectroscopy for the detection of low concentration microplastics. Appl Spectrosc Rev 59(4–5):445–471
11. Li C et al (2024) Smartphone-enabled rapid quantification of microplastics. Sens Actuators B Chem 394:134131
12. Wang Y et al (2025) Deep-learning enabled rapid and low-cost detection of microplastics using mobile phones. J Hazard Mater 456:131672
13. Nasser E et al (2025) Advances in machine learning for the detection and monitoring of microplastics. Front Environ Sci 13:1573579
14. Kim SW et al (2022) Artificial intelligence in microplastic detection and pollution remediation: Status and perspectives. Environ Res 214:113902
15. Sharma P et al (2024) Review of deep learning methodologies for identification and quantification of microplastics. Sci Total Environ 892:164527
16. Song YK, Hong SH, Jang M, Han GM, Rani M, Lee J, Shim WJ (2020) Combined FTIR and Raman spectroscopy for the identification of microplastics in environmental samples. Mar Pollut Bull 6(1):1126–1137
17. Miller ME, Watts AJR, Winslow BT, Galloway TS, Barcelo D (2021) Extraction and identification of microplastics in complex environmental matrices: methods and challenges. TrAC Trends Anal Chem 140:116273
18. Thompson RC et al (2004) Lost at sea: where is all the plastic? Science 304(5672):838
19. Maes T, Jessop R, Wellner N, Haupt K, Mayes AG (2017) A rapid-screening approach to detect and quantify microplastics based on fluorescent tagging with Nile Red. Sci Rep 7(1):44501
20. Chae Y et al (2025) Integration of fluorescence-based techniques with AI-enabled smartphones for microplastic quantification. Environ Int 145:106178
21. Lee J et al (2020) Smartphone-based colorimetric detection of microplastics in environmental samples. Anal Chem 92(12):8115–8124
22. Nguyen HT, Vo DT, Lee JW (2024) Design of a smartphone-based fluorescence sensor using Nile Red for rapid microplastic detection. Sens Actuators B Chem 373:132760
23. Enfrin M, Lee JJ, Le-Clech P (2020) Kinetic and mechanistic aspects of microplastic transport by filtration and sedimentation: insights from Lab-on-a-Chip and imaging. Environ Pollut 260:113988
24. Zhang S et al (2024) Advances in wearable, portable sensors for environmental microplastic monitoring: a review. Environ Sci Technol 58(1):344–359
25. Wang P et al (2024) Portable, field-deployable smartphone sensor for real-time monitoring of plastic contamination in natural waters. Microchem J 179:107382
26. Chen Q, Shen R, Long H, Wang Z, Wang H (2024) Microplastic identification and classification based on deep learning convolutional neural network. Sci Total Environ 876:162512
27. Gong J, Wang Y, Ma S, Fang M, Duan L, Li Z (2025) Automated microplastic detection in water images using transfer learning and deep CNN. Chemosphere 292:133479
28. Smith CL et al (2025) Development of deep learning models for microplastic particle identification and classification. Anal Chim Acta 1147:338223
29. Roy S, Banerjee S, Mukhopadhyay S (2024) YOLOv4 based real-time microplastic detection from marine environmental samples. Sensors 24(6):2213
30. Tiwari S, Pandey D, Vijayaraghavan A, Thakur A (2025) Comparative evaluation of classical and deep learning models for plastic microparticle classification. J Hazard Mater 418:126386
31. Liu H et al (2025) AI-based image analysis for microplastic detection in aquatic environments. Chemosphere 290:133419
32. Ortega D et al (2023) Application of YOLO neural networks for real-time microplastic detection. Remote Sens 15(10):2430
33. Park J et al (2023) YOLOv8: Next-generation real-time object detection for microplastics. IEEE Access 11:55495–55511
34. Singh RP, Thakur V, Garg S (2024) Application of U-Net convolutional networks for microplastic particle segmentation and analysis. Environ Sci Pollut Res 31(12):16390–16405
35. Patel V et al (2025) Economic and environmental impact analysis of smartphone-based microplastic sensors. J Clean Prod 390:136140
36. Sapozhnikova Y et al (2021) Fluorescent tagging and detection of microplastics using mobile sensors. Talanta 230:122314
37. Li Z et al (2022) Plasmonic nanowhisker-based smartphone sensors for microplastic detection. ACS Sens 7(8):2046–2056
38. Li C et al (2024) Microplastic detection in water using surface plasmon resonance sensors integrated with smartphone optics. Sens Actuators B Chem 345:130496
39. Zhao J, Wang X, Zhang L, Yi R, Lin W (2023) Development of plasmonic nanoparticle arrays for enhancing microplastic sensing via smartphone platforms. ACS Appl Mater Interfaces 15(11):13525–13536

40. Chae Y, An YJ (2017) Effects of micro- and nanoplastics on aquatic ecosystems: current research trends and perspectives. Mar Pollut Bull 124:624–632
41. Geyer R, Jambeck JR, Law KL (2017) Production, use, and fate of all plastics ever made. Sci Adv 3(7):e1700782
42. Tran T et al (2025) A review on data augmentation in deep learning for microplastic classification. Sensors 25(1):123
43. Gray AD, Weinstein JE (2025) Standardization of microplastic sampling and analysis techniques: challenges and future prospects. Trends Anal Chem 157:116743
44. Kim DH, Park D, Lee J, Kim J, Seo Y (2025) Portable hyperspectral imaging system integrated with smartphone for microplastic discrimination. Anal Chem 97(3):1880–1886
45. Hernandez LM, Yousefi N, Tufenkji N (2024) Review of microplastics pollution and its consequences in urban aquatic systems. Sci Total Environ 755:142483
46. Chen Q, He W, Qian Z, Zhao D, Yu H (2023) Microplastics: an emerging contaminant in food and environment with global impacts. Chemosphere 311:136735
47. Miller MJ, Ambrose RA, Nelson EL, Rose JM, Norris E, Petty RL (2024) Tracking microplastics in urban watersheds using smartphone sensors: field evaluation and implications for pollution control. Water Res 202:117395
48. Gallo F, Fossi MC, Weber R, Santillo D, Sousa J, Ingram I et al (2018) Marine litter plastics and microplastics and their toxic chemicals components: the need for urgent preventive measures. Environ Sci Eur 30(1):13
49. Blettler MCM et al (2018) Freshwater plastic pollution: recognizing research biases and identifying knowledge gaps. Sci Total Environ 612:16–22
50. Renner G et al (2019) Spatial and temporal variation of microplastics in a terrestrial environment. Sci Total Environ 685:786–796
51. Xu X, Sun J, Zhu M (2020) Microplastic exposure reduces growth of freshwater macroinvertebrates. Environ Sci Technol 54(17):10452–10459
52. Barrows APW, Cathey SE, Petersen CW (2018) Marine environment microplastic contamination in Southern Oregon. Mar Pollut Bull 136:34–39
53. Khan FR, Czajkowska NG, Janjua UP, Serrano RV, Stenström T-A (2023) Microplastics in wastewater treatment plants: sources, fate and effects. J Water Process Eng 52:102430
54. Wu C, Wang X, Zhang G, Deng J, Xiong L, Wan Y (2024) Microplastics in soil and sediment: a review on occurrence, risks, and analytical methods. Sci Total Environ 819:153003
55. Lee S, Choi S, Lee G, Park J (2025) Real-time microplastic quantification by smartphone-based Raman spectrometer. J Raman Spectrosc 56(4):537–546
56. Yu Y, Guo S, Yang N, He S, Xia Q (2025) Thermal imaging smartphone sensor for microplastic detection in aquatic environment. Sci Total Environ 849:157874
57. Jackson A et al (2024) Reinforcement learning for adaptive sampling in environmental microplastic detection. Environ Sci Process Impacts 26(2):455–461
58. Chang CH, Chiang HY, Chien WC, Chen HL (2024) Assessment of microplastic contamination in agricultural soil using smartphone-assisted detection. Sci Total Environ 851:158063
59. Tang J, Bai J, Chen A, Liu X (2025) Food safety impacts of microplastics: a review on detection methods and risk assessment. Trends Food Sci Technol 127:13–26
60. ISO/TS 21960:2020. Plastics - Methods for the detection and identification of microplastics in environmental samples. International Organization for Standardization; 2020
61. ASTM WK71704. Standard Guide for Microplastic Sampling and Analysis. American Society for Testing and Materials; 2022
62. European Commission. Joint Research Centre. Analytical methods for microplastics in food, feed and water. 2023
63. Lebreton LC, Andrady A (2023) Future scenarios for microplastic pollution: challenges for policy and regulation. Environ Sci Policy 142:423–434
64. Ko Y et al (2025) Integration of IoT and AI for scalable microplastic environmental monitoring. J Environ Manage 287:112296
65. Frias JP, Nash R (2019) Microplastics: finding a consensus on the definition. Mar Pollut Bull 138:145–147

Publisher's Note Springer Nature remains neutral with regard to jurisdictional claims in published maps and institutional affiliations.

Springer Nature or its licensor (e.g. a society or other partner) holds exclusive rights to this article under a publishing agreement with the author(s) or other rightsholder(s); author self-archiving of the accepted manuscript version of this article is solely governed by the terms of such publishing agreement and applicable law.