Explanation of posted files

assumed_resource_mix.xlsx: assumed resource mix for the year under study. Effective Nameplate and/or Installed Capacity are not provided for classes with no more than 3 owners due to data confidentiality reasons.

bins.xlsx: this Excel file includes 4 sheets. The pre-merging bins correspond to the output of using the Freedman Diaconis Estimator to create the temperature bins. The post-merging bins correspond to the output after PJM merged a few temperature bins to avoid having too small a sample size (in number of days) in some of the extreme bins. Each of the sheets include the upper bound and lower bound of each bin in load-weighted RTO-wide THI units as well as the days included in each bin. The Days column has all days in each bin since 1993-06-01 until 2024-05-31 (which are used to derive load scenarios). The Days_after_2012-06-01 column has all days in each bin since 2012-06-01 until 2024-05-31 (which are used to derive resource performance scenarios for variable and unlimited resources).

hourly_load_scenarios.xlsx: these are the per-unitized load scenarios used in the model (they are per-unitized on the 50/50 forecasted annual peak load). Hour 0 corresponds to June 1st at 0:00:00 AM. The columns contain the 390 load scenarios based on 30 delivery years of weather history (DY 1993 – DY 2023) and the 13 weather rotations (A-M).

hours_and_weight_for_performance_adjustment_calculation.xlsx: this file includes the timestamps as well as the weight of each timestamp for the calculation of the resource Performance Adjustment for ELCC Classes that have an ELCC Class Rating.

stats_performance_adjustment.xlsx*:* this file provides the minimum, the 25th percentile (25%), the median (50%), the 75th percentile (75%) and the maximum values for the Performance Adjustment in ELCC Classes that have an ELCC Class Rating and with a membership including more than 3 owners.

weekly_schedule_planned_and_maintenance_outages_by_load_scenario.xlsx: this file has the total quantity in MW of planned and maintenance outages for each week in each of the 390 load scenarios (the columns are named after the load scenarios). Week 0 corresponds to the first week of June in a delivery year.

info_for_loss_of_load_hours.xlsx: this file has all the hours with loss of load identified by the model. The columns in the file are:

- HourBeginningInYear: self-explanatory
- Year: this refers to the weather year (weather year 0 starts in June 1st, 1993 and ends in May 31st, 1994)
- Weights: probability of occurrence of the event
- Rotation: weather rotation (value can go from 0 to 12)
- Replication: resource performance draw (value can go from 0 to 99)
- Date: date of the identified loss of load hour in the simulation
- DayOfDeliveryYear: day number in delivery year (value goes from 0 to 364)

- HourBeginning: hour beginning of the loss of load event
- Load: load in hour
- LoadRelativetoSolvedLoad: ratio of load in hour to solved simulated annual peak load
- TotalUnlimitedOutput: total output of resources in the Unlimited Resources ELCC Classes
- TotalVariableOutput: total output of resources in the Variable Resources ELCC Classes
- TotalLimitedDurationAndCombinationOutput: total output of resources in the Limited Duration and Combination Resources ELCC Classes
- DROutput: total output of resources in the Demand Resources ELCC Class
- Margin: load minus total resource output from all ELCC Classes
- LOLEFlag: 1 if there is a loss of load event (i.e. Margin is less than 0)
- PlannedOutagesMW: amount of Planned and Maintenance Outages of Unlimited Resources scheduled in hour
- Bin: temperature bin employed to sample performance for Unlimited and Variable Resources for the hour
- ActualPerfDay: actual historical performance date used to sample performance for Unlimited and Variable Resources for the hour
- ActualTimeStampPerfDay: actual historical performance timestamp used to sample performance for Unlimited and Variable Resources for the hour

montecarlo_by_date.xlsx: this file has the random draws that determine the historical performance days being used in each of the 100 replications (see column names in file that go from 0 to 99) for each of the weather days since June 1st, 1993.

share_of_maintenance_planned_outages_by_unlimited_class.xlsx: this file has the share of the total planned and maintenance outages scheduled in the model by Unlimited Resources class. For accreditation purposes, the weekly amounts of scheduled planned and maintenance outages are allocated based on these class shares.

most_similar_dy_for_hydro_int_and_hydro_nps_performance.xlsx: this file has the list of most similar delivery years that are used to determine the performance of Intermittent Hydropower and Hydropower with Non-Pumped Storage resources. Because the resource performance data used by the model must be post June 1, 2012, the most similar delivery year for delivery years prior to 2012 will be one in the period 2012-2023. For 2012 and delivery years after 2012, the most similar delivery year is the same delivery year.

additional_critical_performance_hours.xlsx: this file has performance timestamps that impact accreditation in addition to those included in the info_for_loss_of_load_hours.xlsx file. The timestamps in this file are associated with performance during non-loss of load hours in the model that are critical for accreditation purposes because output during these hours allows the recharge of storage resources or the delay of the deployment of storage, both of which are helpful to the system during energy-constrained days.

critical_performance_hours_hydro.xlsx: this file has performance timestamps that impact accreditation for intermittent hydropower resources split into two tabs. One tab includes performance timestamps during loss of load hours (which are currently not provided in the info_for_loss_of_load_hours.xlsx file) while the other tab includes performance timestamps during non-loss of load hours (for definition of these hours please see description of previous file). Note that the timestamps are different for intermittent hydropower (compared to other resources) because these intermittent hydropower resources are not subjected to the temperature binning methodology and instead rely on the "most-similar" delivery year approach.

simulated_dr_performance_in_additional_critical_performance_hours.xlsx: this file has the simulated output of Demand Resources during non-loss of load hours in the model that are critical for accreditation purposes (as described in the description of the additional_critical_performance_hours.xlsx file). Also, the Calculations tab illustrates how to use the simulated performance during the non-loss of load hours and the simulated performance during loss of load hours (available in the info_for_loss_of_load_hours.xlsx file) to come up with the weighted average performance during critical hours (which is a good approximation of the DR Class Rating).