

TABLE OF DIMENSIONS FOR JACKING & RECEIVING SHAFTS

Sr. #	Pipe Inner Diameter (m)	Pipe Wall Thickness (m)	Pipe Outer Diameter (m)	Type of Shaft	No. of Shafts	Rectangular					Circular			Depth H-I (m)	Bracing Beams C/C Spacing (mm)			Base Slab Thickness (m)	PCC Thickness (m)	Thrust Block		Circular Shaft Wall Thickness (m)	Sheet Pile Embedment Depth H-II (m)	
						Width (B) (m)	Length (A) (m)	Length including Thrust Block Thickness (m)	Total Length (L) (m)	Total Width (W) (m)	Diameter (D1) (m)	Diameter (D2) (m)	Diameter (D3) (m)		X	Y	Z			Thickness (m)	Height (m)			
Jacking Shafts of Line-A																								
1	2.4	0.225	2.85	A	7	6	8.8	10.0	10.9	6.9				14	2250	2250	5300	0.6	0.1	1.2	4		5	
2	2.4	0.225	2.85	B	2	8.8	8.8	10.0	10.9	9.7				14	2250	2250	5300	0.6	0.1	1.2	4		5	
3	2.4	0.225	2.85	C	7						11	11.9	13.1	14	2750	2750	5300	0.6	0.1	0.6	4	0.6	5	
Jacking Shafts of Line-B																								
1	2.4	0.225	2.85	A	4	6	8.8	10.0	10.9	6.9				14	2250	2250	5300	0.6	0.1	1.2	4		5	
2	2.4	0.225	2.85	B	2	8.8	8.8	10.0	10.9	9.7				14	2250	2250	5300	0.6	0.1	1.2	4		5	
3	2.4	0.225	2.85	C	4						11	11.9	13.1	14	2750	2750	5300	0.6	0.1	0.6	4	0.6	5	
4	1.5	0.169	1.838	D	3						10	10.9	12.1	12	2250	2250	5300	0.6	0.1	0.6	4	0.6	5	
5	1.5	0.169	1.838	E	3	5	8.2	9.4	10.3	5.9				12	1950	1950	5300	0.6	0.1	1.2	4		5	
Jacking Shafts of Line-C																								
1	3.5	0.3	4.1	A	2	7	8.8	10.0	10.9	7.9				18	2250	2250	5300	0.6	0.1	1.2	4		8	
2	3.5	0.3	4.1	B	1	8.8	8.8	10.0	10.9	9.7				18.64	2250	2250	5300	0.6	0.1	1.2	4		8	
3	3.5	0.3	4.1	C	2	6	10.0	11.2	12.1	6.9				18.76	2850	2850	5300	0.6	0.1	1.2	4		8	
4	3.5	0.3	4.1	D	5						12	12.9	14.1	20	3250	3250	5300	0.6	0.1	0.6	4	0.6	8	
Receiving Shafts of Line-A																								
1	2.4	0.225	2.85	A	9	3.5	5.5		6.4	4.4				14				0.6	0.1				5	
2	2.4	0.225	2.85	B	7						7		7.9	14	750	750	5300	0.6	0.1			0.6	5	
Receiving Shafts of Line-B																								
1	2.4	0.225	2.85	A	4	3.5	5.5		6.4	4.4				13				0.6	0.1				5	
2	1.5	0.169	1.838	B	4	2.5	4.5		5.4	3.4				12				0.6	0.1				5	
3	2.4	0.225	2.85	C	1	5.5	5.5		6.4	6.4				12.35				0.6	0.1				5	
4	1.5	0.169	1.838	D	2						6		6.9	11.77	250	250	5300	0.6	0.1			0.6	5	
5	2.4	0.225	2.85	E	5						7		7.9	14	750	750	5300	0.6	0.1			0.6	5	
Receiving Shafts of Line-C																								
1	3.5	0.3	4.1	A	6	4	6.5		7.4	4.9				19				0.6	0.1				8	
2	3.5	0.3	4.1	B	5						8		8.9	18.5	1250	1250	5300	0.6	0.1			0.6	8	

NOT FOR CONSTRUCTION

LAHORE WATER & WASTEWATER MANAGEMENT PROJECT - SEWERAGE SYSTEM FROM LARECH COLONY TO GULSHAN-E-RAVI, LAHORE (THROUGH TRENCHLESS TECHNOLOGY)



WATER AND SANITATION
AGENCY, LAHORE



A Joint Venture

04		
03		
02		
01		
REV.	DATE	DESCRIPTION

DRAWN	
CHECKED BY	
RECOMMENDED	
CHD./VER.	
APPROVED	

JACKING AND RECEIVING SHAFTS
TABLES OF DIMENSIONS

DATE:-
May, 2025

DRAWING NO.:-
LW - TD - 141