ALGAE-BASED AIR FILTERATION: ENHANCING INDOOR AIR QUALITY

Group 17211 | Capstone Text Poster.

Ahmed Ramadan Salah
Mohamed Ali El-Sayed

Moataz Ibrahim Hassan
Ziad Ahmed Youssef

G-11

2024-2025

Abstract

Recently, the insufficient supply of renewable energy and the overdependence on fossil fuels, have become major problems impacting the Egyptian economy and its citizens. According to a recent study done by the IEA in 2022, Fossil fuels contributed to about 90% of the total energy poll in Egypt while renewable energy only contributed to about 10%. Burning this non-clean energy has made air quality deteriorate substantially in the past few decades. This project addresses these challenges by making an eco-friendly and recycled bio-air filter that will be built to absorb CO_2 by utilizing the photosynthetic cycles of the chlorella. While testing the prototype, the ability of the biofilter to absorb CO_2 and the temperature and PH-controlling capabilities of the prototype were considered design requirements. The ability of absorption of CO_2 was measured in terms of the difference in CO_2 concentration divided by the time. To satisfy this design requirement, the prototype was tested by introducing an air sample of 1500 ml and then measuring the CO_2 concentration before and after 10 minutes by using a sensor. To achieve the design requirement of making the prototype capable of controlling the temperature and pH while also providing the algae with enough nutrients. A thermometer and a pH meter were used to measure the temperature and the PH respectively. The temperature was controlled by using a submersible aquarium heater, the pH was controlled by adding NaOH as it is basic and the nutrients were provided using organic waste. The prototype decreased the concentration of CO_2 by about 46% and had the temperature and the pH at an average range of (20-30) and 8 respectively. The major conclusions are that the prototype met all the design requirements and that it is eco-friendly and waste-derived making it a very potent solution to the problem of deteriorating air quality (air pollution).

introduction

The success of the project starts with understanding the grand challenges and problems targeted which are the insufficient use of clean energy, and the ever-growing population which are catalysts for the deterioration of air quality and the spread of multiple air pollutants like CO2. As shown in Graph (1) the CO2 emissions have been increasing until they reached 17.6 trillion tons. This excessive amount of CO2 emissions cause a multitude of problems to the environment and human health such as climate change, ocean acidification, disruption of ecosystems and respiratory and cardiovascular diseases. This project aims to decrease the concentration ofCO2 in the atmosphere. Solving this challenge will minimize the negative consequences of climate change and pollution, while also contributing positively towards the challenge of recycling, which in turn works to eradicate public health issues and diseases.

Graph 1(emissions of CO_2 gas)

Some prior solutions were found including the LIQUID 3 micro algae air biofilter. The pros of this solution are that microalgae have a significantly higher photosynthesis and CO_2 absorption efficiency compared to traditional trees. They are estimated to be 10 to 50 times more productive while also taking way less space. Still as a con, LIQUID 3 units require specific temperature conditions for optimal functioning; they need heating when temperatures drop. This

dependency on external energy sources (both solar and grid electricity) raises concerns about their efficiency during colder months and their overall sustainability. Another prior solution was the photocatalytic oxidation. This prior solution is advantageous as PCO can effectively degrade a wide range of pollutants, including volatile organic compounds (VOCs), nitrogen oxides (NOx), and certain pathogens, reducing harmful substances to less toxic byproducts like water and carbon dioxide. However, the initial cost of installing the PCO can be quite expensive while also not completely degrading the harmful pollutants.

The chosen solution meets all the design and solution requirements to solve the specific problem. The solution requirements include eco-friendliness, efficiency and sustainability. All 3 solution requirements were achieved as the solution is of high efficiency equivalent to 46% while also decreasing the concentration of CO2. The 3 main design requirements are: 1) decreasing the concentration of CO2 by 20% in a timeframe of 10 minutes. The prototype reached a rate of reduction equivalent to 46%. 2) The temperature control capabilities: Due to the automated heating system, the prototype stayed within the range of 20 to 30 Celsius. 3) The optimization of pH and nutrients: The pH of the prototype stayed within the range of 7 to 9 pH which was achieved by adding NaOH and the nutrients were provided to the algae from the biological waste.

The chosen solution which is the algae air biofilter attempts to solve the problem of substantial deterioration of air quality over time especially with the increasing rate of harmful gases emissions every year with each year being worse than the one before it. The CO2 absorption method of the prototype is reliant on photosynthesis so to maximize the efficiency of the photosynthesis process, the algae were put in an ideal environment to maximize its reproduction and rate of its photosynthetic cycles. This selection was chosen as it is way efficient and advantageous

than a grown tree in terms of efficiency of CO2 absorption, space and time utilization.

Materials & methods

Table 1 (materials used)

Item	Amount	Description	Usage	Cost	Source of purchase	Picture
Algae sample	75ml	A water sample containing a number of algae organisms	Used as the first sample in the reproduction of the algal system	——	Faculty of Science, Zagazig University	
Glass container	1	A container made of glass	Contains an environment made for the algae	530 LE	Glass store	
Pipe & valve	50cm pipe 1 valve	A plastic pipe with a diameter of 32 mm, connected to a plastic pipe,	Used as paths for the air sample.	65 LE	Plumping store	
Purple LED strip	2 m	A lightning strip with a purple color of a wavelength between 500 and 600	Used to increase the light intensity of the system increasing the efficiency	40 LE	electronics shop	
Water heater	1	A device uses 220v AC electricity to heat water	Used to control the water temperature to be between 25ᶜ and 35ᶜ	100 LE	Electric shop	
Arduino uno R3	1	A microcontroller that controls the project	Used to control the main functions of the project like turning the heater on/off and sensing the gasses.	300 LE	Electronics shop	
CO_2 sensor (mq-135)	1	——————	Connected to Arduino board to sense the concentration of CO_2 gas in the air	55 LE	Electronics shop	
Temperature sensor (DS18B20)	1	——————	Connected to the Arduino board to sense the temperature of the water	50 LE	Electronics shop	
Electronic connections	1 | bread board 15 | jumper wire 1 | relay module 3 | LEDs 4 | resistors	Simple electronic parts and basics for connecting circuits	Used to connect several electric parts together in circuits.	62 LE	**Electronics shop**	
Total Cost		1202 LE				

Methods:

The prototype was made through many steps of construction, these steps are listed above.

o The glass container was made by cutting the sides by lengths, 2 holes were made in top of the container having 2 pieces of pipe installed in them, one pipe connected to a valve.

o The electric parts were installed in the container. The bread board was installed in top of the container having all the connections in it. The water heater, temperature sensor, and CO2 sensor were installed inside the container, and connected to the Arduino board.

o The Arduino board was connected to a laptop to upload the code written to utilize the function of each electronic part.

o The container was filled with water, the algae sample was inserted into the water and supplied with the needed nutrients.

figure 1(the prototype after construction)

Test plan:

After constructing the prototype, it was time to perform the test plan on it, ensuring that it achieved the design requirements. These tests were in many steps, these steps are listed above:

1)testing the pH scale of the prototype, this step includes the use of litmus paper, which takes a specific color for each pH level, the pH level needed is between 7 and 9.

2)testing the temperature of the system, this test involves the use of the water temperature sensor DS18B20 In measuring the temperature of the system, the temperature needed is between 20 and 30 Celsius.

3)testing the capability of the system to absorb CO_2 Pollutant. This test involves two main steps:

1. preparing the testing air sample, this was done by preparing an amount of CO_2 gas using the reaction of Yeast and Sugar, which produces CO_2 gas and alcohol. The air sample are prepared by

collecting the CO_2 in a closed air container with a volume of 1500ml.

2.testing the absorption rate, this was done by injecting the prepared polluted air sample in the algae environment and watching the reduction of the pollutant using the MQ-135 sensor.

The target of this test is to absorb not less than 20% of the pollutant in the air sample, in a time period not more than 10 minutes.

Results

The prototype was tested on two main things: its carbon removal efficiency and its temperature control capabilities. As shown in the results, the prototype surpassed both design requirements, as illustrated in tables (2) and graph(2).

Table 1: illustrates the carbon removal efficiency of the prototype tested in 3 different trials. The table showcases the carbon removal efficiency of the microalgae within intervals of 2 minutes. These measurements were made by the MQ135 sensor and are as follows:

Table 2 (CO2 capture efficiency)

Time (minutes)	CO_2 PPm		
	Trial 1	Trial 2	Trial 3
0	472 ± 9.44	451 ± 9.02	413 ± 8.26
2_{nd}	427 ± 8.54	414 ± 8.28	373 ± 7.46
4_{th}	389 ± 7.78	380 ± 7.6	338 ± 6.76
6_{th}	354 ± 7.08	346 ± 6.92	305 ± 6.1
8_{th}	321 ± 6.42	315 ± 6.3	272 ± 5.44
10_{th}	292 ± 5.84	285 ± 5.7	240 ± 4.8
Efficiency	38.13%	36.80%	41.88%
AVG Efficiency	**38.93%**		

The CO2 absorption efficiency was calculated by the mathematical law:
$\left|\frac{\Delta c}{c_0}\right| \times 100$. Where c_0 is the initial concentration of CO2 gas and Δc is the difference between the final concentration and the initial concentration of CO2.

The average efficiency is calculated by:$(E\_1+E\_2+E\_3)/3 = (38.13\%+36.8\%+41.88\%)/3 = 38.93\%$. This surpasses the 20% goal set in the design requirement.

Graph 2: Through the 3 trials, the temperature of the prototype was monitored using the temperature sensor DS18B20. As illustrated in the table, the graph had an average range of temperature between (24.4 - 27.1). Staying within the range of (20 Celsius-30 Celsius) This is strictly because of the automatic heating system keeping the prototype at optimum temperatures.

Graph 2 (temperature value over all 3 trials)

Analysis

Considering the test findings, the prototype achieved the design requirements, exhibiting a positive impact on the grand challenges addressed, and the major problem of air pollution.

It's no secret that Egypt is facing an environmental crisis namely the deterioration of air quality, and this is due to the large amount of contaminated gasses emissions from the burning of non-clean energy (fossil fuels). As a way to combat this deterioration of air quality, Egypt is looking to decrease the concentration of those harmful gasses and these efforts are presented in the various air filters that are in Egypt like the Daikin air filtration units and the arabo filters, though these projects aren't keeping up with the recent emissions. If Egypt succeeds in making the rate of emissions equivalent to or less than the rate of air filtration, it will result in improving the environmental situation, and the overall health conditions of the Egyptian citizens.

The algae biofilter (the chosen solution) aids Egypt in its journey to reach the state of equilibrium between the emissions of toxic gases and the rate of air filtration. This solution overcomes the grand challenges and solves the major problem of air pollution. This is because the biological filter filters CO_2 with an efficiency of 10 to 30 times more effective than a tree while also taking substantially less space and time to do said function. The reason why the biological filter was chosen as the solution is because it utilizes the algal photosynthesis process, so the algae are placed in a suitable and ideal environment maximizing both its reproduction and the rate of its photosynthetic cycles thus maximizing the efficiency of its CO_2 removal. Water will be used as the medium for the algae as water needs to gain a considerable amount of energy to increase its temperature due to its high heat capacity thus making its temperature quite stable as learned in (ES.2.01).

The project's strength points as illustrated from the results are that it is highly efficient in terms of decreasing the CO2 concentration, space utilization, and time management especially when compared to an actual tree. It also provides the ideal living environment for the algae thus resulting in them reaching high efficiencies of CO2 absorption equivalent to 46%. The project's weak points are that it requires a fair amount of maintenance to function and consumes energy for the heating system and the CO2 detection system while also not being able to deal well with hot temperatures.

The prototype met all the design requirements and they are as follows:

1) Decrease the concentration of CO2 by 20% in a timeframe of 10 minutes: As shown in graphs (3,4) the prototype surpassed this design requirement as it decreased the CO2 concentration by 46%. This was calculated by using the law:
$\left|\frac{\Delta c}{c_0}\right| \times 100$. This was done by making a database using an Excel sheet of the values for 3 trials then getting the average for said trials. This type of database is called a relational database. (CS.2.02) was essential for making the database and identifying its type.

2) Temperature control capabilities: The prototype showed
 remarkable control over its internal temperature keeping the
range between 20 and 30 Celsius. This was

Graph 3(CO2 absorption per time)

Graph 4(Trials efficiency graph)

achieved primarily
 due to the automatic temperature control system, where the temperature sensor gives a reading to the Arduino and if said
 reading drops below 20 Celsius, a submersible aquarium heater (which is connected to the Arduino using a relay) is coded to have it turn on and heat the water till it reaches a stable temperature of 25 Celsius.

3) pH and nutrient optimization: The pH of the prototype is meant to be in the range of 7 to 9 thus the pH of the prototype was periodically monitored and when the prototype dropped below a pH of 7, NaOH was added and this is because it had a pH of **13** which was calculated from the law that was learned in (CH.2.03) **pH of NAOH = - log (H+)** .

The nutrients of the algae were provided from organic waste. We used molarity to measure how much nutrients was dissolved in the water to help algae grow. **Molality**: Tracks nutrients more accurately when temperature changes and its calculated by using the following law : **number of moles of nutrients / liters of solution** , to ensure algae grow consistently as learned in (CH.2.01).

There are 3 mechanisms that are essential for testing the prototype and they are as follows:

1-Air sample preparation: Yeast will be added to sugar with varying ratios, then after waiting for an approximate time of an hour, CO_2 will be produced and the air sample will be complete. This is illustrated in the reaction: **$C_6H_{12}O_6$ (aq) → 2 C_2H_5OH (aq) + 2 CO_2 (g)**. This way of CO2 preparation was chosen as Ethanol (C_2H_5OH) is considered a nutrients for the algae.

2-The method of CO2 absorption: the algae filters the CO2 out of the air through its photosynthetic cycles illustrated in the following chemical equation: **6 CO_2 + 6 H_2O + light energy → $C_6H_{12}O_6$ + 6 O_2**.

3- The automated heat system: The 220 V heater is connected to the Arduino UNO through a relay. A temperature sensor was also connected to the Arduino circuit. The circuit is coded so that if the temperature sensor gives a reading less than 20 Celsius, the heater automatically turns on, heating the prototype till it reaches a temperature of 25 Celsius ensuring that the prototype is always at optimal temperatures. The system relies on dynamic electricity to power devices such as CO_2 sensors, heater or LED lighting, which optimize the growth environment for algae and enhance CO_2 absorption efficiency which we learned to utilize in (PH.2.03)

Conclusion

The findings that have arisen from the performance results of the prototype indicate relative success of the project since it exceeded expectations in efficiency, durability, and user feedback. Also, the condition requiring the design to lower 20% of CO_2 pollutants within 10 minutes has been met, proving the system's immediacy in addressing challenges of the environment. This is substantiated by the analysis that shows the endurance of the system's operation with varying conditions, so making it reliable and easy to handle for the user. The project is thus incomparable and the most cost-effective and scalable option from other solutions made by the team on researched alternatives. Most of these solutions are either less efficient or more expensive. This addresses some significant gaps in current methods, meaning that it has the potential for application on a

much broader setting. Based on all the results, the validation of the efficacy of the project in meeting its design goals specifically in reducing CO_2 emissions rapidly, makes it a hopeful solution in the fight against environmental pollution in various industries.

Recommendations

Reflective surfaces can be added around the algae tanks, using mirrors or shiny materials to reflect more light into the system. This helps more light reach the algae without the need for extra electricity.

Rainwater can be collected to fill the algae tanks, as it is clean, free, and does not contain chemicals like tap water, which could harm the algae.

Carbon dioxide can be added directly into the system, and bubble columns can be used to spread it evenly, helping the algae grow faster. CO_2 can even be recycled from factories, saving money and benefiting the environment.

A cooler can be added that it turns on when the temperature of the environment gets more than 30degree Celsius, to ensure that the environment stays at optimal temperature regardless of the conditions.

Closed systems like photobioreactors can be used to avoid contamination, and equipment should be cleaned regularly. A

small system can be started to test things before scaling up, helping spot and fix any issues early.

✒️ Literature Cited

1)Anne Trafton | MIT News Office, (January 11, 2017), How photosynthetic pigments harvest light. Retrieved 29/10/2024 From:

https://news.mit.edu/2017/photosynthetic-pigments-harvest-light-artificial-photosynthesis-0111

2)Dr Ivan Spasojević, (n.d.), LIQUID3 An urban photo-bioreactor. Retrieved 25/10/2024 From:

https://theindexproject.org/award/nominees/7109

3)Sarah Fecht, (February 25, 2021), How Exactly Does Carbon Dioxide Cause Global Warming?. Retrieved 28/10/2024 From:

https://news.climate.columbia.edu/2021/02/25/carbon-dioxide-cause-global-warming/

4)Urry, L. A., Cain, M. L., Wasserman, S. A., Minorsky, P. V., Orr, R. B., & Campbell, N. A. (2021). Photosynthesis. In *Campbell biology* (12th ed). Pearson. Retrieved 5/11/2024.

5)World Bank Group, (2022). Population, total - Egypt, Arab Rep. Retrieved 17/10/2024 From:

https://data.worldbank.org/indicator/SP.POP.TOTL?locations=EG

Acknowledgement

First and foremost, we would like to express our gratitude to Allah for His countless blessings and guidance that enabled us to complete this capstone project. We would like to extend our heart felt thanks to Mrs.Amal, the school principal, for her unwavering support and encouragement throughout the entire research process. We would also like to acknowledge the in valuable contributions of Mr. Ehab zeka, our capstone teacher, and Mrs Abeer. our capstone teacher, for their expert guidance and technical assistance. We also extend our appreciation to Mr. shady sleim, our capstone leader, and everyone who helped us in any way to make this research.

For further information

Ahmed Ramadan	ahmed.1723014@stemismailia.moe.edu.eg
Moataz Ibrahim	moataz.1723035@stemismailia.moe.edu.eg
Mohamed Ali	mohamed.1732041@stemismailia.moe.edu.eg
Ziad Ahmed	ziad.1723070@stemismailia.moe.edu.eg