



OPERATOR NAME & SIGNATURE:

1. EXTERNALIZED TASKS - to be done last 30 mins BEFORE SHUTDOWN

Working With	Target time	✓ /
UCL/IBDMSG/C/D/q/07.0		

Follow the line washout procedure to clean out the low and high pressure line

ine

and is heard in the nozzle room.

Check Air/Inert Filter is empty due to risk of blockages on start up (take torch); if not tell CRO to divert to big bag and run fines

SOP OWNER Approved by _____ Date: 11/02/2022	HSR APPROVAL Approved by _____ Date: 11/02/2022	QA APPROVAL Approved by _____ Date: 11/02/2022	AUTHORIZATION Approved by _____ Date: 11/02/2022
---	--	---	---



UGEE CHEMICALS

ATTACHMENT 4

SHUT DOWN CHECKLIST MSG

ADMIX FIELD OPERATOR

Page 17 of 24.

UCL/IBDMSG/CD/Q/07.0

OPERATOR NAME & SIGNATURE: _____

DATE OF CHECKS: _____

	Where	Systems	Working With	Expected time in mins	✓/x
1. EXTERNALIZED TASKS - to be done last 1 hour BEFORE SHUTDOWN					
Leave admix area empty of RM pallets and with correct house keeping (particular care with PC3, SEAs, Perfumes & Alex RMs)	On the floor	Admix	L24 cleaner	5	
Cover RM dump spots if no BigBag over it. Stretch wrap all dump spot with or without BigBag	On the floor	Admix	Level 24 contractor	2	
2. EXTERNALIZED TASKS - to be done last 30 mins BEFORE SHUTDOWN					
Confirm all RM addition into mixdrum has been completed (through sequential shut down) and Mixing belt 1 & 2 are empty	HMI	Admix	CRO	2	
Completely run-out all Blown Powder from Bin A & Bin B, all BP weigh hoppers and BP weighbelts as reblend buggy	On the floor/HMI	Admix	CRO	10	
Run SEA, AC Base & MCAS LIW feeder on GD(Gravimetric Discharge) mode 20minutes to shutdown	On the floor/HMI	Admix	CRO	20	
Blow off ALL mix drum nozzles confirming no blockages.	HMI	Admix	CRO	NA	
Blow off perfume mix drum supply lines.	HMI	Admix	NA	5	
When last re-blend buggy comes out of BFS, de-activate current formula & stop admix.	HMI	Admix	CRO	NA	
Close exit valve of perfume tank being used in last formula	HMI	Admix	NA	2	
2. ADMIX SHUT DOWN					
Evacuate AC base containment	On the floor	Admix	ICSL	30	
Run out the remnant inside SEA LIW hopper via the Diverter scrap line	On the floor	Admix	ICSL	10	
Switch off MCC room panels breakers - MDP & breakers, CVC panel, UPS panel, CP41, Air heater panel, HPP panel, Airlift panel, Exhaust fan panel, RVSO Panel, Panel 121, Panel 181 and Perfume panel.	On the floor	Admix			
Check that admix filter is empty by tapping to get hollow sound and free of fines due to risk of blockages on start up (take torch); if not tell CRO to empty it to buggy through entire system	On the floor		Level 24 contractor		
Check admix filter rotary valve chain to be at base condition (Not broken)	On the floor		Level 24 contractor		
Stop cooling tower fan and circulation pump and close the return valve (if applicable).	On the floor	Utilities			

COMMENTS (last changes highlighted in yellow)

SOP OWNER Agbadi Lawrence Date: 11/02/2022	HSE APPROVAL Adebisi Adebayo Date: 11/02/2022	QA APPROVAL Alawode Oluide Date: 11/02/2022	AUTHORISATION Daramola Nadeeb Date: 14/02/2022
---	--	--	---



UGEE CHEMICALS

ATTACHMENT 4

START UP CHECKLIST MSG

TEAM LEADER

OPERATOR NAME & SIGNATURE: _____

SOP No. UCL/IBDMSG/CD/Q/07.0

Page 20 of 24

DATE OF CHECKS: _____

1. START UP SYSTEMS

	Where	Systems	Working With	Target time	Seasonal Items	✓/x	Comments/Improvements to reduce human effort
Confirm level of EW base is sufficient to startup	RV Base room	Crutching	Staging area	ICSL			
Confirm tower cone indicator is green on SCADA, it is cleaned and free to rotate	Pumping floor	Tower					

2. TEAM SET UP

Check that the team is appropriately staffed and backups are triggered if necessary	On the floor	-					
Communicate action on any outage in team setup to the line leader	On the floor	-					
Check the FHC production plan, MSG 24hrs plan and share respective actions with the team	PC	-					
Take actions on any issue that may arise from Startup and communicate to line manager.	On the floor	-					
Open steam supply valve to the line, drain condensate at the ODOS by steaming the ODOS injection head	On the floor						
Follow the Pumping warm up and startup MSG Job Aid 083.02 to clean the low and high pressure slurry lines	On the floor	Pumping	with Crutcher Panel Op. On HMI	5			
Have checked and verified that all startup activities for CRO, TR, Admix & Sattab has been done	On the floor						

COMMENTS (last changes highlighted in yellow)

SOP OWNER Agbadu Lawrence Date: 11/02/2022	QA APPROVAL Alawode Olujide Date: 11/02/2022	HSE APPROVAL Adebisi Adedoyin Date: 11/02/2022	AUTHORISATION Nadeeb Daramola Date: 11/02/2022
---	---	---	---

ATTACHMENT 4
START UP CHECKLIST MSG
CRO OPERATOR

OPERATOR NAME & SIGNATURE: _____

SOP No. UCL/BDMSG/CD/Q/07.0

Page 22 of 24

DATE OF CHECKS:	Where	Systems	Working With	Time (mins)	✓/x	
1. START UP SYSTEMS						
Follow the generator Startup and shutdown job aid to start the F&HC generator and all relevant panels as stated in the Tower SU & SD SOP	Lv 0	Utilities				
Switch ON the UPS, Servers, Control room PCs, and launch the factory talk program, SQL server and Transaction Manager	Control room	IT	Admix runner	15		
Confirm that the right admix recipe is loaded on the Admix page of the SCADA	HMI	IT	Satlab operator	2		
Switch on the BFMS server and launch the BFM application	Control room	BFMS				
Turn on ODOS panel	Pumping floor	Pumping		5		
Start the sulphate carbonate fan and double flap discharger	Control room	Crutching		2		
Start the rotocloner fan	Control room	Crutching		2		
Start the diesel loading pump (if running airheater or boiler on diesel)	Control room	Tower		2		
Start the tower ancillary systems (cyclone screw and rotary valve, airlift screw and rotary valve, GS rotary valve, PWS flapper and belt)	Control room	Tower		1		
Start all material transfers to silos (HLAS, Caustic & Silicate)	HMI	Crutching	Tower runner	5		
Start high pressure compressor for air injection	HMI	Crutching	Tower runner	2		
Start admix fan from scada and verify it is running from the VFD panel on Level 12.	HMI	Filter	Admix runner	2		
Make sure enzymes dust control system is ON	HMI	Filter	Admix runner	2		
Check that there is zero content inside the Crutcher before crutching and empty content if any	Crutcher floor	Crutching	Level 6 Excel	5		
Check that there is no material build up/make inside the bulk solid materials hopper on the Crutcher and clear if any	Crutcher floor	Crutching	Level 6 Excel	5		
Check that there is no material build up/make inside the dry scrap, carbonate and sulphate screw discharge chutes and clear if any	Crutcher floor	Crutching	Level 6 Excel	5		
Check that there is no accumulation on the crutcher agitator and clean if any	Crutcher floor	Crutching	Level 6 Excel	5		
Check that BP bins and weigh hoppers are empty and run out powder into the buggies if necessary	HMI	Admix	BFS Excel	2		
Confirm admix filter hopper is empty	HMI	Admix	BFS Excel, Hygiene, Admix runner	20		
Start droptank agitator	HMI	Pumping				
2. PREPARE CRUTCHER BATCHES						
Check pre-requisites are established: - Steam pressure & Air injection compressed air pressure - Raw materials in the silos and day tank have enough material	HMI	Crutching		2		
Confirm crutcher recipe	HMI	Crutching		2		
Set Remelt Setpoint to zero during remelt preparation	HMI	Crutching				
Make the first crutcher batch - Use CMM calculator to confirm amount of water to be used in first batch - Ensure level 6 contractor monitors and confirms every material is dosed per recipe - PM electrical is on hand to troubleshoot any electrical issues	HMI	Crutching	Level 6 Excel PM Electrical	20		
2. TOWER WARM UP (in parallel)						
Check rotary valves of cyclones are working without issues and no blockages on chutes/ducts	HMI	BP Handling	Tower runner	5		
Begins Tower and Saacke Burner Start Up Procedure (auto with confirmation of every step):	HMI	BP Handling				
Start up exhaust fan	HMI	BP Handling		1		
Start up of airlift fan & purge	HMI	BP Handling		1		
Start the air heater	HMI	BP Handling	Satlab	15		
Divert air heater to stack and pre-heat the tower until exhaust temperature is at least 90degC and inlet temperature is at least 170degC	HMI	BP Handling		10		
Start the tower belt after air heater is on	HMI	BP Handling		2		
Continue preparing crutcher batches while air heater is starting up	HMI	Crutching				
3. PUMPING WARMING UP & SET UP						
Follow the Pumping warm up and startup MSG Job Aid 083.02 to clean the low and high pressure slurry lines	HMI	Pumping	Tower runner	5		
Close all nozzle valves left open on shutdown for draining	HMI (if auto)	Pumping	Tower runner	2		
Close the HPL drain valve after the HPP once pumping warmup is completed		Pumping	Tower runner	2		
4. TOWER START UP PROCEDURE						
Confirm tower is already warmed up (exhaust temperature above 85°C)	HMI	BP Handling	Team leader	2		
Check that the tower belt and rest of BP handling equipment is started	HMI	BP Handling	Tower runner	2		
Start spraying with one nozzle and ramp up gradually based on BP moisture and density. Ensure level 24 ICSL on the floor to clear PWS	HMI	BP Handling	Satlab	15		
Take CatSO3 sample; record ODOS differential temperature _____ & injection ratio	HMI	BP Handling	Satlab	3		
5. ADMIX READINESS						
Empty weigh belt hopper	HMI & on the floor	Admix	Admix runner	2		
Blow off mix drum nozzles confirming no blockages.	HMI	Admix	Admix runner	3		
Check that all day bins and LIW have sufficient materials- check hopper weighs and refill any feeder with low levels	HMI	Admix	Admix runner	3		
Complete Admix feeders sequence run by running all LIWs for 1 minute each; ensure mixdrum is running & feeder deviation <1%	HMI	Admix	Admix runner	3		
Run all LIW feeders refill system from the scada to ensure no refill faults at start up	HMI	Admix	Admix runner	5		

COMMENTS (last changes highlighted in yellow)

SOP OWNER	QA APPROVAL	HSE APPROVAL	AUTHORISATION
Agbadu Lawrence	Alawode Olujide	Adebisi Adedoyin	Nadeeb Daramola
Date: 11/02/2022	Date: 11/02/2022	Date: 11/02/2022	Date: 11/02/2022



ATTACHMENT 4

0

UGEE CHEMICALS

TOWER FIELD OPERATOR

OPERATOR NAME & SIGNATURE: _____

DATE OF CHECKS: _____

SOP No. UCL/BDMSG/CD/Q/07.0

Page 21 of 24

1. PUMPING WARMING UP & READINESS

Where	Systems	Working With	Target time	✓/x
Open the main process water valve	Process water tank	Pumping	3	
Switch on boiler panel, the boiler, check that water levels across boiler room vessels are okay	Boiler room	Utilities	2	
Switch on MSG air compressor and the air dryer, Confirm compressor valves are opened	Compressor shed	Utilities	4	
Check air injection compressor is on; confirm oil level is within VC and that room extraction fan is on	Air injection shed	Utilities	3	
Check that the solids addition bowl is empty. Break any lumps and discharge using the "Inspection Dry scrap hopper & Crutcher Solids addition bowl at Startup & Shutdown" OPL	On the floor	Crutching	Level 6 ICSL	5
Install Rietz basket and close it	On the floor	Pumping		10
Check that the level of water in the decantation tank is within visual control; Start HPP Oil pump & HPP cooling water pump; Confirm water flow to the plungers.	On the floor	Pumping	CRO	2
Start Rietz water pump; check mech seal cooling water pressure & flow reading.	On the floor	Pumping	CRO	5
Close all Normally closed manual valves (Crutcher, drop tank, LPP head, LPL before & after reitz, HPP end flange, HPL drain valves).	On the floor	Pumping		5

2. TOWER AREA SYSTEMS READINESS

Check that Airift Filter is Empty (tap using a mallet), Airift screw & Rotary valve is free of accumulations & clean if otherwise	On the floor	BP Handling		5
Check that there is no blockage in Gravity Separator chutes above Rotary Valves	On the floor	BP Handling		5
Check that there is no blockage above Rotary Valves: GS, Cyclone, Admix filter	On the floor	BP Handling		10
Check that there is no blockage on the cyclone and Airift return lines to bag	On the floor	BP Handling		10
Check that the PWS belt is cleaned	On the floor	BP Handling		5
Check that the BOT belt is cleaned	On the floor	BP Handling		
Clean BOT infrared sensor	On the floor	BP Handling		5

3. OTHER

Confirm functionality of barcode scanner for suphate and carbonate on L12	On the floor	Crutching		5
---	--------------	-----------	--	---

COMMENTS (last changes highlighted in yellow)

SOP OWNER Signature: Date: 11/02/2022	QA APPROVAL Signature: Date: 11/02/2022	HSE APPROVAL Signature: Date: 11/02/2022	AUTHORISATION Signature: Date: 11/02/2022
--	--	---	--



UGEE CHEMICALS

ATTACHMENT 4
START UP CHECKLIST MSG
ADMIX FIELD OPERATOR

Page 23 of 24.

OPERATOR NAME & SIGNATURE: _____

SOP No. UCL/IBDM/SG/CD/Q/07.0

DATE OF CHECKS: _____

1. START UP SYSTEMS

	CPS?	Where	Systems	Working With	Target time	✓/x
Switch turn on MCC room panels breakers - MDP & breakers, CVC panel, UPS panel, CP41, Air heater panel, HPP panel, Airift panel, Exhaust fan panel, Air injection panel, boiler panel	Yes	MCC room		CRO	5	
Switch ON L6 Panel (RVSO Panel/Crutchler panel)	Yes	Level 6			2	
Switch on level 12 panel(Panel 121, Perfume skid panel, NI skid panel)		Level 12			2	
Switch on level 18 panel		Level 18			5	
Confirm NI heater is on	Yes	Level 12			5	
Confirm functionality of barcode scanners in L24		Level 24			5	
Confirm enzymes dust controls fan and rotary valve are ON		Level 24	Filter		5	

2. ADMIX READINESS

Open valve of required perfume day tank (manual Valve labelled Green)		On the floor or HMI		CRO	2	
Confirm perfumes lines RVSO and NI lines are pressurized (5bar)		On the floor		CRO	10	
Refill SEA LIW Hopper and start the LIW feeder		On the floor/HMI		CRO	5	
Confirm that there are no trips on the lighting and socket breakers. Visibly check that all the insectocutor pubs are powered		On the floor	E&I		10	
Confirm that mettlert toledo display on level 18 panel is showing the weights of the weighing hoppers		On the floor			2	
Switch ON OP12 & Verify that all parameters are correct compared with OP12 programmable centerline sheet making sure there are no failure modes active		On the floor	E&I		15	
Unlock all LIW loadcells					15	
Conduct Static calibration check on the weigh belt 1 & 2		On the floor	Admix		15	
Load RM according to production schedule brands		On the floor	Admix		5	
Run all LIW feeders for 1 minute each from the OP12 panel (ensure mixdrum is running)		On the floor	Admix		5	
Run all LIW feeders refill system from the scada to ensure no refill faults at start up		HMI & on the floor	CRO		5	
Clear Enzyme accumulation on vibratory tray and Run from Control room		HMI & on the floor	CRO		5	
Empty BP weigh belt weighhoppers		HMI & on the floor	CRO		10	
Open valve of required perfume day tank (manual Valve labelled Green)		On the floor or HMI		CRO	5	
Check BFS hopper is empty & free of lumps, break if necessary, confirm that the density station line valve is responding to push button		On the floor		BFS contractors	10	
Admix DCS cleaning - Run the mix drum and belt from the control room		Control Room			5	
Communicate to Buggy operators DCS powder will be dosed. Place empty buggy in the buggy filling station		Buggy floor			2	
Clear blockage and caked powder in the DCS lower into the particular buggy at the filling station		Level 30			15	
Communicate to CRO blockage is completely cleared and powder evacuated		Control Room			2	

COMMENTS (last changes highlighted in yellow)

SOP OWNER	QA APPROVAL	HSE APPROVAL	AUTHORISATION
Agbadu Lawrence	Alawode Oluide	Adebisi Adedoyin	Nadeeb Daramola
Date: 11/07/2022	Date: 11/07/2022	Date: 11/07/2022	Date: 14/02/2022



UGEE CHEMICALS

ATTACHMENT 4

START UP CHECKLIST MSG

SATLAB PERSONNEL OR OTHER OPERATOR AVAILABLE

OPERATOR NAME & SIGNATURE: _____

SOP No. UCL/BDMSG/CD/Q/07.0

Page 24 of 24

DATE OF CHECKS: _____

1. START UP SYSTEMS

	CPS?	Where	Systems	Working With	Target time	✓/x
Switch ON satlab PC		Control room			3	
Open air heater fuel source valves (diesel or gas) and swap air heater to the required fuel source		Air heater	Tower		1	
Confirm inlet gas pressure (if running on gas) or diesel tank has been refilled (if running on diesel)		Air heater	Tower	CRO	1	
Start the air heater		Air heater	Tower	CRO	5	
Start up the BFMS server and launch the BFM application		Bugby Filling Station		CRO	3	
Check for buggies greater than two days on storage from the production date and tag them as "reblend"		Bugby Filling Station		BFS ICSL	4	
Download Admix Production Recipe and verify with the BPR		Control room		CRO	3	
OTHER TASKS						
Inspect and clean the CMM sampling point on the Ageing vessel line		On the floor	Crutching		5	
Appearance check for startup buggy		On the floor	BFS	BFS ICSL	5	
Check and confirm translation of BPR values on scada (match the admix and tower recepie on SCADA and BPR)		On the floor	Control room	CRO	10	

Comments (last changes highlighted in yellow)

SOP OWNER Agbadu Lawrence Date: 11/02/2022	QA APPROVAL Alawode Olajide Date: 11/02/2022	HSE APPROVAL Adebisi Adedoyin Date: 11/02/2022	AUTHORISATION Nadeeb Daramola Date: 14/02/2022
---	---	---	---



UGEE CHEMICALS

ATTACHMENT 4 SHUT DOWN CHECKLIST MSG SATLAB LEADER

UCL/BDMSG/CD/Q/07.0 Page 13 of 24

OPERATOR NAME & SIGNATURE: _____

DATE OF CHECKS: _____

	Where	Systems	Working With	Expected time (mins)	Seasonal Fems	✓/x	
Check Airfilt Filter is empty due to risk of blockages on start up (take torch); if not tell CRO to divert to big bag and run fines into big bags	On the floor	Base Powder Handling	Crutcher Panel Op.	2			
Clean the chutes above the Gravity Separator Rotary Valve	On the floor	Base Powder Handling		5			
Clean PWS	On the floor	Base Powder Handling		10			
Clean the Density station(Inerior and exterior)	On the floor	Base Powder Handling		10			
Clean the sampling point for CMM and the sampling cup	On the floor	Crutching		10			

COMMENTS

SOP OWNER Agbadu Lawrence Date: 11/02/2022	HSE APPROVAL Adebiyi Adedoyin Date: 11/02/2022	QA APPROVAL Alawode Olufide Date: 11/02/2022	AUTHORIZATION Daramola Nadeeb Date: 14/02/2022
---	---	---	---



ATTACHMENT 4
SHUT DOWN CHECKLIST MSG
TEAM LEADER

UGEE CHEMICALS

UCL/BDMSG/CD/Q/07.0 Page 18 of 24

OPERATOR NAME & SIGNATURE: _____

DATE OF CHECKS: _____

	Where	Systems	Working With	Expected time (mins)	✓/x	
Close main process water valve into the operation	On the floor	Utilities	NA	5		
Clean tower belt drum free of make up	On the floor	BP handling	ICSL	30		
Clean the airflit from level 0 to level 6	On the floor	BP handling	ICSL	20		
Check the tower belt for charred powder and clean if applicable	On the floor	BP handling	CRO, ICSL	5		
Follow the washout procedure of LP and HP lines for a for long shutdown job aid no:065.03 to steam out the high pressure line	On the floor	Pumping	CRO	15		
Makes sure all roles are staffed for shutdown	On the floor	-	NA	NA		
Manages and provides resources to solve any issue during shut down process	On the floor	-	NA	NA		
Have checked and verified that all shutdown activities for CRO, TR, Admix & Sallab has been done						

COMMENTS (last changes highlighted in yellow)

SOP OWNER Agbadu Lawrence Date: 11/02/2022	HSE APPROVAL Adebisi Adegboyin Date: 11/02/2022	QA APPROVAL Alawode Adebisi Date: 14/1 Feb 2022	AUTHORIZATION Daramola Nadeeb Date: 14/02/2022
---	--	--	---



UGET CHEMICALS

ATTACHMENT 4 SHUT DOWN CHECKLIST MSG CRO OPERATOR

OPERATOR NAME & SIGNATURE: _____

DATE OF CHECKS: _____

UCL/BDMMSGCD/07.0

Page 16 of 24

	Where	System	Working With	Target time	✓/x
1. EXTERNALIZED TASKS - to be done last 30 mins BEFORE SHUTDOWN					
Increase usage of dry scrap for the last two crutcher batches while still adhering to the reblend matrix	On the floor	Dry scrap	Level 6 contractor	NA	
Ensure remelt vessel is completely empty at shut down	HMI	Remelt	Tower runner	NA	
Ensure dry scrap screw is completely empty at shut down	HMI	Dry scrap	Tower runner	NA	
2. WASH OUT PROCEDURES					
Follow the line washout procedure to clean out the low and high pressure line	HMI		Tower Field Op.	NA	
a. Transfer 150kg of water into the Crutcher, agitate at high speed - to completely clean out any residual slurry.	HMI & On the floor	Crutcher	16 contractor	NA	
b. Clean the solids inlet bowl to the crutcher and any deposits of slurry on the crutcher agitator into the water	Level 6	Pumping	Tower runner, level 6 contractor	NA	
c. Open the magnetic filter drain valve and the Crutcher auto valve to empty the content of the Crutcher into the pit	HMI & On the floor	Pumping	Tower runner	NA	
d. Flush the crutcher Transfer line into the Ageing vessel with water from Flushing water pump.	HMI & On the floor	Pumping	Tower runner	NA	
e. Spray the water through the pumps and nozzles into the tower using the flushing water pump - ensure air injection is on to flush the air injection system	HMI	Pumping	Tower runner	NA	
f. Steam out the ODS injection head while spraying water	HMI, pump floor	Pumping	Tower runner	10	
g. Spray water through all the nozzles 1-6 to avoid blocked nozzles	HMI	Pumping	Tower runner	15	
h. Open all drains to drain water and left drains open - Ageing vessel, before and after L.P.P, before H.P.P, after H.P.P	HMI, pump floor	Pumping	Tower runner	10	
i. Open the reitz filter basket and leave open with the basket out	HMI, pump floor	Pumping	Tower runner	NA	
j. Run cooling water through reitz mechanical seal after pump shutdown for 10mins	HMI, pump floor	Pumping	Tower runner	NA	
3. SHUT DOWN OF SYSTEMS					
Stop crutcher and droplank agitators	HMI	Crutcher		1	
Stop crutcher & drop tank rotolcone	HMI	Crutcher		1	
Stop high pressure compressor for air injection	HMI	Crutcher		1	
Stop Pumps, motors, filters & Agitators	HMI	All Making		1	
Switch OFF all P.C.S, screens, and applicable panels in control room 1&2	Control room 1&2			4	
5. AIR HEATER SHUTDOWN					
Switch off Burner on Air Heater HMI	HMI, level 0	Air Heater		3	
Turn off main gas supply valve	HMI, level 1	Air Heater		1	
6. SHUT DOWN OF SYSTEMS					
Stop all transfers from silos/day tanks	HMI	Transfers		1	
Stop admix dust controls except enzyme dust control which must be left ON (stop fan, leave 2 minutes, stop compressed air for bags, wait 2 mins and then stop the rotary valve)	HMI	Filter		1	
Stop all core equipment from tower belt to BFS	HMI	Several		1	
Run Exhaust fan to cool the tower to exhaust temperature of 55degC as shown on QVW	HMI	Spraying		1	
Clean the tower cone cleaner ring with a scraper	On the floor	Spraying		1	
Stop airlift air conditioner chiller pump (if applicable)	HMI	Airlift/Util.		1	
Close the manual valve before crutcher steam feeding system.	On the floor	Crutcher		1	

COMMENTS (last changes highlighted in yellow)

SOP OWNER Agbadu Lawrence Date: 11/02/2022	HSE APPROVAL Adebisi Adedoyin Date: 11/02/2022	QA APPROVAL Alawode Oluide Date: 11/02/2022	AUTHORISATION Daramola Nadeob Date: 14/02/2022
---	---	--	---