

Facility Management Quarterly Report - Q2 2026

Harmony Senior Residences · Senior Living · Singapore

Document ID	SL-01
Category	Facility Management
Classification	Operational
Date	2026-07
Prepared by	Facility Management Team, Harmony Senior Residences

1. Property overview

Harmony Senior Residences has 220 residential units in two 12-storey blocks, with a care centre, dining hall and therapy rooms. Common areas and resident rooms are cooled by a central 350 RT water-cooled chiller plant with two cooling towers, and each room has a fan coil unit. Each block has two lifts.

KPI (Q2 2026)	Value	vs Q2 2025
Electricity (MWh)	740	+3%
Chiller plant efficiency (spot reading, kW/RT)	1.05	n/a
Work orders	412	+9%
Average work order response (hours)	3.8	+0.6
Lift breakdowns	6	+2
Hot water complaints	23	+8

2. Key issues

- Energy: air-conditioning runs 24 hours a day in common areas and resident rooms. The chiller plant has no permanent metering, and the spot reading of 1.05 kW/RT suggests poor efficiency. Chillers are staged manually by the technician on duty.
- Lifts: six breakdowns in the quarter, mostly door-related. Residents with mobility aids are the most affected; see the lift incident log for details.
- Hot water: electric storage heaters cannot meet the morning peak demand, leading to complaints about lukewarm showers.
- Resident satisfaction: families have complained about slow repairs and a lack of updates during maintenance works.

3. Q3 2026 action plan

- Commission a chiller plant efficiency audit and install basic metering.
- Review the lift maintenance contract and response times with the contractor.
- Study the feasibility of heat-pump hot water.
- Introduce advance notices for maintenance works that affect residents.