

## Sequence Report



### Summary

#### Mic500 200k Termination

Signal Path Setup PASSED

Stepped Frequency Sweep MIC 500 FAILED

#### Mic 2k 200k termination

Signal Path Setup PASSED

Stepped Frequency Sweep MIC 2K FAILED

#### Mic 2k 15dB PAD 200k termination

Signal Path Setup PASSED

Stepped Frequency Sweep 15dB PAD FAILED

#### Line Gain -10 200kTermination

Signal Path Setup PASSED

Stepped Frequency Sweep -10 FAILED

#### Line Gain -10 600 Termination

Signal Path Setup PASSED

Level and Gain -10 PASSED

#### Line Gain +5 200kTermination

Signal Path Setup PASSED

Stepped Frequency Sweep +5 FAILED

#### Line Gain +5 600 Termination

Signal Path Setup PASSED

Level and Gain +5 FAILED

#### Line Gain -5 600 Termination

Signal Path Setup PASSED

Level and Gain -5 FAILED

#### Line Gain 0 600 Termination

Signal Path Setup PASSED

Level and Gain 0 FAILED

#### Line Gain +10 600 Termination

Signal Path Setup PASSED

Level and Gain +10 FAILED

#### Line Gain +10 200k Termination Level Hi

Signal Path Setup PASSED

Noise Recorder (RMS) CW FAILED

#### Line Gain +10 200k Termination Level Low

Signal Path Setup PASSED

Noise Recorder (RMS) CCW FAILED

#### Hi Z Gain -10 2.2M 200k Termination

Signal Path Setup	✓ PASSED
Level and Gain 2.2M	⚠ FAILED
Hi Z Gain -10 47k 200k Termination	
Signal Path Setup	✓ PASSED
Level and Gain 47K	⚠ FAILED
Dummy Signal Path For Report	
Signal Path Setup	✓ PASSED
Sequence Result:	
Sequence Result:	⚠ FAILED

## Sequence Report



### Mic500 200k Termination : Signal Path Setup

Output Connector:	Analog Balanced
Channels:	1
Source Impedance:	100 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Balanced
Channels:	1
Channel:	Ch1
Termination:	200 kohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

#### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBrA:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

#### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00

## Sequence Report



Port C (hex): 00  
Port D (hex): 00  
• Clocks  
Output Rate: Track Output SR  
Sync Out Level: 3.300 V  
Sync Out Polarity: Normal  
Timebase Reference: Internal  
Jitter: Disabled  
• Triggers  
Source: Off  
Input Logic Level: 3.300 V  
Edge: Rising

### Mic500 200k Termination : Verify Connections

Waveform: Sine  
Generator Level: -42.300 dBu  
DC Offset: 0.000 V  
Frequency: 1.00000 kHz

### RMS Level (5/15/2023 5:55:58.613 PM)

Ch1 290.7 mVrms

### Gain (5/15/2023 5:55:58.613 PM)

Ch1 33.788 dB

### THD+N Ratio (5/15/2023 5:55:58.613 PM)

Ch1 ---- %

### Frequency (5/15/2023 5:55:58.613 PM)

Ch1 ---- Hz

## Sequence Report



Mic500 200k Termination : Stepped Frequency Sweep MIC 500

Generator Level: -42.300 dBu

DC Offset: 0.000 V

EQ: None

Start Frequency: 20.0000 kHz

Stop Frequency: 20.0000 Hz

Step Type: Logarithmic

Number of Points: 10


Weighting Filter: Signal Path

High-pass Filter: 20 Hz

Phase Ref Channel: Ch1

Measured 1 5/15/2023 5:56:02 PM

RMS Level (5/15/2023 5:56:02.075 PM)




Ch1 Failed Lower Limit

## Sequence Report



Result: ▲ FAILED


THD+N Ratio (5/15/2023 5:56:02.075 PM)



Result: ✔ PASSED

THD Ratio (5/15/2023 5:56:02.075 PM)

## Sequence Report



Ch1 Failed Upper Limit

Result: FAILED

## Sequence Report



### Mic 2k 200k termination : Signal Path Setup

Output Connector:	Analog Balanced
Channels:	1
Source Impedance:	100 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Balanced
Channels:	1
Channel:	Ch1
Termination:	200 kohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

#### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBrA:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

#### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00
Port C (hex):	00

5/15/2023 5:58 PM



## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Mic 2k 200k termination : Verify Connections

Waveform: Sine

Generator Level: -42.300 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

### RMS Level (5/15/2023 5:56:07.113 PM)

Ch1 287.4 mVrms

### Gain (5/15/2023 5:56:07.113 PM)

Ch1 33.688 dB

### THD+N Ratio (5/15/2023 5:56:07.113 PM)

Ch1 ---- %

### Frequency (5/15/2023 5:56:07.113 PM)

Ch1 ---- Hz

## Sequence Report



Mic 2k 200k termination : Stepped Frequency Sweep MIC 2K

Generator Level: -42.300 dBu

DC Offset: 0.000 V

EQ: None

Start Frequency: 20.0000 kHz

Stop Frequency: 20.0000 Hz

Step Type: Logarithmic

Number of Points: 10


Weighting Filter: Signal Path

High-pass Filter: 20 Hz

Phase Ref Channel: Ch1

Measured 1 5/15/2023 5:56:10 PM

RMS Level (5/15/2023 5:56:10.658 PM)




Ch1 Failed Lower Limit

## Sequence Report



Result: ▲ FAILED

THD Ratio (5/15/2023 5:56:10.658 PM)



Ch1 ▲ Failed Upper Limit

Result: ▲ FAILED

## Sequence Report



Mic 2k 15dB PAD 200k termination : Signal Path Setup

Output Connector:	Analog Balanced
Channels:	1
Source Impedance:	100 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Balanced
Channels:	1
Channel:	Ch1
Termination:	200 kohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBrA:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00
Port C (hex):	00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Mic 2k 15dB PAD 200k termination : Verify Connections

Waveform: Sine

Generator Level: -42.300 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

### RMS Level (5/15/2023 5:56:15.810 PM)

Ch1 283.7 mVrms

### Gain (5/15/2023 5:56:15.810 PM)

Ch1 33.577 dB

### THD+N Ratio (5/15/2023 5:56:15.810 PM)

Ch1 ---- %

### Frequency (5/15/2023 5:56:15.810 PM)

Ch1 ---- Hz

## Sequence Report



Mic 2k 15dB PAD 200k termination : Stepped Frequency Sweep 15dB PAD

Generator Level: -42.000 dBu

DC Offset: 0.000 V

EQ: None

Start Frequency: 20.0000 kHz

Stop Frequency: 20.0000 Hz

Step Type: Logarithmic

Number of Points: 10


Weighting Filter: Signal Path

High-pass Filter: 20 Hz

Phase Ref Channel: Ch1

Measured 1 5/15/2023 5:56:19 PM

RMS Level (5/15/2023 5:56:19.979 PM)




Ch1 Failed Upper Limit

## Sequence Report



Result: ▲ FAILED

THD Ratio (5/15/2023 5:56:19.979 PM)



Ch1 ▲ Failed Upper Limit

Result: ▲ FAILED

## Sequence Report



### Line Gain -10 200kTermination : Signal Path Setup

Output Connector:	Analog Balanced
Channels:	1
Source Impedance:	100 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Balanced
Channels:	1
Channel:	Ch1
Termination:	200 kohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

#### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBra:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

#### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00
Port C (hex):	00

5/15/2023 5:58 PM



## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Line Gain -10 200kTermination : Verify Connections

Waveform: Sine

Generator Level: 0.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:56:25.124 PM)

Ch1 296.0 mVrms

Gain (5/15/2023 5:56:25.124 PM)

Ch1 -8.357 dB

THD+N Ratio (5/15/2023 5:56:25.124 PM)

Ch1 ---- %

Frequency (5/15/2023 5:56:25.124 PM)

Ch1 ---- Hz

## Sequence Report



Line Gain -10 200kTermination : Stepped Frequency Sweep -10

Generator Level: 0.000 dBu

DC Offset: 0.000 V

EQ: None

Start Frequency: 20.0000 kHz

Stop Frequency: 20.0000 Hz

Step Type: Logarithmic

Number of Points: 15


Weighting Filter: Signal Path

High-pass Filter: 20 Hz

Phase Ref Channel: Ch1

Measured 1 5/15/2023 5:56:29 PM

RMS Level (5/15/2023 5:56:29.658 PM)



Ch1 Failed Lower Limit

5/15/2023 5:58 PM


Page 18 of 54

# Sequence Report



Result: ▲ FAILED

THD+N Ratio (5/15/2023 5:56:29.658 PM)



Ch1 ▲ Failed Upper Limit

Result: ▲ FAILED

## Sequence Report



### Line Gain -10 600 Termination : Signal Path Setup

Output Connector:	Analog Balanced
Channels:	1
Source Impedance:	100 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Balanced
Channels:	1
Channel:	Ch1
Termination:	600 ohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

#### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBrA:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

#### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00
Port C (hex):	00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Line Gain -10 600 Termination : Verify Connections

Waveform: Sine

Generator Level: -10.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

### RMS Level (5/15/2023 5:56:34.895 PM)

Ch1 297.0 mVrms

### Gain (5/15/2023 5:56:34.895 PM)

Ch1 1.673 dB

### THD+N Ratio (5/15/2023 5:56:34.895 PM)

Ch1 ---- %

### Frequency (5/15/2023 5:56:34.895 PM)

Ch1 ---- Hz

## Sequence Report



Line Gain -10 600 Termination : Level and Gain -10

Waveform: Sine

Generator Level: -10.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:56:37.565 PM)

Channel	Lower Limit	Value	Upper Limit	
Ch1	-11.500 dBu	-8.528 dBu	-8.500 dBu	✓

Result: ✓ PASSED

## Sequence Report



### Line Gain +5 200kTermination : Signal Path Setup

Output Connector: Analog Balanced  
Channels: 1  
Source Impedance: 100 ohm  
AG52 Generator Option: Installed  
Output EQ: None  
Input Connector: Analog Balanced  
Channels: 1  
Channel: Ch1  
Termination: 200 kohm  
Input Bandwidth: AC (<10 Hz) - 90k (192 kHz SR)  
Device Delay: 0.000 s  
Input EQ: None

#### • References

dBr G: 100.0 mVrms  
dBm (Output Power): 600.0 ohm  
W(watts) (Output Power): 8.000 ohm  
Shared Frequency Reference: 1.00000 kHz  
dBrA: 1.000 Vrms  
dBrB: 1.000 Vrms  
dBrA Offset: 0.000 dB  
dBrB Offset: 0.000 dB  
dBSPL1: 10.00 mVrms  
dBSPL2: 10.00 mVrms  
dBSPL1 Calibrator Level: 94.000 dB SPL  
dBSPL2 Calibrator Level: 94.000 dB SPL  
dBm (Input Power): 600.0 ohm  
W(watts) (Input Power): 8.000 ohm

#### • DCX

DC Output 1: 0.000 V  
DC Output 1: Off  
DC Output 2: 0.000 V  
DC Output 2: Off  
Port A (hex): 00  
Port B (hex): 00  
Port C (hex): 00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Line Gain +5 200kTermination : Verify Connections

Waveform: Sine

Generator Level: 0.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:56:42.794 PM)

Ch1 283.0 mVrms

Gain (5/15/2023 5:56:42.794 PM)

Ch1 -8.746 dB

THD+N Ratio (5/15/2023 5:56:42.794 PM)

Ch1 ---- %

Frequency (5/15/2023 5:56:42.794 PM)

Ch1 ---- Hz



## Sequence Report



Line Gain +5 200kTermination : Stepped Frequency Sweep +5

Generator Level: 0.000 dBu

DC Offset: 0.000 V

EQ: None

Start Frequency: 20.0000 kHz

Stop Frequency: 20.0000 Hz

Step Type: Logarithmic

Number of Points: 15


Weighting Filter: Signal Path

High-pass Filter: 20 Hz

Phase Ref Channel: Ch1

Measured 1 5/15/2023 5:56:47 PM

RMS Level (5/15/2023 5:56:47.582 PM)




Ch1 Failed Lower Limit

Sequence Report



Result: ▲ FAILED

THD+N Ratio (5/15/2023 5:56:47.582 PM)



Ch1 ▲ Failed Upper Limit

Result: ▲ FAILED

## Sequence Report



### Line Gain +5 600 Termination : Signal Path Setup

Output Connector:	Analog Balanced
Channels:	1
Source Impedance:	100 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Balanced
Channels:	1
Channel:	Ch1
Termination:	600 ohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

#### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBrA:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

#### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00
Port C (hex):	00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Line Gain +5 600 Termination : Verify Connections

Waveform: Sine

Generator Level: -10.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:56:53.119 PM)

Ch1 280.4 mVrms

Gain (5/15/2023 5:56:53.119 PM)

Ch1 1.175 dB

THD+N Ratio (5/15/2023 5:56:53.119 PM)

Ch1 ---- %

Frequency (5/15/2023 5:56:53.119 PM)

Ch1 ---- Hz

## Sequence Report



Line Gain +5 600 Termination : Level and Gain +5


Waveform: Sine

Generator Level: -10.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:56:55.874 PM)

Channel	Lower Limit	Value	Upper Limit	
Ch1	+3.500 dBu	-8.698 dBu	+6.500 dBu	

Result:  FAILED

## Sequence Report



### Line Gain -5 600 Termination : Signal Path Setup

Output Connector:	Analog Balanced
Channels:	1
Source Impedance:	100 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Balanced
Channels:	1
Channel:	Ch1
Termination:	600 ohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

#### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBrA:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

#### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00
Port C (hex):	00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Line Gain -5 600 Termination : Verify Connections

Waveform: Sine

Generator Level: -10.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

### RMS Level (5/15/2023 5:57:01.228 PM)

Ch1 293.7 mVrms

### Gain (5/15/2023 5:57:01.228 PM)

Ch1 1.577 dB

### THD+N Ratio (5/15/2023 5:57:01.228 PM)

Ch1 ---- %

### Frequency (5/15/2023 5:57:01.228 PM)

Ch1 ---- Hz

## Sequence Report



Line Gain -5 600 Termination : Level and Gain -5

Waveform: Sine

Generator Level: -10.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:57:04.093 PM)

Channel	Lower Limit	Value	Upper Limit	
Ch1	-6.500 dBu	-8.731 dBu	-3.500 dBu	

Result:  FAILED



## Sequence Report



### Line Gain 0 600 Termination : Signal Path Setup

Output Connector: Analog Balanced  
Channels: 1  
Source Impedance: 100 ohm  
AG52 Generator Option: Installed  
Output EQ: None  
Input Connector: Analog Balanced  
Channels: 1  
Channel: Ch1  
Termination: 600 ohm  
Input Bandwidth: AC (<10 Hz) - 90k (192 kHz SR)  
Device Delay: 0.000 s  
Input EQ: None

#### • References

dBr G: 100.0 mVrms  
dBm (Output Power): 600.0 ohm  
W(watts) (Output Power): 8.000 ohm  
Shared Frequency Reference: 1.00000 kHz  
dBrA: 1.000 Vrms  
dBrB: 1.000 Vrms  
dBrA Offset: 0.000 dB  
dBrB Offset: 0.000 dB  
dBSPL1: 10.00 mVrms  
dBSPL2: 10.00 mVrms  
dBSPL1 Calibrator Level: 94.000 dB SPL  
dBSPL2 Calibrator Level: 94.000 dB SPL  
dBm (Input Power): 600.0 ohm  
W(watts) (Input Power): 8.000 ohm

#### • DCX

DC Output 1: 0.000 V  
DC Output 1: Off  
DC Output 2: 0.000 V  
DC Output 2: Off  
Port A (hex): 00  
Port B (hex): 00  
Port C (hex): 00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Line Gain 0 600 Termination : Verify Connections

Waveform: Sine

Generator Level: -10.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:57:09.614 PM)

Ch1 285.0 mVrms

Gain (5/15/2023 5:57:09.614 PM)

Ch1 1.314 dB

THD+N Ratio (5/15/2023 5:57:09.614 PM)

Ch1 ---- %

Frequency (5/15/2023 5:57:09.614 PM)

Ch1 ---- Hz

## Sequence Report



Line Gain 0 600 Termination : Level and Gain 0


Waveform: Sine

Generator Level: -10.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:57:12.467 PM)

Channel	Lower Limit	Value	Upper Limit	
Ch1	-1.500 dBu	-8.674 dBu	+1.500 dBu	

Result:  FAILED

## Sequence Report



### Line Gain +10 600 Termination : Signal Path Setup

Output Connector:	Analog Balanced
Channels:	1
Source Impedance:	100 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Balanced
Channels:	1
Channel:	Ch1
Termination:	600 ohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

#### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBrA:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

#### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00
Port C (hex):	00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Line Gain +10 600 Termination : Verify Connections

Waveform: Sine

Generator Level: -10.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

### RMS Level (5/15/2023 5:57:17.991 PM)

Ch1 290.3 mVrms

### Gain (5/15/2023 5:57:17.991 PM)

Ch1 1.475 dB

### THD+N Ratio (5/15/2023 5:57:17.991 PM)

Ch1 ---- %

### Frequency (5/15/2023 5:57:17.991 PM)

Ch1 ---- Hz

## Sequence Report



Line Gain +10 600 Termination : Level and Gain +10


Waveform: Sine

Generator Level: -10.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:57:20.930 PM)

Channel	Lower Limit	Value	Upper Limit	
Ch1	+8.500 dBu	-8.535 dBu	+11.500 dBu	

Result:  FAILED

## Sequence Report



Line Gain +10 200k Termination Level Hi : Signal Path Setup

Output Connector: Analog Balanced  
Channels: 1  
Source Impedance: 100 ohm  
AG52 Generator Option: Installed  
Output EQ: None  
Input Connector: Analog Balanced  
Channels: 1  
Channel: Ch1  
Termination: 200 kohm  
Input Bandwidth: AC (<10 Hz) - 90k (192 kHz SR)  
Device Delay: 0.000 s  
Input EQ: None

### • References

dBr G: 100.0 mVrms  
dBm (Output Power): 600.0 ohm  
W(watts) (Output Power): 8.000 ohm  
Shared Frequency Reference: 1.00000 kHz  
dBrA: 1.000 Vrms  
dBrB: 1.000 Vrms  
dBrA Offset: 0.000 dB  
dBrB Offset: 0.000 dB  
dBSPL1: 10.00 mVrms  
dBSPL2: 10.00 mVrms  
dBSPL1 Calibrator Level: 94.000 dB SPL  
dBSPL2 Calibrator Level: 94.000 dB SPL  
dBm (Input Power): 600.0 ohm  
W(watts) (Input Power): 8.000 ohm

### • DCX

DC Output 1: 0.000 V  
DC Output 1: Off  
DC Output 2: 0.000 V  
DC Output 2: Off  
Port A (hex): 00  
Port B (hex): 00  
Port C (hex): 00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Line Gain +10 200k Termination Level Hi : Verify Connections

Waveform: Sine

Generator Level: -20.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

### RMS Level (5/15/2023 5:57:26.315 PM)

Ch1 300.8 mVrms

### Gain (5/15/2023 5:57:26.315 PM)

Ch1 11.785 dB

### THD+N Ratio (5/15/2023 5:57:26.315 PM)

Ch1 ---- %

### Frequency (5/15/2023 5:57:26.315 PM)

Ch1 ---- Hz




## Sequence Report



Line Gain +10 200k Termination Level Hi : Noise Recorder (RMS) CW

Waveform: None  
Low-pass Filter: 20 kHz  
Weighting Filter: Signal Path  
High-pass Filter: 20 Hz  
Sweep Time: 0.00:00:03.000  
Reading Rate: 10/sec  
Input Bandwidth: Use Signal Path  
Record Acquisition: False  
Measured 1 5/15/2023 5:57:31 PM

RMS Level (5/15/2023 5:57:31.630 PM)



Ch1 Failed Upper Limit

Result: FAILED

5/15/2023 5:58 PM

Page 41 of 54



## Sequence Report



### Line Gain +10 200k Termination Level Low : Signal Path Setup

Output Connector:	Analog Balanced
Channels:	1
Source Impedance:	100 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Balanced
Channels:	1
Channel:	Ch1
Termination:	200 kohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

#### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBrA:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

#### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00
Port C (hex):	00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Line Gain +10 200k Termination Level Low : Verify Connections

Waveform: Sine

Generator Level: -20.000 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

### RMS Level (5/15/2023 5:57:37.120 PM)

Ch1 292.0 mVrms

### Gain (5/15/2023 5:57:37.120 PM)

Ch1 11.526 dB

### THD+N Ratio (5/15/2023 5:57:37.120 PM)

Ch1 ---- %

### Frequency (5/15/2023 5:57:37.120 PM)

Ch1 ---- Hz


## Sequence Report



Line Gain +10 200k Termination Level Low : Noise Recorder (RMS) CCW

Waveform: None  
Low-pass Filter: 20 kHz  
Weighting Filter: Signal Path  
High-pass Filter: 20 Hz  
Sweep Time: 0.00:00:03.000  
Reading Rate: 10/sec  
Input Bandwidth: Use Signal Path  
Record Acquisition: False  
Measured 1 5/15/2023 5:57:43 PM

RMS Level (5/15/2023 5:57:43.077 PM)



Ch1 Failed Upper Limit

Result: FAILED

5/15/2023 5:58 PM

Page 45 of 54



## Sequence Report



### Hi Z Gain -10 2.2M 200k Termination : Signal Path Setup

Output Connector:	Analog Balanced
Channels:	2
Source Impedance:	100 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Balanced
Channels:	1
Channel:	Ch1
Termination:	200 kohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

#### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBrA:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

#### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00
Port C (hex):	00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Hi Z Gain -10 2.2M 200k Termination : Verify Connections

Waveform: Sine

Generator Level: -22.300 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

#### RMS Level (5/15/2023 5:57:48.370 PM)

Ch1 286.5 mVrms

#### Gain (5/15/2023 5:57:48.370 PM)

Ch1 13.662 dB

#### THD+N Ratio (5/15/2023 5:57:48.370 PM)

Ch1 ---- %

#### Frequency (5/15/2023 5:57:48.370 PM)

Ch1 ---- Hz



## Sequence Report



Hi Z Gain -10 2.2M 200k Termination : Level and Gain 2.2M


Waveform: Sine

Generator Level: -22.300 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:57:51.643 PM)

Channel	Lower Limit	Value	Upper Limit	
Ch1	-2.000 dBu	-8.604 dBu	+2.000 dBu	

Result:  FAILED

## Sequence Report



Hi Z Gain -10 47k 200k Termination : Signal Path Setup

Output Connector: Analog Balanced  
Channels: 2  
Source Impedance: 100 ohm  
AG52 Generator Option: Installed  
Output EQ: None  
Input Connector: Analog Balanced  
Channels: 1  
Channel: Ch1  
Termination: 200 kohm  
Input Bandwidth: AC (<10 Hz) - 90k (192 kHz SR)  
Device Delay: 0.000 s  
Input EQ: None

### • References

dBr G: 100.0 mVrms  
dBm (Output Power): 600.0 ohm  
W(watts) (Output Power): 8.000 ohm  
Shared Frequency Reference: 1.00000 kHz  
dBrA: 1.000 Vrms  
dBrB: 1.000 Vrms  
dBrA Offset: 0.000 dB  
dBrB Offset: 0.000 dB  
dBSPL1: 10.00 mVrms  
dBSPL2: 10.00 mVrms  
dBSPL1 Calibrator Level: 94.000 dB SPL  
dBSPL2 Calibrator Level: 94.000 dB SPL  
dBm (Input Power): 600.0 ohm  
W(watts) (Input Power): 8.000 ohm

### • DCX

DC Output 1: 0.000 V  
DC Output 1: Off  
DC Output 2: 0.000 V  
DC Output 2: Off  
Port A (hex): 00  
Port B (hex): 00  
Port C (hex): 00

5/15/2023 5:58 PM

## Sequence Report



Port D (hex): 00

- Clocks

Output Rate: Track Output SR

Sync Out Level: 3.300 V

Sync Out Polarity: Normal

Timebase Reference: Internal

Jitter: Disabled

- Triggers

Source: Off

Input Logic Level: 3.300 V

Edge: Rising

### Hi Z Gain -10 47k 200k Termination : Verify Connections

Waveform: Sine

Generator Level: -22.300 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

### RMS Level (5/15/2023 5:57:57.125 PM)

Ch1 288.2 mVrms

### Gain (5/15/2023 5:57:57.125 PM)

Ch1 13.711 dB

### THD+N Ratio (5/15/2023 5:57:57.125 PM)

Ch1 ---- %

### Frequency (5/15/2023 5:57:57.125 PM)

Ch1 ---- Hz

## Sequence Report



Hi Z Gain -10 47k 200k Termination : Level and Gain 47K


Waveform: Sine

Generator Level: -22.300 dBu

DC Offset: 0.000 V

Frequency: 1.00000 kHz

RMS Level (5/15/2023 5:57:59.878 PM)

Channel	Lower Limit	Value	Upper Limit	
Ch1	-8.000 dBu	-8.674 dBu	-4.000 dBu	

Result:  FAILED

## Sequence Report



### Dummy Signal Path For Report : Signal Path Setup

Output Connector:	Analog Unbalanced
Channels:	2
Source Impedance:	50 ohm
AG52 Generator Option:	Installed
Output EQ:	None
Input Connector:	Analog Unbalanced
Channels:	2
Termination:	100 kohm
Input Bandwidth:	AC (<10 Hz) - 90k (192 kHz SR)
Device Delay:	0.000 s
Input EQ:	None

#### • References

dBr G:	100.0 mVrms
dBm (Output Power):	600.0 ohm
W(watts) (Output Power):	8.000 ohm
Shared Frequency Reference:	1.00000 kHz
dBrA:	1.000 Vrms
dBrB:	1.000 Vrms
dBrA Offset:	0.000 dB
dBrB Offset:	0.000 dB
dB SPL1:	10.00 mVrms
dB SPL2:	10.00 mVrms
dB SPL1 Calibrator Level:	94.000 dB SPL
dB SPL2 Calibrator Level:	94.000 dB SPL
dBm (Input Power):	600.0 ohm
W(watts) (Input Power):	8.000 ohm

#### • DCX

DC Output 1:	0.000 V
DC Output 1:	Off
DC Output 2:	0.000 V
DC Output 2:	Off
Port A (hex):	00
Port B (hex):	00
Port C (hex):	00
Port D (hex):	00

5/15/2023 5:58 PM

## Sequence Report



- Clocks

Output Rate:	Track Output SR
Sync Out Level:	3.300 V
Sync Out Polarity:	Normal
Timebase Reference:	Internal
Jitter:	Disabled

- Triggers

Source:	Off
Input Logic Level:	3.300 V
Edge:	Rising

### Dummy Signal Path For Report : Verify Connections

Waveform:	Sine
Generator Level:	100.0 mVrms
DC Offset:	0.000 V
Frequency:	1.00000 kHz

### RMS Level (5/15/2023 5:58:03.618 PM)

Ch1	291.3 mVrms
Ch2	287.2 mVrms